


DRIVEWAY PERMIT — SITE PLAN [REV. 1 — APR 2026]

8506 Seven Coves Court · Hillsborough County, FL · After-the-fact ROW Permit

ADDRESS: 8506 Seven Coves Ct, Tampa FL 33634
MATERIAL: 6" Reinf. Conc. on 6" Comp. Base
SCALE: Approx. 1" = 8 ft
DATE: April 2026 — Rev. 1
SHEET: 1 of 2 — Site Plan



UTILITY SYMBOLS (in ROW)

- Water Meter (WM)**
min. 1 ft ✓
Located in ROW grass / swale. No relocation.
- Electric Box (EB)**
min. 3 ft ✓
Surface pad. No relocation.

SEPARATIONS @ EOP

- DW1 ↔ DW2: **10 ft** (min. 10 ft) ✓
- DW1 ↔ Neighbor DW: **10 ft** (min. 10 ft) ✓
- DW1 setback from L. PL corner: **5 ft**
- DW2 to start of PL curve: **17 ft**

ROW GEOMETRY

- ROW total: **50 ft** (25 ft each side of CL)
- Pavement: **24 ft** (12 ft each side of CL)
- Grass / swale (PL → EOP): **13 ft**
- Utility easement: **5 ft** inside PL
- Frontage: **59 ft**



 CONCRETE DRIVEWAY (6" / 6")

 ROADWAY PAVEMENT

 ROW GRASS / SWALE

 UTILITY EASEMENT (5 ft)

 PRIVATE PROPERTY

 NEIGHBOR DW (schematic)

 WATER METER (WM)

 ELECTRIC BOX (EB)

NOTES, LEGEND & PROJECT INFORMATION [REV. 1 — APR 2026]

8506 Seven Coves Court · Hillsborough County, FL · Sheet 2 of 2

CONSTRUCTION NOTES (Revised)

- 1. All driveway construction: 6" reinforced concrete on 6" compacted base material (limerock or equivalent). Pre-existing condition; no new construction proposed.
- 2. DW1 width: 17 ft. DW2 width: 10 ft. Both rectangular cross-section.
- 3. Separation DW1 to DW2 measured at EOP between the straight edges (no flares constructed) = 10 ft. County minimum: 10 ft. **MEETS REQUIREMENT.**
- 4. Neighboring driveway separation, measured at EOP from DW1 left edge = 10 ft (field measurement). County min: 10 ft. **MEETS.** See dashed indication on Sheet 1.
- 5. Water meter (WM) clearance to DW1: 3 ft (county min. 1 ft). ✓
- 6. Electric box (EB) clearance to DW2: 3 ft (county min. 3 ft). ✓
- 7. No trees, signs, drainage structures, fire hydrants, or other utilities within the ROW driveway area.
- 8. DW1 set back 5 ft from the left property corner (dimensioned on Sheet 1).
- 9. Property line at NE corner curves at R = 14 ft (cul-de-sac geometry). This is **NOT** a driveway flare. DW2 right edge clears the start of the curve by 17 ft.
- 10. SOD to be restored in any disturbed ROW areas.
- 11. Contractor / homeowner to call 811 (Sunshine 811) before any excavation. (No excavation proposed.)
- 12. ROW = 50 ft total (25 ft each side of CL). Roadway pavement = 24 ft total (12 ft each side of CL). Distance from EOP to property line = 13 ft (grass / swale).
- 13. Utility easement: 5 ft strip on the inside of the property line. No utilities within easement conflict with either driveway.
- 14. No public utilities (water main, sanitary sewer, storm pipe, gas, comms) are crossed or relocated by the existing driveways. WM and EB are surface assets only and clearances meet County minimums.
- 15. Driveways pre-existing at time of property purchase (December 22, 2025). This permit is filed after-the-fact for legalization to Hillsborough County standards.

Highlight key: green = revised note · yellow = new note added in Rev. 1

PROJECT INFORMATION

Project Address: 8506 Seven Coves Ct, Tampa FL 33634
County: Hillsborough County, Florida
Permit Type: After-the-fact ROW — Driveway Access (Legalization)
Number of Driveways: Two (2) — DW1 & DW2
Lot Type: Interior residential, no sidewalk, on cul-de-sac
Property Frontage: 59 ft
Scale: Approx. 1" = 8 ft
Drawing Date: April 2026 — Revision 1
Date Acquired: December 22, 2025 (driveways pre-existing)

DRIVEWAY DIMENSIONS

DW1 Width: 17 ft
DW1 Material: 6" Reinf. Conc. on 6" Comp. Base
DW1 Setback (left PL corner): 5 ft
DW2 Width: 10 ft
DW2 Material: 6" Reinf. Conc. on 6" Comp. Base
DW2 Clearance to PL Curve: 17 ft
Separation DW1 ↔ DW2 @ EOP: 10 ft (min. 10 ft) ✓
Driveway Geometry: Rectangular; no flares (existing condition)
PL Curve at NE corner: R = 14 ft (cul-de-sac PL, not a driveway flare)

MINIMUM SEPARATION REQUIREMENTS — Hillsborough County ROW

Requirement	County Min	As Shown	Status
DW1 ↔ DW2 separation @ EOP	10 ft	10 ft	MEETS ✓
WM to driveway edge	1 ft	3 ft	MEETS ✓
EB to driveway edge	3 ft	3 ft	MEETS ✓
Utility / tree / structure to driveway	3 ft	3 ft min.	MEETS ✓
Neighbor DW to DW1 @ EOP	10 ft	10 ft	MEETS ✓
Driveways limited to property side of EOP	required	terminate at EOP	REVISED ✓

CONCRETE DRIVEWAY

ROADWAY PAVEMENT

ROW GRASS / SWALE

UTILITY EASEMENT (5 ft)

PRIVATE PROPERTY

NEIGHBOR DW (schematic)

NUMBERED CALLOUT

Applicant signature

Date: _____

Applicant printed name

Property: 8506 Seven Coves Ct, Tampa FL 33634

Sheet 2 of 2 — Notes & Legend · **REV. 1 — INCORPORATES REVIEWER COMMENTS (Issues #1, #2, #3)**