

Script 1 — Surface Water, Ground Water, and the Microbial Rules

Recording script. Target ~18–20 minutes at a normal reading pace. Headers, bracketed notes, and timing estimates are for your reference and are not read aloud.

The Surface Water Treatment Rules

1. Multi-barrier framing [~1 min]

The rules covered in this script all share one idea: the multi-barrier treatment approach. The concept is that a plant uses several different treatment processes in series, so that if any one process fails or underperforms, the others pick up the slack and keep the finished water safe. A system that relies on only one or two processes has no backup when something goes wrong. Every surface water rule that follows is built to reinforce that principle: multiple independent barriers against pathogens, with monitoring at each barrier so a problem shows up before it reaches the customer.

The pathogens these rules target are *Cryptosporidium*, *Giardia*, and viruses. The two core barriers are filtration, which physically removes organisms, and disinfection, which inactivates what gets through.

2. The Surface Water Treatment Rules [~10 min]

The Surface Water Treatment Rules consist of five rules built up over several decades. They apply to any system using surface water, or groundwater under the direct influence of surface water.

The original Surface Water Treatment Rule set the foundation. It required 3-log (99.9%) inactivation of *Giardia*, and 4-log (99.99%) inactivation of viruses, through filtration and disinfection. The SWTR set the first turbidity limits for the combined filter effluent, or CFE: a 95th percentile at or below 0.5 NTU, and never above 5 NTU. It also set the disinfectant residual requirements: at least 0.2 mg/L entering the distribution system, and a detectable residual in at least 95 percent of distribution system samples across any two consecutive months.

Turbidity is the real-time indicator of how well filtration is working. Low turbidity means the filter is capturing particles, including *Giardia*. When turbidity rises, that is the signal that the physical barrier is weakening.

The next two rules were the Interim Enhanced Surface Water Treatment Rule and the Long Term 1 Enhanced Surface Water Treatment Rule. They carried effectively the same requirements, but the Interim Enhanced rule came first and applied to larger systems, while LT1 applied to smaller systems.

These rules tightened turbidity requirements to the limits in force today: a CFE 95th percentile at or below 0.3 NTU, and never above 1 NTU. They added individual filter effluent (IFE) monitoring, which is continuous turbidity monitoring on each filter, recorded every 15 minutes. The CFE can hide one bad filter. Monitoring the output of each filter allows an operator to understand when one or more may be underperforming. When an individual filter crosses certain turbidity triggers, the operator must respond, with steps that escalate from producing a filter profile, to a filter self-assessment, to a comprehensive performance evaluation if the problem persists. IFE triggers are based on two consecutive readings taken 15 minutes apart and include:

- Above 0.5 NTU 4 hours after a backwash or return to service results in a filter profile.

- Above 1.0 NTU results in a filter profile.
- The same filter, 3 months in a row with readings above 1.0 NTU results in a filter self-assessment.
- The same filter, 2 months in a row with readings above 2.0 NTU results in a comprehensive performance evaluation.

These rules also added 2-log (99%) removal of *Cryptosporidium* through filtration. Crypto is the pathogen that drove much of this tightening, because it has a hard outer shell that resists chlorine at normal doses. The defense against it leans heavily on physical removal by filtration. The rules also required sanitary surveys by the state, introduced disinfection profiling and benchmarking, and required new finished-water storage reservoirs to be covered.

The Filter Backwash Recycling Rule addresses plants that recycle their backwash water, or any liquids derived from a solids separation process, such as filtrate from a belt press or supernatant from a settling pond. These liquids are full of the particles and pathogens in a concentrated form. Sending them back into the plant carelessly can introduce a slug of Crypto ahead of treatment.

In California, Title 22 requires recycle flows to be treated via solids removal and returned to the headworks of the plant. It also requires monitoring the turbidity and flow of the recycle stream. Through the rule's Technical Guidance Manual and California's *Cryptosporidium* Action Plan, goals of a recycle flow rate under 10 percent of the plant's influent flow and under 2 NTU are heavily encouraged, often winding up in a plant's operating permit. The goal is to limit overwhelming the main treatment train with a heavy Crypto load.

The last rule in the family is the Long Term 2 Enhanced Surface Water Treatment Rule. LT2 targets Crypto specifically. It required systems to monitor their source water for Crypto, and based on the average level found, placed each system into one of four bins. Bin 1 is the lowest contamination and requires no additional Crypto treatment. Bins 2 through 4 require progressively more treatment on top of what the earlier rules already require.

Water systems use the Microbial Toolbox, which is an EPA technical guidance manual that details the options a system can utilize to earn a set amount of log-removal or log-inactivation credit. The tools fall into categories: source protection and management, additional pretreatment, improved existing filtration performance, additional filtration, and additional inactivation through disinfection. A system can combine tools to reach its required credit. LT2 also required existing uncovered finished-water reservoirs to be covered, or the water re-treated before entering the distribution system.

Disinfection credit under these rules is measured by CT, which is disinfectant concentration multiplied by contact time. A required CT value must be met to claim a given level of *Giardia* or virus inactivation. The two levers an operator controls are the residual concentration and the contact time the water spends before the first customer. Two water conditions also affect it: colder water and higher pH both require more CT to achieve the same inactivation. Systems using chlorine dioxide, ozone, or ultraviolet

light can also earn additional Crypto inactivation credit under LT2, since those disinfectants are effective against Crypto where free chlorine is not.

3. The Ground Water Rule [~3 min]

The Ground Water Rule takes a different approach from the surface water rules. Groundwater is generally better protected than surface water, so the rule does not impose blanket filtration or disinfection on every system. Instead, it is risk-targeted: it identifies the groundwater systems that are vulnerable to fecal contamination and directs treatment there.

The GWR works through four parts.

First, sanitary surveys by the state to find significant deficiencies that make a system vulnerable to contamination. After the initial survey, these run every 3 years for community water systems, and every 5 years for community systems that provide 4-log virus treatment or have strong performance records.

Second, triggered source water monitoring: when a routine distribution coliform sample comes back total-coliform-positive, a system that is not already providing 4-log treatment must sample its source water to check whether the contamination is coming from the source.

Third, corrective action: if the source sample shows fecal contamination, or a sanitary survey finds a significant deficiency, the system must fix it. The options are to correct the deficiency, eliminate the source of contamination, provide an alternate source, or install treatment that reliably achieves 4-log virus treatment before the first customer.

Fourth, compliance monitoring: a system that provides 4-log virus treatment monitors that treatment to confirm it is working, and in exchange avoids the triggered source sampling.

4. The Total Coliform and Revised Total Coliform Rules [~4 min]

The Total Coliform Rules consist of the original Total Coliform Rule and the Revised Total Coliform Rule. The revised rule did not throw out the original. It kept most of the original rule's sampling framework but changed how a system responds when coliforms show up.

The original Total Coliform Rule established distribution system monitoring for coliforms. It required systems to collect routine samples on a schedule based on the population served. If a routine sample came back total-coliform-positive, the system had to collect a repeat sample set within 24 hours: a repeat at the original location, and samples within five service connections upstream and downstream. The TCR also established a total coliform MCL, with two kinds of violations. A monthly violation occurred when a system taking 40 or more samples had more than 5 percent of its samples positive. An acute violation occurred when any repeat sample was E. coli-positive, or when an E. coli-positive routine sample was followed by a total coliform-positive repeat.

The Revised Total Coliform Rule built on the TCR framework. Its biggest change was to eliminate the total coliform maximum contaminant level altogether. Total coliforms are common in the environment and are not by themselves proof of fecal contamination, so under the RTCR a positive total coliform result is no longer a violation and instead becomes a trigger to investigate. In place of the total

coliform MCL, the revised rule added a standalone E. coli MCL, since E. coli is the reliable indicator of actual fecal contamination, and it added a find-and-fix treatment technique.

The old numbers carried forward, but their meaning changed. The same thresholds that used to define a monthly MCL violation now trigger a Level 1 assessment and are no longer an MCL violation themselves.

The sampling framework carried forward. Routine sampling still follows a written Bacteriological Sample Siting Plan, and every total-coliform-positive sample is tested for E. coli.

The find-and-fix approach is the heart of the RTRC, and has two levels.

A Level 1 assessment is conducted by the system's own operator. It is triggered when a system taking 40 or more samples per month has more than 5 percent of its samples positive; or when a system fails to take all its required repeat samples.

A Level 2 assessment is more serious and is conducted by the state or a state-approved third party. It is triggered by an E. coli MCL violation, or by a system on annual monitoring hitting a Level 1 trigger two years in a row.

The purpose of both assessments is to find the sanitary defect and correct it. The assessment form goes to the state within 30 days of the trigger, with corrective action completed by then or on a state-approved schedule.

An E. coli MCL violation can signal an acute health risk and requires Tier 1 public notification.

5. Close [~1 min]

Everything in this script comes back to the multi-barrier approach. Filtration and disinfection are the two core barriers against pathogens in surface water. Turbidity monitoring watches the filtration barrier in real time. CT confirms the disinfection barrier. The enhanced rules added Crypto protection because it resists chlorine. The Filter Backwash Recycling Rule keeps a plant from undermining its own barriers. The Ground Water Rule extends risk-based protection to vulnerable groundwater. And the Total Coliform Rules monitor the distribution system for signs that a barrier has failed somewhere between the plant and the customer. Each rule adds a layer, and each layer has its own monitoring, so a failure shows up early.