


ORIGINAL DRAWING SIZE IS 30"x 42"; SCALE ENTITIES ACCORDINGLY IF REDUCED/ENLARGED


P SHEET NO. 01 OF 07



1 LOWER LEVEL PLAN - PLUMBING DOMESTIC WATER

SCALE: 1/4" = 1'-0"

0 2' 4' 8'




Setty DC Office
1415 Elliot Place, NW

ISSUES AND REVISIONS							
No.	Description	Date					

Drawn/CheckedAuthor / CheckerProject NumberSYY220001DC01Drawing DateDDBid DateBDPermit DatePD

LEVEL 1 - PLUMBING DOMESTIC WATER



1 LOWER LEVEL PLAN - PLUMBING SANITARY AND GAS
P102 SCALE: 1/4" = 1'-0"
0 2' 4' 8'




Setty DC Office
1415 Elliot Place, NW

ISSUES AND REVISIONS						
No.	Description	Da ⁻				

Drawn/CheckedAuthor / CheckerProject NumberSYY220001DC01Drawing DateDDBid DateBDPermit DatePD

LEVEL 1 - PLUMBING SANITARY AND GAS






Setty DC Office
1415 Elliot Place, NW

ISSUES AND REVISIONS						
lo.	Description	Date				
	<u> </u>	·				

Drawn/CheckedAuthor / CheckerProject NumberSYY220001DC01Drawing DateDDBid DateBDPermit DatePD

LEVEL 2 - PLUMBING






Setty DC Office
1415 Elliot Place, NW

	ISSUES AND REVISIONS	S
No.	Description	Date

Drawn/CheckedAuthor / CheckerProject NumberSYY220001DC01Drawing DateDDBid DateBDPermit DatePD

ROOF PLAN - PLUMBING



DOMESTIC WATER HEATER SCHEDULE											
ID	FIXTURE	LOCATION	MANUFACTURER	MODEL	TYPE	GAS INPUT (MBH)	VOLTAGE	PHASE	TANK STORAGE (GALLONS)	RECOVERY GPM 90° F RISE	EXPANSION TANK
DWH-1	DOMESTIC WATER HEATER	MECHANICAL_008	BRADFORD WHITE	RG250T6N	GAS	40	120 V	1	50 Gallon	0.710 GPM	WATTS DETA 12 TANK VOLUME - 5 GAL

			NATU	JRAL GAS EQUIPI	MENT SCHEDULE		
ID	DESCRIPTION	PRV DETAILS	GAS SERVICE	EQUIPMENT LOCATION			
DWH-1	DOMESTIC WATER HEATER	1	40	3/4"	PRV WITH VENT LIMITERS, NO PRV VENTING REQUIRED	2 PSI	MECHANICAL 008
F-6	GAS RANGE	1	120	3/4"	PRV WITH VENT LIMITERS, NO PRV VENTING REQUIRED	2 PSI	KITCHEN 106
BOILER	BOILER	1	410	1"	PRV WITH VENT LIMITERS, NO PRV VENTING REQUIRED	2 PSI	MECHANICAL 008
AHU-1	AIR HANDILING	1	180	3/4"	PRV WITH VENT LIMITERS, NO PRV VENTING REQUIRED	2 PSI	LOW ROOF
AHU-2	AIR HANDILING	1	180	3/4"	PRV WITH VENT LIMITERS, NO PRV VENTING REQUIRED	2 PSI	LOW ROOF
	TOTAL MBH		930				

	BACKFLOW PREVENTOR						
ID	FIXTURE	MANUFACTURER	MODEL	DISCRIPTION			
BFP-1	DOUBLE CHECK VALVE ASSEMBLY (DCVA)	ZURN	350 SERIES	4" INCOMING DOMESTIC WATER SERVICE, ASSE #1015.			



Setty DC Office
1415 Elliot Place, NW

ISSUES AND REVISIONS						
No.	Description	Date				
	1					

Drawn/CheckedAuthor / CheckerProject NumberSYY220001DC01Drawing DateDDBid DateBDPermit DatePD

PLUMBING SCHEDULES

