


INSTRUMENT TAGNAME MATRIX				
FIRST-LETTER		SUCCEEDING-LETTERS		
	BASE	MODIFIER	PASSIVE FUNCTION	OUTPUT FUNCTION
				MODIFIER
A	ANALYSIS	---	ALARM	---
C	---	---	---	CONTROL
D	---	DIFFERENTIAL	---	---
E	VOLTAGE	---	ELEMENT	---
F	FLOW	RATIO	---	---
G	---	---	GLASS	---
H	HAND	---	---	HIGH
I	CURRENT	---	INDICATE	---
J	POWER	---	---	---
K	TIME	RATE OF CHANGE	---	---
L	LEVEL	---	LIGHT	LOW
M	HUMIDITY	MOMENTARY	---	MIDDLE
O	---	---	ORIFICE	OPEN
P	PRESSURE	---	---	---
Q	QUANTITY	TOTALIZE	---	---
S	SPEED , FREQUENCY	---	---	SWITCH
T	TEMPERATURE	---	---	TRANSMITTER
V	VIBRATION	---	---	VALVE
Y	EVENT, STATE	---	---	---
Z	POSITION	---	---	---

REV. NO.	DATE	DESCRIPTION	FOSDICK & HILMER 309 VINE STREET, SUITE 50 TELEPHONE (513)241-5640		CONSULTING ENGINEERS CINCINNATI, OHIO 45202 WWW.FHENG.COM				Jimmy Huntington Building 714 Fourth Avenue, Suite 20 Fairbanks, Alaska 99701 Telephone (907) 455-1500 Fax (907) 455-6788		Date: 19 FEB 2010	Scale: NTS		UTILITY SERVICE EXTENSION TO AIRCRAFT PARTS STORAGE SYMBOLS, ABBREVIATIONS & GENERAL NOTES		Drawing No. X-02
0	05/09/11	RECORD DRAWING										Designed By: JRS				
												Drawn By: JRS				
												Checked By: EAE				