


MID LEVEL PLAN
SCALE: 1/4"=1'-0"

-  **DRAWING NOTES:**
1. FIELD DEVICES SHALL BE WIRED TO CP-G693 IN VAULT G6-9-3.
 2. CONTROL PANEL SHALL BE WALL-MOUNTED BY ELECTRICAL CONTRACTOR, 36" A.F.F.
 3. THIS FIELD DEVICES REQUIRES (3) BELDEN 8760 CABLES.

LOWER LEVEL PLAN
SCALE: 1/4"=1'-0"

REV. NO.	DATE	DESCRIPTION	FOSDICK & HILMER CONSULTING ENGINEERS 309 VINE STREET, SUITE 50 CINCINNATI, OHIO 45202 TELEPHONE (513)241-5640 WWW.FHENG.COM		Date: 17 FEB 2010 Scale: 1/4"=1'-0" Designed By: JRS Drawn By: RHW Checked By: EAE	UTILITY SERVICE EXTENSION TO AIRCRAFT PARTS STORAGE NEW VAULT G6-9-3 FORT GREELY, AK. DU PROJECT NO. J101395, 101396, 101397	Drawing No. PC-04
0	05/09/11	RECORD DRAWING					