



GENERAL DETAIL NOTES:

- A. BACKFILL MATERIAL ABOVE THE CONDUIT BEDDING MATERIAL SHALL BE NATIVE MATERIAL IF IT COMPLIES WITH ALASKA DOT SECTION 204 – 2.01, TYPE C.
- B. BACKFILL COMPACTION SHALL COMPLY WITH ALASKA DOT SECTION 301 – 3.03. MOISTURE/DENSITY RELATIONS OF SOILS SHALL BE CALCULATED IN ACCORDANCE WITH AASHTO T 99 OR T 180.
- C. PROVIDE (2) 2" SCHEDULE 40 HDPE CONDUITS.
- D. PROVIDE SPACERS AT A MINIMUM OF EVERY 8'-0".



DETAIL 1 DUCT BANK  
N.T.S.  
E-04  
E-05

REV. NO.	DATE	DESCRIPTION	FOSDICK & HILMER CONSULTING ENGINEERS 309 VINE STREET, SUITE 50 TELEPHONE (513)241-5640 CINCINNATI, OHIO 45202 WWW.FHENG.COM	 Doyon Utilities Jimmy Huntington Building 714 Fourth Avenue, Suite 20 Fairbanks, Alaska 99701 Telephone (907) 455-1500 Fax (907) 455-6788	Date: 23 FEB 2010	UTILITY SERVICE EXTENSION TO AIRCRAFT PARTS STORAGE DUCT BANK DETAIL FORT WAINWRIGHT, AK. DU PROJECT NO. J101395, J101396, J101397	Drawing No.  E-08
	04/09/10	ISSUED FOR CONSTRUCTION			Scale: NTS		
					Designed By: LBG		
					Drawn By: EMS		
					Checked By: NEM		