


WALL PLATE 1  
H006



PIPE GUIDE 2  
H006

#### NOTES:

- ITEMS 2 AND 3 ARE TO BE SANDBLASTED AND EPOXY COATED AFTER FABRICATION.
- PROVIDE SLOTTED BOLT HOLES LONGITUDINALLY FOR 1\"
- PIPE GUIDE SIZE NUMBER IS DETERMINED BY DIAMETER OF PIPE AND THICKNESS OF INSULATION.
- TOUCH-UP PAINT REQUIRED FOR AREAS DAMAGED DURING INSTALLATION.

#### DIMENSIONS:

PIPE SIZE	GUIDE SIZE *	2			3		1	5
		STRUCTURAL TEE	A	B HOLE DIA.	C	D	E	BOLT SIZE
2"	C	WT5x19.5	7-7/8"	5/8"	15"	10"	6"	1/2"Øx2"
3"	C	WT5x19.5	7-7/8"	5/8"	15"	10"	6"	1/2"Øx2"
4"	C	WT5x19.5	7-7/8"	5/8"	15"	10"	6"	1/2"Øx2"
6"	E	WT5x19.5	9-3/4"	3/4"	15"	10"	8"	5/8"Øx2"
8"	E	WT5x19.5	9-3/4"	3/4"	15"	10"	8"	5/8"Øx2"
10"	F	WT6x25	14-1/8"	1"	15"	12"	8"	3/4"Øx2"
12"	F	WT6x25	14-1/8"	1"	15"	12"	8"	3/4"Øx2"
14"	G	WT6x25	15-7/8"	1"	15"	12"	8"	3/4"Øx2"
16"	G	WT6x25	15-7/8"	1"	15"	12"	8"	3/4"Øx2"
18"	H	WT8x44	16-3/8"	1"	18"	14"	10"	3/4"Øx2"
20"	H	WT8x44	16-3/8"	1"	18"	14"	10"	3/4"Øx2"
24"	J	WT8x44	17-1/8"	1"	18"	14"	10"	3/4"Øx2"

\* GUIDE SIZE BASED ON STEAM PIPE DIAMETER PLUS 3\"

#### MATERIAL LIST:

ITEM	DESCRIPTION
1	ANVIL FIG. 256 PIPE GUIDE
2	STRUCTURAL TEE. SEE TABLE THIS SHEET.
3	1/2\"
4	1/2\"
5	STAINLESS STEEL MOUNTING BOLT, WASHERS AND NUT (TYPICAL OF 4). SEE TABLE THIS SHEET. FOR SIZE.



Jimmy Huntington Building  
714 Fourth Avenue, Suite 201  
Fairbanks, Alaska 99701  
Telephone (907) 455-1500  
Fax (907) 455-6788

Date: 14 FEB 2010  
Scale: 1\"

UTILIDOR & VAULT PIPE SUPPORT SYSTEM  
STEAM & CONDENSATE SUPPORT GUIDE DETAILS  
DESIGN & CONSTRUCTION STANDARDS

Drawing No.

UES-DD-H006