

GENERAL STRUCTURAL NOTES

A. DESIGN CRITERIA

1. ACCESS VAULT DESIGN STANDARDS..... ACI 318-05, AISC LATEST EDITION
2. ACCESS VAULT LOADS:
LIVE LOAD 100 PSF
3. SEISMIC LOADS:
OCCUPANCY CATEGORY..... II
SDS..... 0.784
SD1..... 0.37
SITE CLASS D

B. FOUNDATION

1. AT ACCESS VAULTS, DO NOT BACK FILL WALLS UNTIL ACCESS VAULT LIDS ARE IN PLACE AND CONCRETE HAS ACHIEVED DESIGN STRENGTH. BRING GRADE UP EVENLY (WITH MAXIMUM 8" LIFTS) ON ALL SIDES TO FINAL ELEVATIONS.

C. CONCRETE

1. ALL CAST-IN-PLACE CONCRETE SHALL HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH ($f'c$) OF 4000 PSI.
2. REINFORCING BARS SHALL CONFORM TO ASTM A615 GRADE 60, UNLESS OTHERWISE NOTED, EXCEPT #3 BARS WHICH MAY BE GRADE 40.
3. DETAIL REINFORCING BARS IN ACCORDANCE WITH THE ACI DETAILING MANUAL AND THE ACI BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE, LATEST EDITION.
4. CONCRETE SHALL MEET ALL REQUIREMENTS OF ACI 301 SPECIFICATION FOR STRUCTURAL CONCRETE BUILDINGS.
5. HORIZONTAL FOUNDATION AND WALL REINFORCING SHALL BE CONTINUOUS AROUND CORNERS AND INTERSECTIONS; PROVIDE CORNER BARS.
6. LAP ALL REINFORCING 61 BAR DIAMETERS.
7. PROVIDE ALL ACCESSORIES NECESSARY TO SUPPORT REINFORCING AT POSITIONS SHOWN ON THE DRAWINGS. PROVIDE SUFFICIENT TIE BARS TO SUPPORT ALL REINFORCING.
8. PROVIDE REINFORCEMENT COVER AS FOLLOWS, UNLESS NOTED OTHERWISE ON DRAWINGS:
CONCRETE POURED AGAINST EARTH 3"
CONCRETE POURED IN FORMS 1 1/2" TYPICAL EXCEPT AS NOTED BELOW
CONCRETE POURED IN FORMS 2" IF FACE OF CONCRETE IS IN CONTACT WITH EARTH
CONCRETE SLABS ON GRADE PLACE REINFORCING AT SLAB MID-DEPTH

D. STRUCTURAL STEEL

1. ALL STRUCTURAL STEEL WIDE FLANGE MEMBERS SHALL BE ASTM A992 GRADE 50 (F_y = 50 KSI).
2. SQUARE/ RECTANGULAR HOLLOW STRUCTURAL SECTIONS (HSS) SHALL CONFORM TO ASTM A500 GRADE B (F_y = 46 KSI).
3. ROUND HSS (PIPES) SHALL CONFORM TO ASTM A53 GRADE B (F_y = 35 KSI).
4. ANGLES, CHANNELS, AND PLATES SHALL BE ASTM A36 (F_y = 36 KSI).
5. ALL STRUCTURAL STEEL SHALL BE DETAILED AND FABRICATED IN ACCORDANCE WITH THE LATEST EDITION OF THE AISC MANUAL OF STEEL CONSTRUCTION.
6. WELDING SHALL BE PERFORMED WITH E70XX ELECTRODES. WELDING SHALL BE DONE BY QUALIFIED WELDERS AND SHALL CONFORM TO THE LATEST EDITION OF THE AWS CODE. ALL WELDS ARE INTENDED TO BE CONTINUOUS UNLESS NOTED OTHERWISE.
7. FIELD WELDS NOTED THROUGHOUT THE CONTRACT DOCUMENTS ARE ACCEPTABLE LOCATIONS FOR FIELD WELDING. AT THE CONTRACTOR'S OPTION, FIELD WELDS MAY BE PERFORMED IN THE SHOP.

E. GENERAL

1. CONTRACTOR IS TO FIELD VERIFY ALL DIMENSIONS AND ELEVATIONS TO MATCH NEW CONSTRUCTION TO EXISTING CONSTRUCTION.

Date Stamped: 8/20/2010	
By	
Revision	
Date	08/31/11
AS-BUILT	

2515 1st Street
Anchorage, Alaska 99503
(907) 276-4245
544 4th Avenue,
Suite 102
Fairbanks, Alaska 99701
(907) 452-4100
3017 Chitina Drive
Juneau, Alaska 99801
(907) 790-2801
351 W. Parks Highway
Wasilla, Alaska 99564
(907) 376-7815
4411 W 5th Avenue,
Suite 200
Anchorage, Alaska 99501
(907) 276-0805

www.uskh.com

Project:
TUNISTA/
FTW 336A

TUNISTA
FT. WAINWRIGHT, ALASKA

Project Mgr.	
Drawn	FST
Checked	GL
Date	

Sheet Contents:
GENERAL
NOTES

Sheet No.:

S1

USKH W.O. 1267800