



# NOTES:

1. WATER SERVICE PIPE SHALL HAVE A LEVEL OR POSITIVE GRADE FROM THE WATER MAIN TO THE BUILDING (NO HUMPS OR DIPS) TO PREVENT AIR TRAPS.
2. TRACE WIRE SEE DETAIL ON DWG W111.
3. CONTRACTOR WILL ENSURE MATERIALS REQUIRED FOR HOT TAP, ARE AT JOB SITE, AND THE DISINFECTING AND PRESSURE TESTING OF THE SERVICE LINE HAVE BEEN COMPLETED, AND EXCAVATION OF BELL HOLE IS DONE PRIOR TO NOTIFYING THE OWNER.
4. CONSTRUCTOR WILL GIVE THE OWNER 10 WORKING DAYS NOTICE OF THE NEED TO SCHEDULE A TIE-IN TO EXISTING UTILITIES.
5. URETHANE FOAM INSULATION WITHIN SEVEN (7) FEET OF STORM LINES SHALL REQUIRE TWO (2) INCHES OF ADDITIONAL INSULATION.

WATER PIPING TIE-IN DETAIL 1  
1/4"=1'-0" W107



Jimmy Huntington Building  
714 Fourth Avenue, Suite 201  
Fairbanks, Alaska 99701  
Telephone (907) 455-1500  
Fax (907) 455-6788

Date: 14 FEB 2010  
Scale: NOTED  
Designed By: CDH  
Drawn By: DLW  
Checked By: NEM

DIRECT BURIED WATER DISTRIBUTION SYSTEM  
WATER PIPING TIE-IN 4" AND LARGER  
DESIGN & CONSTRUCTION STANDARDS

Drawing No.  
UES-DD-W107