



DETAIL 4 PRESSURE TRANSMITTER  
N.T.S. PC-02

- DETAIL NOTES:**
1. THE 1/2" VALVE CLOSEST TO THE TRANSMITTER IS NOT NEEDED IF DIMENSION "L" IS LESS THAN 15'-0".
  2. FOR STEAM INSTALLATION, INSTALL A PIGTAL IN THIS SECTION FOR HEAT REDUCTION.

REV. NO.	DATE	DESCRIPTION	FOSDICK & HILMER CONSULTING ENGINEERS 309 VINE STREET, SUITE 50 CINCINNATI, OHIO 45202 TELEPHONE (513)241-5640		DOYON UTILITIES Jimmy Huntington Building 714 Fourth Avenue, Suite 20 Fairbanks, Alaska 99701 Telephone (907) 455-1500 Fax (907) 455-6788		Date: 7/21/10 Scale: N.T.S. Designed By: J.T. Drawn By: G.N. Checked By: J.T.		UTILITY SERVICE EXTENSION TO AIRCRAFT PARTS STORAGE UTILITY MONITORING	Fort Wainwright, AK. DU PROJECT NO. J101395, 101396, 101397	Drawing No. PC-08
0	05/09/11	RECORD DRAWING									