

GENERAL INSTALLATION NOTES (M SERIES DRAWINGS):


- A. ABATE ALL ACM AS REQUIRED TO ACCOMPLISH THE WORK SHOWN IN THE CONTRACT DOCUMENTS.
- B. PROVIDE ALL EARTHWORK, EXCAVATION, BACKFILL, AND RESTORATION OF SURFACE CONDITIONS AS REQUIRED TO ACCOMPLISH THE WORK SHOWN IN THE CONTRACT DOCUMENTS.
- C. CONTRACTOR SHALL ASSUME THAT ALL EXISTING UTILIDOR LIDS ARE REMOVABLE UNLESS OTHERWISE NOTED ON DRAWINGS.
- D. PROVIDE UTILIDOR INSULATION AS DESCRIBED IN SPECIFICATIONS FOR UTILIDORS EXPOSED AS PART OF THIS CONTRACT.
- E. AN ATTEMPT HAS BEEN MADE FOR DU TO FURNISH ALL MAJOR PIPING AND EQUIPMENT ASSOCIATED WITH NEW WORK. IN THE EVENT THAT ALL REQUIRED MATERIALS HAVE NOT BEEN FURNISHED, CONTRACTOR SHALL PROVIDE ALL REMAINING MATERIALS. SEE LIST OF DU FURNISHED MATERIALS IN THE CONTRACT DOCUMENTS.
- F. SUBMIT FOR REVIEW BY ENGINEER, STRUCTURAL DESIGN FOR ALL NEW VAULTS AS SHOWN ON DRAWINGS. DESIGN SHALL BE OF SIZE SHOWN ON DRAWINGS AND SHALL CONFORM TO ALL STATE AND LOCAL CODES. FINAL APPROVED DESIGN SHALL BEAR STAMP OF A PROFESSIONAL ENGINEER REGISTERED IN STATE OF ALASKA.
- G. INSTALL ALL DU FURNISHED MATERIALS AS DESCRIBED IN CONTRACT DOCUMENTS. REFER TO PC-SERIES DRAWINGS FOR FIELD DEVICE INSTALLATION LOCATIONS.
- H. PROVIDE ALL SUPPORTS, ANCHORS, GUIDES, AND INSULATION ASSOCIATED WITH ALL PIPING INSTALLED ON THIS PROJECT.
- I. REPLACE ALL EXISTING VAULT ACCESS HATCHES WITH DU FURNISHED ACCESS HATCH AND RAISE FINAL ELEVATION A MINIMUM OF 12 INCHES ABOVE FLOOD PLANE.
- J. REPLACE ALL EXISTING VAULT LADDERS THAT DO NOT MEET CURRENT OSHA STANDARDS. MODIFY EXISTING LADDERS AS NECESSARY TO COORDINATE WITH ACCESS HATCHES AND ALL PIPING.
- K. REPLACE ALL EXISTING VAULT VENTS AND BOLLARDS.

GENERAL INSTALLATION NOTES (E SERIES DRAWINGS):

- A. PROVIDE ALL EARTHWORK, EXCAVATION, BACKFILL, AND RESTORATION OF SURFACE CONDITIONS AS REQUIRED TO ACCOMPLISH THE WORK SHOWN IN THE CONTRACT DOCUMENTS.
- B. PROVIDE CONNECTIONS FROM POLE MOUNTED METERS TO POWER PANELBOARDS AS SHOWN ON DRAWINGS. DU WILL PROVIDE PRIMARY POLE-MOUNTED TRANSFORMERS, SECONDARY SERVICE FEEDS, AND METERING.
- C. PROVIDE POWER PANELBOARDS, LOAD PANELBOARDS AND SERVICE DISCONNECTS AS SHOWN ON DRAWINGS.
- D. INSTALL DU FURNISHED PANELS AS SHOWN ON DRAWINGS.
- E. PROVIDE EACH ACCESS VAULT WITH SWITCHED LED LIGHTING AND CONVENIENCE RECEPTACLES. RECEPTACLES SHALL BE MOUNTED A MINIMUM OF 48" FROM VAULT FLOORS UNLESS INDICATED OTHERWISE.
- F. PROVIDE 120 VAC POWER TO EACH ACCESS VAULT FROM PANELBOARDS TO LIGHTING, RECEPTACLES, CONTROL PANELS, AND SUMP PUMPS AS SHOWN ON DRAWINGS. ALL CONDUIT AND WIRING SHALL BE INSTALLED AT AN ELEVATION NO LESS THAN 18" FROM TOP OF WALL OF VAULT.

GENERAL INSTALLATION NOTES (PC SERIES DRAWINGS):

- A. PROCESS CONTROLS DRAWINGS REFERENCE WORK TO BE DONE BY BOTH THE CONTRACTORS.
- B. ALL INSTRUMENTS, FIELD DEVICES AND CONTROL PANELS WILL BE FURNISHED BY THE OWNER, UNLESS OTHERWISE SPECIFIED.
- C. PROVIDE CABLING AND CONDUIT FOR PROCESS CONTROLS INSTRUMENTATION IN UTILIDORS PER SYMBOL LEGEND. MINIMUM CONDUIT SIZE: 3/4". CONDUIT FILL SHALL NOT EXCEED 50%. LOW VOLTAGE CONTROLS CABLING SHALL BE RUN IN SEPARATE CONDUIT FROM 120VAC.
- D. SEE CONTROL PANEL REFERENCE DRAWINGS FOR WIRING TERMINATIONS.

REV. NO.	DATE	DESCRIPTION	FOSDICK & HILMER 309 VINE STREET, SUITE 50 TELEPHONE (513)241-5640	CONSULTING ENGINEERS CINCINNATI, OHIO 45202 WWW.FHENG.COM		Jimmy Huntington Building	Date: 19 FEB 2010	UTILITY SERVICE EXTENSION TO AIRCRAFT PARTS STORAGE SYMBOLS, ABBREVIATIONS & GENERAL NOTES	Drawing No. X-03	
	04/09/10	ISSUED FOR CONSTRUCTION				714 Fourth Avenue, Suite 20	Scale: NTS			
						Fairbanks, Alaska 99701	Designed By: JRS			
						Telephone (907) 455-1500	Drawn By: JRS			
						Fax (907) 455-6788	Checked By: EAE			
								FORT WAINWRIGHT, AK. DU PROJECT NO. J101395, J101396, J101397		