



DAILY FIELD QC REPORT

PROJECT MANAGER: Bill Farrell
ENGINEERING MANAGER: Matt Williams
SITE REPRESENTATIVE: Chris Davis

PROJECT NAME: FTW 336A, Aircraft Parts
PROJECT NUMBER: 09-0430
CONTRACTOR: Fulford / Grasle

DISTRIBUTION LIST:
PROJECT MANAGER
ENGINEERING MANAGER
SITE REPRESENTATIVE
File:

WEATHER

Temperature 60 Deg
Wind Vel/Dir Slight
Precipitation None
Visibility/Conditions Partly Cloudy

Date 26-Aug-10
Day Thursday
Report No. 1

CONTRACTOR

LABOR FORCE	NO.
Operators	
Line App	
Wire App	
Wiremen	
Linemen	
Instruments	
Surveyors	
Foreman	
Staff (non-manual)	
Total	

SUBCONTRACTORS	NO.

No. of Shifts Worked _____
Day _____ Swing _____ Mid _____
O.T. _____

EQUIPMENT ON SITE	Work	Idle	Down
Excavator			
Excavator			
Front End Loader			
Skid Steer			
Backhoe Tamp			
Roller Compactor			
Dump Truck			
Crew Truck			
Bucket Truck			
Line Truck			

JOB ACTIVITIES (Line Segments/Pole Numbers Inspected)

Fullford was completing work on the HBO connections during the site visit.

**Grasle has installed the 50kVA transformer and riser on 22-71-A. Power has been connect to the HBOs
The lighting has not been installed yet.**

No UG primary work has been done for the building service.

Prepared By: Chris Davis
Site Representative