



1. A BREAKAWAY FLANGE IS REQUIRED ON FIRE HYDRANT BASE FLANGE. (SHOE)
2. FIRE HYDRANT LOCATIONS AS SPECIFIED ON PLAN SHEETS.
3. EXCAVATION SHALL CONFORM TO OSHA STANDARDS.
4. ALL FIRE HYDRANTS SHALL BE PLUMB.
5. ALL FIRE HYDRANTS SHALL RECEIVE 3 LAYERS 6 MIL. POLYETHYLENE SHEETING AROUND BURCO BARREL PORTION.