Host Utilities

TATA

TATA POWER

TATA POWER-DDL

BSES

BSES Rajdhani Power Limited

BSES

BSES Yamuna Power Limited

Co - Host Utilities

CESC LIMITED

POWER CORPORATION LIMITED UTTAR PRADESH UPPCL UNDERTAKING

ORGANIZER

ISGF

India Smart Grid Forum

India SMART UTILITY Week 2024

Supporting Ministries

सत्यमेव जयते
MINISTRY OF POWER
GOVERNMENT OF INDIA

सत्यमेव जयते
MINISTRY OF NEW AND RENEWABLE ENERGY
GOVERNMENT OF INDIA

सत्यमेव जयते
नीति आयोग
National Institution for Transforming India

सत्यमेव जयते
MINISTRY OF ELECTRONICS & INFORMATION TECHNOLOGY
GOVERNMENT OF INDIA

सत्यमेव जयते
MINISTRY OF HEAVY INDUSTRIES
GOVERNMENT OF INDIA

सत्यमेव जयते
MINISTRY OF JAL SHAKTI
DEPARTMENT OF WATER RESOURCES, RIVER DEVELOPMENT & GANGA REJUVENATION, GOVERNMENT OF INDIA

सत्यमेव जयते
MINISTRY OF POWER
GOVERNMENT OF INDIA
CENTRAL ELECTRICITY AUTHORITY

Session : Foundational blocks for Smart Grids

Optimized Design and Development of Cost Effective Transmission Line Inspection Robot

SILVER OAK UNIVERSITY
EDUCATION TO INNOVATION

Presented By

MANAN PATHAK, ASSISTANT PROFESSOR, SILVER OAK UNIVERSITY

Challenges in Transmission Line Inspection

Accessing Remote Areas

Transmission lines often traverse rugged terrain, making accessibility a major challenge for inspection teams.

Weather-Dependent Operations

Inspection activities are heavily influenced by weather conditions, leading to potential delays and safety concerns.

Data Interpretation Complexity

Processing large volumes of inspection data requires advanced analytics and poses significant computational challenges.

Safety Risks for Personnel

Manual inspection methods expose workers to hazardous environments, leading to safety and liability risks.

Objectives: Goals of the Project

An overview of the project reveals the focus on creating a cost-effective robot for inspecting transmission lines. The project aims to optimize the design and development process to ensure efficient and reliable inspection operations.

- **Efficient Inspection:** Develop a robot capable of inspecting transmission lines quickly and accurately
- **Data Collection:** Enable the robot to gather comprehensive data for analysis and maintenance planning
- **Safety Enhancement:** Implement safety measures to reduce risk to human inspectors during line inspections



Figure: A man inspecting PTLs using binoculars from the ground

Design Considerations: Factors Influencing the Robot's Design

1

Ergonomics

The robot's design must prioritize user-friendly ergonomics to ensure ease of operation and maintenance.

2

Environmental Adaptability

Considering different weather conditions and terrains to create a robot with versatile adaptability.

3

Power Efficiency

Developing a design that maximizes power efficiency to prolong operational duration and reduce recharging frequency.



Figure - Factors affecting Hybrid Transmission Line

Benefits of using the Robot for Inspection

Efficiency

The robot streamlines the inspection process, covering large distances and accessing difficult areas with precision and speed. Its efficient operation reduces the time and manpower required for routine inspections.

Accuracy

Equipped with advanced sensors and imaging technology, the robot ensures precise data collection, detecting potential issues and anomalies with high accuracy.

Safety

By eliminating the need for human inspection in hazardous environments, the robot enhances safety for workers while minimizing the possibility of accidents or injuries related to manual inspections.

Cost-effectiveness

Utilizing the robot for inspection significantly lowers overall operational costs by reducing labor expenses, minimizing downtime, and enabling timely maintenance, ultimately saving resources and increasing ROI.

System Architecture: Components and Their Functions

Sensors

These components detect environmental conditions and transmit data to the central processing unit for analysis.

Central Processing Unit

The CPU processes the data received from sensors and controls the robot's movements and inspection activities.

Power Supply

Provides the necessary energy to operate the robot and its components throughout the inspection process.

Inspection Techniques: Methods Used for Line Inspection

Aerial Inspection

Aerial drones equipped with high-resolution cameras provide an efficient method for visually inspecting transmission lines.

Ground-based Inspection

Ground robots or vehicles are used to conduct close-range inspections of the transmission lines for detailed assessments.

Infrared Thermography

This technique employs infrared cameras to detect abnormal heat patterns indicating potential issues in the transmission lines.

Ultrasonic Testing

Ultrasonic sensors are utilized to identify material defects or corrosion within the transmission lines, ensuring structural integrity.

Cost Optimization: Strategies to Reduce Production Costs

Operational Efficiency

Streamlining processes to minimize waste and maximize output.

Budget Management

Efficient allocation and monitoring of financial resources.



1 _ Crossarm; 2 _ suspension; 3 _ lightning shield wire; 4 _ insulator; 5 _ conductor; 6 _ guy wire; 7 _ guyed disk; 8 _ down lead; 9 _ grounding device; 10 _ chassis; 11 _ foundation

Maintenance Planning

Strategic scheduling to reduce downtime and repair costs.

Supply Chain Optimization

Improving logistics and sourcing to lower material expenses.

Performance Evaluation: Metrics for Assessing Robot Performance

Performance Metric	Evaluation Method
Speed of Inspection	Time taken to inspect per mile
Accuracy of Data Collection	Deviation from actual measurements
Energy Efficiency	Power consumption per hour of operation
Adaptability to Terrain	Ability to navigate different landscapes



Cost-Effectiveness Analysis

Factors	Traditional Inspection	Robot Inspection
Cost of Equipment	High initial investment in specialized equipment	Lower initial investment due to multipurpose robot capabilities
Operational Cost	High operational costs due to manpower and time requirements	Lower operational costs due to efficient automated processes
Downtime	Significant downtime during inspections causing revenue loss	Minimized downtime resulting in improved revenue generation
Accuracy	Potential for human error impacting accuracy	High accuracy and reliability in inspections

The cost-effectiveness analysis clearly demonstrates the advantages of using the robot for transmission line inspection. The lower initial investment and operational costs, coupled with minimized downtime and high accuracy, make the robot inspection method highly cost-effective and efficient.

Future Developments and Improvements

1

Enhanced Navigation Systems

In the future, the robot's navigation systems will be further optimized to navigate through complex terrain and withstand challenging weather conditions. This will involve the integration of advanced GPS technologies, obstacle detection sensors, and machine learning algorithms to enhance the robot's autonomy and safety.

2

Integration of AI for Data Analysis

Upcoming developments will focus on integrating artificial intelligence (AI) algorithms to analyze the data collected during inspections. This will enable the robot to identify and classify potential issues with greater accuracy and efficiency, providing more detailed insights into the condition of the transmission lines.

3

Expansion of Robotic Arm Capabilities

Future improvements will involve the expansion of the robot's robotic arm capabilities to perform additional maintenance tasks during inspections. This may include the integration of custom end-effectors for specific maintenance activities, further enhancing the robot's versatility and overall utility in transmission line inspection operations.

Conclusion: Summary of the Project and Future Prospects

- ✓ As we conclude our discussion on the optimized design and development of cost-effective transmission line inspection robot, it's evident that embracing innovative robotics technology has immense potential to revolutionize inspection processes.
- ✓ By leveraging the capabilities of the robot, organizations can significantly enhance the efficiency, accuracy, and safety of transmission line inspections.
- ✓ The introduction of advanced robotic solutions marks a pivotal turning point in the field of infrastructure maintenance and inspection, ushering in an era of heightened productivity and cost-effectiveness.
- ✓ After rigorous testing and data analysis, the transmission line inspection robot has proved to be a cost-effective and efficient solution for monitoring and maintaining power transmission infrastructure.
- ✓ The successful implementation of this project opens the door to future advancements in automated inspection technologies, promising safer and more reliable operations for the industry Times

THANK YOU

For discussions/suggestions/queries

email: mananpathak.gn@socet.edu.in

References

I. Toussaint Kristopher, Nicolas Pouliot SM. Transmission line maintenance robots capable of crossing obstacles: state-of-the-art review and challenges ahead. J F Robot 2009;26:477–99. https://doi.org/10.1002/rob.

II. Katrasnik J, Pernus Franjo, Likar B. A survey of mobile robots for distribution power line inspection. IEEE Trans Power Deliv 2010;25:485–93.

III. Jalal MFA, Sahari KSM, Anuar A, Arshad ADM, Idris MS. Conceptual design for transmission line inspection robot. IOP Conf Ser Earth Environ Sci 2013;16:1–5. https://doi.org/10.1088/1755-1315/16/1/012094.

IV. Menendez O, Auat Cheein FA, Perez M, Kouro S. Robotics in power systems: enabling a more reliable and safe grid. IEEE Ind Electron Mag 2017;11:22–34. https://doi.org/10.1109/MIE.2017.2686458.

V. Jalil B, Leone GR, Martinelli M, Moroni D, Pascali MA, Berton A. Fault detection in power equipment via an unmanned aerial system using multi modal data. Sensors (Switzerland) 2019;19:1–15. https://doi.org/10.3390/s19133014.

VI. Bin Ren Z, Yi R, Zheng L, Yong Y. Motion planning of inspection robot suspended on overhead ground wires for obstacle-navigation. 2009 Chinese Control Decis Conf CCDC 2009 2009. p. 1322–6. https://doi.org/10.1109/CCDC.2009.5192699.

VII. Wu G, Zheng T, Xiao H, Li C. Navigation, location and non-collision obstacles overcoming for high-voltage power transmission-line inspection robot. 2009 IEEE Int Conf Mechatronics Autom ICMA 2009 2009. p. 2014–20. https://doi.org/10. 1109/ICMA.2009.5245998.

VIII. Disyadej T, Promjan J, Muneesawang P, Poochinapan K, Grzybowski S. Application in O&M practices of overhead power line robotics. IEEE PES GTD Gd Int Conf Expo Asia (GTD Asia) IEEE; 2019. p. 347–51. https://doi.org/10.1109/gtdasia.2019. 8715886.

IX. Zhou C, Liu Y. Modeling and mechanism of rain-wind induced vibration of bundled conductors. Shock Vib 2016;2016:1–7. https://doi.org/10.1155/2016/1038150.

X. Alhassan AB, Zhang X, Shen H, Jian G, Xu H, Hamza K. Investigation of aerodynamic stability of a lightweight dual-arm power transmission line inspection robot under the influence of wind. Math Probl Eng 2019;2019:1–16.