

Foundational Blocks for Smart Grids

Implementation of Smart Pillar Box With Digital Communication in LT Distribution System

Speaker : *Nirvik Biswas, Asst. Manager, CESC LTD*

Company name: CESC Limited

Scope: Generation & Distribution of electricity across 567 sq. km in Kolkata & Howrah in West Bengal

Registered Office: CESC House, Chowringhee Square, Kolkata - 700001



CESC House

Head Office of CESC Limited
A heritage building built in 1933

Brief Company details

Website	www.cesc.co.in
Managing Director (Generation)	Mr. Rabi Chowdhury
Managing Director (Distribution)	Mr. Debasish Banerjee
Employee Strength In CESC's direct payroll : 7,377	Officers - 792 (including 4 PTMOs) JMS - 139 Non covenanted employees – 6,446 Contracted workforce – 4,475
Turnover (in Rs. Crores) in FY21	Rs. 7,101 Crores
Consumer base	LT ~ 3.4 million, HT ~ 1,700



Perennial Problems in our System

1. Submergence of bottom of Pillar Box under water during any deluge subsequently the body of the Pillar Box becoming alive.
2. Longer restoration time due to LT HRC Fuse failure in transformers resulting in revenue loss
3. Revenue loss due to delay in restoration of Pillar Box HRC Fuse Failure




Problem Measurement

1. The increasing trend of Alive Calls and unsafe incidents suggest that there is an urgent need of incorporation of some preventive/proactive measures
2. The increase in ART of restoration of PB Fuse calls and DTR LT HRC Fuse calls clearly indicates that we have to look out for a proactive solution to decrease the revenue loss due to delay in restoration.



Presentation on the Topic

• Root Cause/Why-Why Analysis of the Problems



DTR LT HRC Fusing

Pillar Box Fusing

Submergence of Pillar Box in Waterlogged Area

Presentation on the Topic

Water Level Indicator

- ❑ Sensors introduced in the Pillar boxes for measuring water level.
- ❑ Pillar Box installed in the waterlogged area are judiciously chosen.
- ❑ A dashboard has been prepared in order to monitor the data fetched from these sensors installed in the pillar boxes.
- ❑ GSM based communication module installed in the pillar boxes

CESC CALL CENTER Logged in as LT Control Room

Water Level Status [Since 13/11/2019] Refresh Auto refresh in 60 seconds. Water Evacuated Water Logged


Sl #	Dist.	Location	Installation Date	SIM No.	Water Logged (Event Count)	Water Evacuated (Event Count)	Last SMS Received At
1	SWD	DENT MISSION (S) T/H F1&2 [N/S HITECH]	24.05.18	917605082641	3	10	23/03/20 12:13
2	SWD	ACPB 1757 [N/S HITECH]	05.11.19	917605097822	10	26	16/08/21 02:29
3	SWD	B.K RD O/T-2 F1 [N/S HITECH]	05.11.19	917605097823	3	11	09/12/19 05:54
4	SWD	B.K RD P/T F1&2A [N/S HITECH]	05.11.19	917605097820	0	1	18/11/19 12:46
5	SWD	MOMINPORE P/T F1A [N/S HITECH]	05.11.19	917605097825	2	22	18/12/19 03:22
6	SWD	MOMINPORE(E) P/T F1 [N/S HITECH]	05.11.19	917605097824	11	13	26/04/21 04:46
7	SWD	ACPB 1020 [N/S HITECH]	19.02.20	917605082642	1	1	14/06/21 17:52
8	SWD	ACPB 1116 [N/S HITECH]	19.02.20	917605082643	0	0	
9	SWD	ACPB 2016 [N/S HITECH]	19.02.20	917605082644	16	42	14/06/21 17:25
10	SWD	ACPB 0140 [N/S HITECH]	19.02.20	917605082645	2	4	17/06/21 02:06
11	SWD	ACPB 1154 [N/S HITECH]	19.02.20	917605082646	0	1	20/05/20 23:02
12	SWD	MOMINPORE (C) P/T F-1 [N/S HITECH]	19.02.20	917605082647	0	0	
13	CSD	MODEL [N/S HITECH]	01.02.20	918584873834	3	6	05/02/20 10:51
14	WSD	ACPB 0920 [N/S HITECH]	05.03.20	917605082555	0	1	14/06/21 11:57
15	WSD	ACPB 0919 [N/S HITECH]	05.03.20	917605082558	7	15	18/11/20 10:57
16	WSD	ACPB 2464 [N/S HITECH]	05.03.20	917605082554	0	1	14/06/21 14:58
17	WSD	Fatehpur (E) P/T F1 [N/S HITECH]	05.03.20	917605082557	9	2	18/06/21 23:05
18	WSD	Sampa Mirza Nagar (S) O/T F1 [N/S HITECH]	05.03.20	917605082556	0	0	
19	WSD	Shampa Mirza Nagar T/H F1 [N/S HITECH]	05.03.20	917605082553	0	3	14/06/21 11:00
20	CCD	JANNAGAR (C) P/T F-1 [N/S HITECH]	03.08.20	917605073449	1	2	16/08/21 10:11
21	CCD	GORACHAND (W) P/T F-1 [N/S HITECH]	03.08.20	917605073446	0	2	27/05/21 17:07



Presentation on the Topic

Installation of Pillar Box HRC fuse fail indicator device

- ❑ Introducing Sensors for measuring the electrical parameters from remote
- ❑ Installing GSM based communication module
- ❑ Chalking out the pillar boxes according to their sensitivity
- ❑ Developing a dashboard to monitor the data fetched from these sensors to detect the outage due to fusing



LT-Consumer Node graph=main.bgr

Alarm Summary			
LT PILLAR BOX MONITORING SYSTEM			
Bagbazar Sarbojonin (CND) Bagbazar (W) O/T F1 Bagbazar (W) O/T F2	Sreebhumi (ND) Sreebhumi (N) T/H F1 Canal St P/T F1	Naktala Udayan Sangha (SD) Naktala O/T1 F1 Naktala O/T2 F1	Tridhara Sammilani (CSD) Monoharpukur (C) T/H Monoharpukur (S) O/T
Ahiritola Sarbojonin (CND) B.K.Pal (W) P/T B.K.Pal T/H F1	DumDumPark Tarun Sangha (ND) DumDumPark (S) P/T	Ajay Sanghati (SWD) Putiary (S) O/T F1	Harish Park Sarbojonin (CSD) Harish Park O/T1 Harish Park O/T2
Kumartuli Park (CND) Sovabazar O/T 1 F1 Sovabazar O/T 2 F1 Sovabazar R/S O/T F1	DumDumPark Bharat Chakra (ND) DumDumPark P/T F1	Deshapriya Park Sarbojonin (CSD) Tilak Road O/T Rashbehari Ave T/H	Singhee Park (CSD) Ramani Chatt St O/T1 F1 Ramani Chatt St O/T2 F1
	41 Pally (SWD) Putiary (C) O/T F1	Maddox Square (CSD) Maddox Sq (E) P/T F1 Maddox Sq P/T F1	



Presentation on the Topic

DTR LT HRC Fuse Failure Indicator inside Pillar Box

- ☐ Introducing Sensors for measuring the voltage of the incomer cables emanating from DTR
- ☐ Installing GSM based communication module
- ☐ Flagging out SMS during missing potential for any one or two phases simultaneously
- ☐ Mitigating staggered movement




Use Case/Case Study

Tangible Gains for 400 no of Smart Pillar Boxes in Waterlogging Areas

Tangible Gains for 400 no of Smart Pillar Boxes having DFR for ART of Fuse Calls

Tangible Gains for 400 no of Smart Pillar Boxes for Fuse Failure Indicator



Key Takeaways/ Recommendations

- Technology infusion in traditionally used equipment has transformed the LT distribution system of CESC.
- Consumer safety has been prioritized and proactive information gathering through water level indicators will expedite rapid action to avoid electrical hazard to pedestrians.
- The digital revolution sparked in the Outage Management domain by the Fuse Failure Indicators not only minimizes consumer down-time, but also results in huge revenue savings for the utility.
- The steady transformation has begun towards a new and better CESC LT system where proactive instead of reactive action is the norm.

STAY SAFE



ANY QUERIES

