Host Utilities

TATA

TATA POWER

TATA POWER-DDL
Towards a Greener Tomorrow

BSES
BSES Rajdhani Power Limited

BSES
BSES Yamuna Power Limited

ORGANIZER

ISGF
India Smart Grid Forum

Supporting Ministries

सत्यमेव जयते
MINISTRY OF POWER
GOVERNMENT OF INDIA

सत्यमेव जयते
MINISTRY OF POWER
GOVERNMENT OF INDIA
CENTRAL ELECTRICITY AUTHORITY

India
SMART UTILITY
Week 2026
10 – 14 March 2026, New Delhi

Session : Technical Paper Presentation

Cyber Crisis Management Plan(CCMP)

Presented By

Aamir Hussain Khan, CISO, Tata Power-DDL

Parul Bahl Sawhney, TL-IT &OT Security and Assessment, Tata Power-DDL

INTRODUCTION

Tata Power Delhi Distribution Limited [Tata Power-DDL] is a **joint venture between Tata Power and the Government of NCT of Delhi** with the majority stake being held by Tata Power Company (51%).

Distribution sector has adopted various advanced IT and OT technologies to improve the reliability and availability of power to its consumers for enhancing the Customer Delight Index. However, the increasing technological complexity in the field of cybersecurity continuously introduces new vulnerabilities, leading to evolving and sophisticated cyber threats. In this context, it **is imperative for critical infrastructure sectors** particularly the power distribution sector **to establish a robust Cyber Crisis Management Plan (CCMP).**

CONTEXT

Attack Month	Name of Organization	Attack Type / Description	Root Cause	Lesson Learnt
Dec'25	Multiple Polish energy & industrial firms (wind & solar farms, combined heat & power plant, manufacturing company)	Coordinated destructive cyberattack targeting over 30 wind and solar farms, a combined heat & power (CHP) plant supplying heat to ~500 000 users, and a private manufacturing firm. Attackers deployed destructive *wiper* malware (e.g., **DynoWiper/ LazyWiper**) aiming to disrupt communications and damage systems, but energy generation and heat supply were not interrupted thanks to defensive controls.	1)Exploitation of exposed/weak perimeter devices (e.g.,VPN/firewalls with inadequate authentication) and lateral movement inside OT/IT networks; threat actors attributed with links to Russian-aligned groups such as **Static Tundra/Berserk Bear/Sandworm.**	1)Critical infrastructure must enforce strong authentication (MFA) on internet-facing devices, patch known vulnerabilities promptly, segment IT/OT networks, deploy robust OT/ICS monitoring, and plan incident response simulations for large-scale coordinated attacks.
Sep'25	European Airports (London Heathrow, Berlin, Dublin, Brussels)	DDoS Cyberattack on check-in and baggage systems	1)Coordinated cyberattack on airport IT infrastructure	1)Strengthen resilience and redundancy in aviation IT systems 2) Joint cybersecurity posture across aviation network 3) Establish **Cyber Crisis Management Plan** for Airport Operations
Aug/Sep'25	Jaguar Land Rover	Ransomware Attack by Scattered Lapsus Hunters forced shutdown of production line	1)Insufficient Multi-Factor Authentication 2) Lack of IT and OT Segmentation	1) Ensure availability of **Cyber Crisis Management Plan** for Assembly line Operations
Jun–Jul'25	Qantas Airways	Data breach via third-party customer service platform	1) Third-party vendor compromise 2) Weak supply-chain security	1)Implement strong vendor risk management 2) Encrypt customer data and limit external access 3) **Cyber Crisis Management Plan** for Airways

RELEVANCE

Power sector is one of the most important infrastructures of the country, as growth of this sector is directly correlated with the economic growth of the country. Any disruption in the Power sector due to cyber-attack creates hardship to human beings, as every aspect of human life is directly or indirectly associated with the electricity.

The main objectives of CCMP are –

a) To ensure that interruption or manipulations of critical functions/services in critical distribution sector are brief, infrequent, manageable and cause least possible damage.
b) To establish the strategic framework and guide actions to prepare for, respond to, and begin to coordinate recovery from a cyber-incident.
c) To put in place a mechanism to effectively deal with cyber security crisis and be able to define responsibilities and accountabilities at individual level.

Schools

Hospitals

CCMP METHODOLOGY

1) Decision and Analysis-

Reporting of a cyber security incident to the First Responders. Monitor status of the impacted system, investigate situation and involve other relevant stakeholders.

CCMP shall be declared/invoked when both DC and DR of the organization are not available due to cyber-attack (Ransomware, DDoS, Malware/Virus attack, etc.) and BCP cannot be executed for restoration of services.

First Responders activate Crisis Response Team (CRT) via Email/Call notification/Meeting application.

2) Isolate, Prepare and Respond-

CRT Team member(s) pursue following actions:

- Decide whether to involve additional team members.
- Support from vendors and service providers.
- Open bridge line with key stakeholders to discuss status and next steps. Incident Recovery & Business Continuity, Regulators & Law Enforcement.
- Refer the respective CCMP Standard Operating Procedures(SOPs) that have been pre-defined.

CCMP METHODOLOGY

3) Incident Containment, Eradication & Recovery-

- Start working parallelly to ensure restoration of normal business operations.
- Carry out the daily activities manually
- Restore the existing infrastructure .
- Follow the pre-existing SOPs.

4) Post-Incident Recovery-

Critical Business Processes are restored, and business availability is back online. CRT emergency contact(s) shall keep reviewing the status (daily basis) and will update the relevant stakeholders that business is restored. Apex Committee shall play the major role in below mentioned activities:

1. Involvement of Law Enforcement and necessary complaints, if needed.
2. Status of Cyber Insurance process and costs incurred post Incident Recovery and Closure.
3. Lessons Learnt and necessary details are documented.
4. Tracks the closure of recommendations and drives the improvement process.
5. Root Cause Analysis, taking Corrective Actions and Mitigation Plan for the gaps.
6. Decision on submission of report to concerned stakeholders.

WORKFLOW

[redacted]

Attention! CCMP Decla ***rill)***

As per discussion with C vemeber-2025 13:02

hours.

Please find the below compli

Department Name
Sub Transmission Zone

Cyber Crisis Management Plan(CCMP) Mock Drill			
Business Critical Application/Function Name	Grid Operations		
Date of Mock Drill	20-Dec-24		
Actual Start time	1:00 PM	**Actual End Time**	3:12 PM
Actual Duration	2 Hours and 12 Minutes		
Expected RTO	NA	**Actual RTO**	NA
Drill Initiated By	Aamir Hussain Khan (CISO)		
Stakeholders Involved in Drill	IT, Call Centre, Grids, Zones and PSC Team		
Scope of Drill	Scenario-2-Grid Substations are impacted. (Grid Communication Impacted along with Interruption at Field)	Total No. of Grids considered for CCMP Drill: Narela A-7 and IFC Narela Total No. of Zone considered for CCMP Drill: Zone-522	
Observations	01-Mock Drill performance found satisfactory. 02-As per CCMP SOP of Grid "1.1.2, HOG-STS has to reach immediately at PSC control room for coordination with field teams. "Action is required to perform during mock drill." 03-Security Team to be communicated about Drill 04-Related Data to be provided by respective EIC 05-Chronological Order of actions including data sharing to be prepared by Corp Safety so that all concerned departments shall provide the required information for preparing of effective report of Mock Drill		
Learning from Drill	Notification system may improve through automation for fast communication. Alert notification system in place of manual phone communication (Auto Dialler System)		

Host Utilities

TATA

TATA POWER

TATA POWER-DDL
Towards a Greener Tomorrow

BSES
BSES Rajdhani Power Limited

BSES
BSES Yamuna Power Limited

ORGANIZER

ISGF
India Smart Grid Forum

India
SMART UTILITY
Week 2026
10 – 14 March 2026, New Delhi

Supporting Ministries

सत्यमेव जयते
MINISTRY OF POWER
GOVERNMENT OF INDIA

सत्यमेव जयते
MINISTRY OF POWER
GOVERNMENT OF INDIA
CENTRAL ELECTRICITY AUTHORITY

THANK YOU

For discussions/suggestions/queries email: isuw@isuw.in

www.isuw.in

Links/References (If any)