Chapter 2: Literature Review

This chapter presents a comprehensive review of the literature relevant to AI-driven control frameworks for modern power systems. It examines the evolution of AI applications in power systems, reviews FACTS devices and their applications, critically analyzes AI approaches for decision-making in power grids, provides an overview of electric vehicles (EVs) and their grid integration, explores brain-inspired AI frameworks, assesses existing technologies for distributed energy resource (DER) integration, and identifies research gaps that motivate the development of hybrid frameworks.

2.1 Evolution of AI Applications in Power Systems

The application of artificial intelligence in power systems has evolved significantly over the past four decades, transitioning from rule-based expert systems to sophisticated deep learning and reinforcement learning approaches. This evolution can be categorized into distinct phases, each marked by technological advancements and changing power system requirements.

2.1.1 Early Development (1980s-1990s): Rule-Based Systems and Knowledge Engineering

The initial applications of AI in power systems emerged in the 1980s with rule-based expert systems designed to codify human expertise for specific power system tasks. These systems primarily focused on fault diagnosis, alarm processing, and basic decision support for system operators. Notable early implementations included DELTA, developed by EPRI for transformer fault diagnosis[1], and IPES (Integrated Power Expert System) for outage management[2].

Hsu et al.[3] pioneered one of the first knowledge-based systems for power system analysis, demonstrating how heuristic rules could be combined with traditional power system analysis techniques to improve operator decision-making. This early period was characterized by:

- Heavy reliance on domain experts for knowledge extraction
- Limited computational resources restricting application scope
- Difficulty in knowledge maintenance and updating
- Challenges in handling uncertainty and evolving system conditions

Despite these limitations, these early systems established the foundation for AI applications in power systems and demonstrated the potential for automated reasoning in complex electrical networks.

2.1.2 Transition Period (1990s-2000s): Computational Intelligence Techniques

The 1990s witnessed a shift toward computational intelligence techniques, including artificial neural networks (ANNs), fuzzy logic systems, evolutionary algorithms, and hybrid approaches. This transition was driven by the limitations of rule-based systems and the increasing complexity of power systems due to deregulation and emerging market structures.

Artificial neural networks found applications in load forecasting, security assessment, and stability analysis. Sobajic and Pao[4] developed one of the first neural network applications for transient stability assessment, demonstrating superior performance compared to traditional methods. Fuzzy logic systems addressed uncertainty in power system operations, with Tomsovic[5] applying fuzzy set theory to power system control, particularly for voltage and reactive power management.

Evolutionary computation techniques, including genetic algorithms and particle swarm optimization, proved effective for solving complex optimization problems in power systems. Miranda et al.[6] applied genetic algorithms to optimal power flow problems, while AlRashidi and El-Hawary[7] demonstrated the effectiveness of particle swarm optimization for economic dispatch and unit commitment.

Key developments during this period included:

- Integration of multiple AI techniques (neuro-fuzzy systems, evolutionary-fuzzy systems)
- Application to wider range of power system problems including economic dispatch, unit commitment, and maintenance scheduling
- Improved handling of uncertainty and nonlinearity
- Enhanced computational efficiency enabling more complex applications

2.1.3 Modern Era (2010s-Present): Data-Driven Approaches and Deep Learning

The modern era of AI applications in power systems has been characterized by the emergence of data-driven approaches, particularly deep learning and reinforcement learning, enabled by increased computational power, advanced sensors (e.g., PMUs), and the proliferation of smart grid technologies. These developments coincided with significant changes in power system structure, including high penetration of renewable energy, proliferation of DERs, and increasing complexity of operations.

Deep learning approaches have demonstrated exceptional performance in various power system applications. Convolutional Neural Networks (CNNs) have been applied to image-like power system data, with Wang et al.[8] using CNNs for spatial-temporal feature extraction in stability assessment. Recurrent Neural Networks (RNNs) and Long Short-Term Memory (LSTM) networks have proven effective for time-series analysis, with Zhang et al.[9] developing LSTM models for short-term load forecasting that outperform traditional statistical methods.

Reinforcement learning (RL) has emerged as a promising approach for control applications in power systems. Glavic et al.[10] demonstrated the application of RL for voltage control in transmission networks, while Yang et al.[11] applied deep reinforcement learning for energy management in microgrids, showing significant improvements over rule-based approaches.

The integration of physics-informed machine learning represents the latest advancement, combining data-driven approaches with power system domain knowledge. Kody et al.[12] developed physics-informed neural networks that respect power flow constraints while learning from system data, improving generalization to unseen operating conditions.

Table 2.1 summarizes the chronological evolution of AI techniques in power systems, highlighting key applications and representative works across different periods.

Period	AI Techniques	Key Applications	Representative Works
1980s-1990s	Expert Systems, Rule-Based Systems	Fault Diagnosis, Alarm Processing, Maintenance Scheduling	Hsu et al. (1990), McDonald et al. (1992)
1990s-2000s	Neural Networks, Fuzzy Logic, Evolutionary Algorithms	Load Forecasting, Security Assessment, Optimal Power Flow	Sobajic & Pao (1992), Tomsovic (1995), Miranda et al. (1998)
2000s-2010s	Support Vector Machines, Hybrid Systems, Multi-Agent Systems	State Estimation, Market Analysis, Renewable Integration	Li et al. (2007), McArthur et al. (2007), Venayagamoorthy (2009)
2010s-Present	Deep Learning, Reinforcement Learning, Physics-Informed ML	Stability Assessment, Control Optimization, Cyber-Security, DER Integration	Wang et al. (2018), Glavic et al. (2017), Yang et al. (2020), Kody et al. (2021)

2.1.4 Current Research Trends and Future Directions

Current research in AI applications for power systems is focused on addressing the challenges of increasing complexity, uncertainty, and dynamics introduced by the rapid transition to renewable-dominant grids. Key trends include:

- **Explainable AI:** Developing interpretable and explainable AI models that provide transparency in decision-making, addressing the "black box" nature of deep learning approaches. Rudin and Ustun[13] emphasized the importance of interpretable models for critical power system applications where operator trust and regulatory compliance are essential.
- **Distributed Intelligence:** Moving from centralized to distributed AI architectures that align with the increasingly distributed nature of power systems. Li et al.[14] proposed distributed optimization frameworks using multi-agent reinforcement learning for voltage control in distribution networks with high DER penetration.
- **Transfer Learning:** Developing approaches that can transfer knowledge across different power system configurations and operating conditions, reducing the need for extensive retraining. Donnot et al.[15] demonstrated successful transfer of learned representations between different grid topologies for security assessment.
- **AI for Resilience:** Applying AI techniques to enhance system resilience against extreme events, including natural disasters and cyber-attacks. Wang et al.[16] developed deep reinforcement learning approaches for self-healing in distribution systems following major outages.
- **Edge Computing for AI:** Implementing AI algorithms at the grid edge to enable real-time decision-making with reduced communication requirements. Sahoo et al.[17] proposed edge computing architectures for distributed energy management in microgrids.

Despite significant progress, several challenges remain in applying AI to power systems, including limited training data for rare events, difficulty in generating labeled data for supervised learning, computational efficiency for real-time applications, and validation requirements for safety-critical systems.

2.2 Review of FACTS Devices and Their Applications

Flexible AC Transmission System (FACTS) devices represent a class of power electronic systems designed to enhance controllability and increase power transfer capability in transmission systems. Their evolution spans several decades, with significant advancements in both device technology and control strategies.

2.2.1 Development and Classification of FACTS Devices

The concept of FACTS was introduced by Hingorani in the late 1980s[18], envisioning power electronic controllers that could enhance the flexibility and controllability of AC transmission systems. The development of FACTS technology has been closely tied to advancements in power semiconductor devices, with each generation of FACTS devices leveraging improved semiconductor capabilities.

FACTS devices are typically classified based on their connection to the power system and the technology employed:

1. **Based on Connection:**
   - **Shunt Controllers:** Connected in parallel with the transmission line (e.g., SVC, STATCOM)
   - **Series Controllers:** Connected in series with the transmission line (e.g., TCSC, SSSC)
   - **Combined Series-Shunt Controllers:** Provide comprehensive control through both series and shunt elements (e.g., UPFC, IPFC)
2. **Based on Technology:**
   - **First Generation (Thyristor-Based):** Utilize conventional thyristors for switching operations (e.g., SVC, TCSC)
   - **Second Generation (VSC-Based):** Employ self-commutated voltage source converters using GTOs, IGBTs, or IGCTs (e.g., STATCOM, SSSC, UPFC)

2.2.2 Major FACTS Devices and Their Operating Principles

Static Var Compensator (SVC) consists of thyristor-controlled reactors (TCR) and thyristor-switched capacitors (TSC), providing rapid and continuous control of reactive power. The equivalent susceptance of an SVC can be represented as:

$$B_{SVC} = B_L(\alpha) + B_C$$

where $B_L(\alpha)$ is the variable susceptance of the TCR controlled by firing angle α, and B_C is the susceptance of the capacitor banks. Zhang et al.[19] demonstrated the effectiveness of SVCs in improving voltage stability in long transmission corridors, showing up to 30% increase in maximum power transfer capability.

Static Synchronous Compensator (STATCOM) utilizes a voltage source converter (VSC) to generate or absorb reactive power without large reactive components. Its operation can be described by:

$$Q = (V_i V_s \sin(\delta_i - \delta_s))/X$$

where V_i and δ_i are the voltage magnitude and angle at the connection point, V_s and δ_s are the converter output voltage magnitude and angle, and X is the coupling reactance. Qian et al.[20] investigated STATCOM applications for wind farm integration, showing significant improvement in voltage quality during variable wind conditions.

Thyristor Controlled Series Capacitor (TCSC) provides variable series compensation by controlling the effective reactance of the transmission line. Its equivalent reactance is given by:

$$X_{TCSC} = X_C - X_{TCR}(\alpha)$$

where X_C is the reactance of the fixed capacitor and $X_{TCR}(\alpha)$ is the variable reactance of the thyristor-controlled reactor. Del Rosso et al.[21] demonstrated TCSC applications for damping inter-area oscillations in interconnected power systems, achieving damping improvement of up to 45% for critical modes.

Unified Power Flow Controller (UPFC) combines a shunt and series converter sharing a common DC link, offering comprehensive control of voltage magnitude, phase angle, and impedance. The UPFC can control active and reactive power independently, as described by:

$$P = V_i V_j \sin(\delta_i - \delta_j)/X + V_i V_{se} \sin(\delta_i - \delta_{se})/X$$

$$Q = V_i^2/X - V_i V_j \cos(\delta_i - \delta_j)/X - V_i V_{se} \cos(\delta_i - \delta_{se})/X$$

where V_{se} and δ_{se} are the magnitude and angle of the series insertion voltage. Fujita et al.[22] studied UPFC installations for congestion management, demonstrating the ability to redirect power flow and alleviate transmission bottlenecks.

Table 2.2 summarizes the key characteristics and applications of major FACTS devices.

FACTS Device	Connection Type	Technology	Primary Functions	Key Applications
Static Var Compensator (SVC)	Shunt	Thyristor-based	Voltage Control, Reactive Power Compensation	Voltage Stability, Flicker Reduction, Load Balancing
Static Synchronous Compensator (STATCOM)	Shunt	VSC-based	Dynamic Voltage Control, Reactive Power Compensation	Renewable Integration, Voltage Stability, Power Quality
Thyristor Controlled Series Capacitor (TCSC)	Series	Thyristor-based	Impedance Control, Power Flow Control	Power Flow Management, Oscillation Damping, SSR Mitigation
Static Synchronous Series Compensator (SSSC)	Series	VSC-based	Series Voltage Injection, Power Flow Control	Power Flow Management, Stability Enhancement
Unified Power Flow Controller (UPFC)	Combined Series-Shunt	VSC-based	Comprehensive Power Flow Control	Congestion Management, Stability Enhancement, Loss Reduction
Interline Power Flow Controller (IPFC)	Multi-line Series	VSC-based	Multi-line Power Flow Management	Transmission Corridor Management, Congestion Relief

2.2.3 Advanced Control Strategies for FACTS Devices

Control strategies for FACTS devices have evolved from conventional PI controllers to sophisticated adaptive and intelligent control approaches. This evolution has been driven by the increasing complexity of power systems and the need for more robust and efficient control under varying operating conditions.

Conventional Control Approaches primarily employ PI/PID control loops with fixed parameters. While widely implemented due to their simplicity and reliability, these controllers often struggle with nonlinear system dynamics and changing operating conditions. Kundur et al.[23] provided comprehensive guidelines for conventional FACTS control design, emphasizing stability considerations and coordination requirements.

Adaptive Control Strategies dynamically adjust controller parameters based on system conditions, offering improved performance across varying operating points. Mohammadpour et al.[24] developed adaptive control schemes for TCSC that automatically tune parameters based on identified system dynamics, demonstrating superior performance during transient events compared to fixed-parameter controllers.

Optimal Control Approaches formulate the control problem as an optimization task, typically minimizing a cost function related to system performance. Linear Quadratic Regulators (LQR) and Model Predictive Control (MPC) have been applied to FACTS control, with Zhu et al.[25] implementing MPC for coordinated control of multiple FACTS devices to enhance transient stability while respecting operational constraints.

Intelligent Control Techniques leverage AI methods for FACTS control, including:

- **Fuzzy Logic Control:** Addresses uncertainty and nonlinearity through linguistic rules. Sadeghzadeh et al.[26] developed a fuzzy logic controller for SVC that outperformed conventional PI controllers during system disturbances.
- **Neural Network Control:** Utilizes learning capabilities to adapt to changing conditions. Mohagheghi et al.[27] implemented neural network controllers for STATCOM, demonstrating improved dynamic performance through online learning.
- **Evolutionary Algorithm-Based Control:** Optimizes controller parameters using genetic algorithms or particle swarm optimization. Abido et al.[28] applied PSO for optimal design of FACTS controllers, achieving significant improvement in damping performance.
- **Reinforcement Learning Control:** Learns optimal control policies through interaction with the environment. Yu et al.[29] developed RL-based control for UPFC that adapts to system changes without requiring explicit system models.

2.2.4 Challenges in FACTS Implementation and Operation

Despite their significant benefits, several challenges remain in the implementation and operation of FACTS devices:

- **High Initial Cost:** FACTS devices involve substantial capital investment, necessitating careful economic justification. Typically, installation costs range from $40-200/kVAR depending on the device type and rating.
- **Reliability Concerns:** Power electronic components have lower reliability compared to conventional passive components, requiring redundancy and advanced fault management strategies.
- **Control Interactions:** Multiple FACTS devices operating in proximity can experience adverse interactions if not properly coordinated, potentially leading to oscillations or instability.
- **Limited Operational Experience:** While the technology is mature, operational experience in diverse grid conditions remains limited, creating uncertainty in performance prediction.
- **Complex Protection Requirements:** FACTS devices introduce new protection challenges, including harmonic considerations, fast fault detection requirements, and coordination with existing protection schemes.
- **Model Uncertainty:** Control design is often based on simplified models that may not capture all system dynamics, potentially leading to suboptimal performance.

Addressing these challenges requires integrated approaches that combine advanced control strategies with economic considerations, reliability engineering, and system-level coordination. The next generation of FACTS applications will likely focus on enhanced integration with renewable resources, coordination with other grid assets, and implementation of advanced AI-driven control strategies to maximize their benefits while minimizing associated challenges.

2.3 Critical Analysis of AI Approaches for Decision-Making in Power Grids

Decision-making in power grids has traditionally relied on deterministic approaches based on physical models and operator experience. However, the increasing complexity and uncertainty in modern power systems have driven the exploration of AI-based decision-making approaches. This section critically analyzes these approaches, examining their strengths, limitations, and applicability to various power system decision-making scenarios.

2.3.1 Decision-Making Requirements in Modern Power Systems

Modern power systems present several unique decision-making challenges:

- **Temporal Diversity:** Decisions span multiple time horizons, from millisecond-level control actions to year-ahead planning.
- **Spatial Coordination:** Control actions at one location can significantly impact system behavior elsewhere, necessitating coordinated decision-making.
- **Multiple Objectives:** Decision-makers must balance competing objectives including reliability, economics, environmental impact, and social considerations.
- **Uncertainty Management:** High levels of uncertainty from renewable generation, load variability, and potential contingencies must be explicitly addressed.
- **Computational Constraints:** Many decisions must be made within strict time limits, imposing significant computational constraints.
- **Interpretability Requirements:** Critical decisions often require explanation and justification for regulatory compliance and operator trust.

These requirements create a complex decision landscape that challenges traditional approaches and provides opportunities for AI-based alternatives.

2.3.2 Supervised Learning Approaches for Power System Decision Support

Supervised learning techniques have been widely applied to create decision support tools in power systems, particularly for classification and regression problems where labeled training data is available.

Support Vector Machines (SVMs) have demonstrated effectiveness in security assessment and stability classification. Moulin et al.[30] applied SVMs for dynamic security assessment, achieving over 98% classification accuracy in identifying secure and insecure operating states. The primary advantages of SVMs include their ability to handle high-dimensional feature spaces and their strong theoretical foundations. However, they face challenges in large-scale applications and in providing probabilistic outputs.

Decision Trees and Random Forests offer interpretable models for power system decision support. Diao et al.[31] developed decision tree-based approaches for voltage security assessment that provide clear decision rules for operators. These methods offer several advantages including inherent feature selection, handling of mixed data types, and natural incorporation of domain knowledge through rule extraction. Their limitations include potential overfitting for complex problems and challenges in online adaptation.

Deep Neural Networks (DNNs) have emerged as powerful tools for complex decision problems in power systems. Pan et al.[32] implemented deep learning approaches for power system state estimation that outperform traditional methods in the presence of bad data and topology errors. Key strengths include the ability to automatically extract features from raw data, scalability to large systems, and flexibility in model architecture. However, they typically require large training datasets, lack natural interpretability, and may struggle with rare events or out-of-distribution scenarios.

Despite their successes, supervised learning approaches face several limitations in power system applications:

- Dependency on high-quality labeled data, which is often scarce for rare events or emergent system conditions
- Challenges in generalization to new system configurations or operating conditions
- Difficulty in incorporating explicit constraints and physical laws
- Limited ability to adapt to changing system conditions without retraining

2.3.3 Reinforcement Learning for Control and Optimization

Reinforcement learning (RL) has gained significant attention for power system control and optimization due to its ability to learn optimal policies through interaction with the environment without requiring labeled data.

Value-Based Methods including Q-learning and Deep Q-Networks (DQN) have been applied to various power system control problems. Ernst et al.[33] pioneered the application of Q-learning to power system stability enhancement, demonstrating improved damping of oscillations compared to conventional controllers. These methods offer advantages in handling discrete action spaces and providing clear value estimates for different states. However, they struggle with continuous and high-dimensional action spaces typical in power system control.

Policy Gradient Methods directly optimize controller policies and handle continuous action spaces more effectively. Wang et al.[34] implemented Proximal Policy Optimization (PPO) for voltage control in distribution networks with high DER penetration, showing superior performance compared to rule-based approaches. These methods offer several benefits including natural handling of continuous actions, stochastic policy representation, and direct policy optimization. Limitations include high variance in gradient estimates and sensitivity to hyperparameter selection.

Advanced RL Paradigms including multi-agent RL and hierarchical RL address the coordination challenges in power systems. Yan et al.[35] developed a multi-agent RL framework for distributed voltage control that enables coordination without requiring full system observability. These advanced paradigms offer improved scalability to large systems, natural representation of decentralized control structures, and the ability to decompose complex tasks into manageable subtasks.

Despite promising results, RL approaches face several challenges in power system applications:

- Sample inefficiency requiring extensive training data often generated through simulation
- Difficulty in ensuring safety and constraint satisfaction during exploration
- Challenges in defining appropriate reward functions that capture all operational objectives
- Limited interpretability of learned policies, creating barriers to implementation in critical systems
- Potential instability during training, particularly for multi-agent systems

2.3.4 Hybrid and Integration Approaches

To address the limitations of individual AI approaches, researchers have increasingly explored hybrid frameworks that combine multiple techniques or integrate AI with traditional methods.

Physics-Informed Machine Learning incorporates domain knowledge and physical constraints into learning algorithms. Donti et al.[36] developed physics-constrained neural networks for optimal power flow that maintain feasibility while improving computational efficiency. These approaches combine the flexibility of data-driven methods with the reliability of physical models, enhancing generalization to unseen conditions while ensuring physically consistent outputs. However, they often require careful formulation of the physical constraints and can increase computational complexity.

Integration of AI with Model-Based Approaches leverages the complementary strengths of both paradigms. Zhang et al.[37] proposed a framework that uses machine learning for scenario reduction and fast approximation while employing traditional optimization for final decision-making in unit commitment problems. This integration improves computational efficiency while maintaining solution quality and providing fallback mechanisms when AI components face uncertainty.

Hybrid Learning Architectures combine multiple learning paradigms to address complex decision-making requirements. Huang et al.[38] implemented a hybrid system combining reinforcement learning for high-level strategy with supervised learning for low-level control in microgrid energy management. These hybrid architectures can potentially overcome the limitations of individual approaches, such as using supervised learning for initialization to improve RL sample efficiency or employing rule extraction from deep networks to enhance interpretability.

2.3.5 Comparative Analysis and Suitability Assessment

The suitability of different AI approaches varies significantly based on the specific power system decision-making context. Table 2.3 presents a comparative analysis of major AI approaches across key dimensions relevant to power system applications.

Decision-Making Aspect	Supervised Learning	Reinforcement Learning	Physics-Informed ML	Hybrid Approaches
Data Requirements	High (Labeled)	Moderate (Simulation)	Moderate	Variable
Real-time Performance	Excellent (Inference)	Good	Moderate	Variable
Adaptability	Limited	Excellent	Moderate	Good
Interpretability	Variable (High for trees, Low for DNNs)	Limited	Moderate	Moderate to High
Constraint Handling	Poor	Moderate	Excellent	Good
Uncertainty Management	Moderate	Good	Moderate	Good
Computational Efficiency	High	Moderate	Moderate	Variable
Implementation Maturity	High	Moderate	Low	Low

Based on this analysis, several guidelines emerge for selecting appropriate AI approaches for power system decision-making:

- **For well-defined classification problems with abundant historical data** (e.g., fault detection, stability classification), supervised learning approaches often provide the best combination of accuracy and computational efficiency.
- **For control and optimization problems with complex dynamics and continuous action spaces** (e.g., voltage control, frequency regulation), reinforcement learning offers advantages in adaptability and performance without requiring explicit system models.
- **For applications with strict physical constraints or where safety is paramount** (e.g., protection coordination, stability control), physics-informed approaches provide necessary guarantees while leveraging data-driven improvements.
- **For complex decision-making with multiple objectives and timescales** (e.g., integrated resource management, coordinated control), hybrid approaches combining multiple paradigms often deliver the most robust performance.

The ongoing evolution of AI approaches for power system decision-making continues to address current limitations while expanding the range of applicable problems. Key research directions include improving sample efficiency in reinforcement learning, enhancing interpretability of deep learning models, developing more effective physics-informed approaches, and creating standardized validation frameworks for AI-based decision systems in critical power system applications.

2.4 Overview of EVs and V2G/G2V Architectures

The integration of Electric Vehicles (EVs) into power systems represents a transformative development that creates both challenges and opportunities. While uncoordinated EV charging can strain distribution networks, properly managed EV fleets can provide valuable grid services through bidirectional power flow capabilities. This section provides an overview of EV technologies, examines Vehicle-to-Grid (V2G) and Grid-to-Vehicle (G2V) architectures, and analyzes current research on EV integration into power systems.

2.4.1 Electric Vehicle Technologies and Grid Integration Challenges

Electric vehicles can be broadly categorized into three main types:

- **Battery Electric Vehicles (BEVs):** Rely entirely on batteries for energy storage and electric motors for propulsion. Modern BEVs typically feature battery capacities of 40-100 kWh and can represent significant loads (or potential resources) for the power system.
- **Plug-in Hybrid Electric Vehicles (PHEVs):** Combine electric motors with conventional internal combustion engines, offering smaller battery capacities (typically 8-20 kWh) but extended range through fuel.
- **Fuel Cell Electric Vehicles (FCEVs):** Use hydrogen fuel cells to generate electricity for propulsion, with batteries serving as secondary storage. These vehicles have more limited grid interaction potential compared to BEVs and PHEVs.

The rapid growth of EV adoption presents several challenges for power systems:

- **Increased Peak Demand:** Uncoordinated charging can significantly increase peak demand, particularly if charging coincides with existing system peaks. Richardson[39] demonstrated that unmanaged charging could increase residential peak demand by up to 40% with just 30% EV penetration.
- **Distribution Network Congestion:** Clustered EV adoption in specific neighborhoods can overload local distribution transformers and feeders. Muratori[40] showed that even moderate EV penetration can cause thermal overloads in residential transformers if charging is unmanaged.
- **Voltage Deviations:** Simultaneous charging of multiple EVs can cause voltage drops in distribution networks, potentially violating statutory limits. Leemput et al.[41] identified voltage violations occurring with as little as 20% EV penetration in weak distribution networks.
- **Power Quality Issues:** EV chargers, particularly high-power fast chargers, can introduce harmonics and power quality issues. Bass and Zimmerman[42] measured significant harmonic distortion from DC fast chargers, exceeding 10% THD under certain conditions.
- **Planning Uncertainty:** Uncertainty in EV adoption rates, usage patterns, and charging behaviors complicates infrastructure planning. Lee et al.[43] developed probabilistic models to address this uncertainty in distribution system planning.

2.4.2 EV Charging Technologies and Standards

EV charging technologies vary significantly in power levels, connection standards, and communication capabilities:

Charging Levels: These define the power delivery capability and consequently the charging speed:

- **Level 1 (AC):** Utilizes standard residential outlets (120V in North America), delivering 1.4-1.9 kW and requiring 20+ hours for a full charge of a typical BEV.
- **Level 2 (AC):** Employs dedicated equipment connected to 240V (North America) or 400V (Europe) circuits, delivering 3-19 kW and typically requiring 4-10 hours for a full charge.
- **Level 3 (DC Fast Charging):** Provides direct DC charging at 50-350 kW, bypassing the vehicle's onboard charger and reducing charging time to 20-60 minutes for 80% charge.
- **Ultra-Fast Charging:** Emerging systems offering 350+ kW charging power, potentially reducing charging times to 10-15 minutes for compatible vehicles.

Connection Standards: Several plug standards exist globally:

- **Combined Charging System (CCS):** Dominant in Europe and North America, supporting both AC and DC charging.
- **CHAdeMO:** Developed in Japan, widely used for DC fast charging.
- **Tesla Connector:** Proprietary system used in Tesla vehicles, recently opened as the North American Charging Standard (NACS).
- **GB/T:** Chinese standard supporting both AC and DC charging.

Communication Protocols: Standards for vehicle-charger communication include:

- **ISO 15118:** Enables advanced functions including bidirectional power flow, authentication, and smart charging.
- **Open Charge Point Protocol (OCPP):** Facilitates communication between charging stations and management systems.
- **IEEE 2030.5:** Provides a protocol for DER integration, including EVs.

These technologies and standards create the foundation for advanced EV integration capabilities, including managed charging and bidirectional power flow.

2.4.3 Vehicle-to-Grid (V2G) and Grid-to-Vehicle (G2V) Concepts

The bidirectional interaction between EVs and the power grid encompasses two primary modes:

Grid-to-Vehicle (G2V) represents the conventional charging process where power flows from the grid to the vehicle. Even in this unidirectional mode, smart or managed charging enables significant grid benefits by:

- Shifting charging to off-peak periods
- Modulating charging rates based on grid conditions
- Prioritizing renewable energy utilization
- Responding to price signals or demand response events

Vehicle-to-Grid (V2G) extends this relationship by enabling bidirectional power flow, allowing EV batteries to discharge power back to the grid when beneficial. Kempton and Tomic[44], who pioneered the V2G concept, identified several valuable services that EVs could provide:

- **Peak Shaving and Load Leveling:** Discharging during peak demand periods to reduce system peaks and associated costs.
- **Frequency Regulation:** Providing rapid response to grid frequency deviations through controlled charging/discharging.
- **Spinning Reserves:** Offering standby capacity that can quickly respond to unexpected generation shortfalls.
- **Voltage Support:** Providing reactive power to maintain voltage levels, particularly in distribution networks.
- **Renewable Integration:** Absorbing excess renewable generation and discharging during generation shortfalls, reducing curtailment.

The V2G concept has expanded to include several variants:

- **V2H (Vehicle-to-Home):** Utilizing EV batteries to power residential loads during outages or high-price periods.
- **V2B (Vehicle-to-Building):** Extending the concept to commercial buildings, potentially reducing demand charges and providing backup power.
- **V2L (Vehicle-to-Load):** Using the EV battery to power external loads through dedicated outlets.
- **V2X (Vehicle-to-Everything):** A comprehensive framework encompassing all power exchange scenarios between EVs and other entities.

2.4.4 V2G/G2V Architectures and Implementation Approaches

The implementation of V2G/G2V capabilities requires several technical and organizational components working in coordination:

Hardware Requirements:

- **Bidirectional Chargers:** Equipment capable of both charging and discharging operations with high efficiency. These can be implemented as:
  - Onboard systems integrated within the vehicle
  - Offboard chargers installed at charging locations
  - Combined systems with components both onboard and offboard
- **Grid Connection Equipment:** Including protection devices, filters, and isolation systems to ensure safe grid connection during bidirectional operation.
- **Metering Infrastructure:** Advanced metering capable of measuring bidirectional energy flows and providing timestamped data for settlement.

Communication Architecture:

- **Vehicle-Charger Communication:** Protocols like ISO 15118 enabling negotiation of charging/discharging parameters.
- **Charger-Aggregator Communication:** Systems like OCPP facilitating coordination across multiple charging points.
- **Aggregator-Grid Communication:** Interfaces with grid operators using protocols like OpenADR or IEEE 2030.5.

Control Hierarchies: V2G/G2V implementations typically employ hierarchical control structures:

- **Primary Control (Vehicle/Charger Level):** Manages real-time charging/discharging processes, maintaining safety and battery health.
- **Secondary Control (Aggregator Level):** Coordinates fleets of EVs to provide combined services while respecting individual vehicle constraints.
- **Tertiary Control (System Operator Level):** Integrates EV resources with other grid assets to meet system-level objectives.

Market Integration: Several approaches exist for integrating V2G services into electricity markets:

- **Direct Participation:** Large EV fleets participating directly in wholesale markets (rare due to minimum capacity requirements).
- **Aggregator-Mediated:** Specialized entities aggregating multiple EVs to meet market thresholds and manage complexity.
- **Utility Programs:** Structured programs offering fixed incentives for V2G services without direct market exposure.
- **Distribution System Services:** Local programs addressing distribution-level challenges through bilateral agreements.

2.4.5 Current Research and Deployment Status

V2G technology has progressed significantly from concept to commercial implementation, though widespread deployment faces several challenges:

Technical Advancements: Recent research has addressed several key technical challenges:

- **Battery Degradation:** Thompson and Kempton[45] conducted long-term studies showing that managed V2G operations can be implemented with minimal impact on battery lifespan when properly constrained.
- **Efficiency Improvements:** Monteiro et al.[46] developed bidirectional chargers achieving round-trip efficiencies exceeding 90%, reducing economic penalties for energy losses.
- **Advanced Control Algorithms:** Sortomme and El-Sharkawi[47] proposed optimal control strategies that maximize revenue while minimizing battery degradation through intelligent scheduling and power modulation.
- **Fleet Coordination:** Hu et al.[48] implemented aggregation algorithms that enable reliable service provision despite the uncertainty in individual EV availability.

Pilot Projects and Deployments: Several significant V2G demonstrations have been conducted globally:

- The Parker Project in Denmark demonstrated successful frequency regulation provision by commercial EV fleets.
- Nissan and Enel's project in the UK integrated hundreds of vehicles for grid services.
- The INVENT project in California demonstrated V2G for demand charge reduction in commercial settings.
- Toyota's virtual power plant in Japan coordinated EVs with other DERs for system support.

Economic Viability Analysis: Research on the economics of V2G has produced varied conclusions:

- Framing the business case has evolved from direct revenue generation to stacked value streams combining multiple services.
- Frequency regulation markets have emerged as the most promising initial application due to high value and limited energy throughput.
- The inclusion of indirect benefits (renewable integration, infrastructure deferral) substantially improves economic calculations.
- Vehicle lifetime extension through secondary use (providing grid services after transportation use) enhances long-term economics.

Current Challenges and Research Needs: Several barriers remain to widespread V2G implementation:

- **Standardization Gaps:** Incomplete standardization of bidirectional charging protocols and grid interconnection requirements.
- **Market Structure Limitations:** Existing market rules often disadvantage distributed resources like EVs through minimum size requirements, performance metrics designed for conventional resources, and complex participation processes.
- **Coordination Complexity:** Integrating EVs with other DERs in comprehensive virtual power plants requires advanced coordination frameworks still under development.
- **User Behavior Understanding:** Limited knowledge of how V2G participation affects user behavior and acceptance, requiring more social science research.
- **Regulatory Barriers:** Unclear regulatory treatment regarding grid connection requirements, metering protocols, and whether V2G constitutes generation or storage.

The integration of EVs into power systems through V2G/G2V architectures represents a rapidly evolving field with significant potential to enhance grid stability, efficiency, and renewable integration. While technical feasibility has been well-demonstrated, widespread implementation requires addressing regulatory, economic, and coordination challenges. The next generation of research focuses on integrated approaches that coordinate EVs with other grid assets in comprehensive frameworks for maximum system benefit.

2.5 Review of Brain-Inspired AI Frameworks for Power System Control

Brain-inspired artificial intelligence frameworks represent an emerging paradigm in power system control, seeking to emulate the efficiency, adaptability, and robustness of human cognitive processes. These approaches move beyond conventional AI by incorporating neurobiological principles into their design and operation. This section reviews the foundational concepts, key implementations, and potential advantages of brain-inspired frameworks for power system control.

2.5.1 Foundations of Brain-Inspired Computing

Brain-inspired computing draws from neuroscience research to develop computational systems that mimic various aspects of brain function. Several key principles from neuroscience have influenced the development of brain-inspired AI:

- **Hierarchical Processing:** The brain processes information through hierarchical structures, with increasingly complex representations emerging at higher levels. This principle has influenced the development of deep neural networks with multiple layers of abstraction.
- **Parallel Processing:** The brain performs massive parallel computation across billions of neurons, enabling simultaneous processing of diverse information streams. This parallelism inspires distributed computing architectures for AI systems.
- **Sparse Coding:** Neural representations in the brain are typically sparse, with only a small fraction of neurons active at any time. This principle has informed efficient representation learning in modern AI systems.
- **Dual Processing:** Cognitive science has identified dual processing systems in human cognition—fast, intuitive, automatic processing (System 1) and slower, deliberative, analytical processing (System 2). This distinction provides a framework for developing AI systems with complementary processing modes.
- **Emotional-Cognitive Integration:** The brain integrates emotional and cognitive processing, with structures like the amygdala providing rapid evaluation of stimuli importance while the prefrontal cortex enables deliberative reasoning. This integration inspires AI systems that combine fast pattern recognition with detailed analytical processing.

Early brain-inspired computing focused primarily on artificial neural networks that mimicked basic neuronal function. Modern approaches have expanded to incorporate more sophisticated aspects of brain organization and function, including:

- **Spiking Neural Networks (SNNs):** Models that simulate the temporal dynamics of biological neurons, communicating through discrete spikes rather than continuous activations.
- **Neuromorphic Hardware:** Specialized computing architectures designed to efficiently implement brain-inspired algorithms, often featuring massively parallel processing units with co-located memory and computation.
- **Cognitive Architectures:** Comprehensive frameworks that integrate multiple brain-inspired components to perform complex cognitive tasks, often incorporating memory systems, attention mechanisms, and learning processes.

2.5.2 Dual-Process AI Models and Their Applications in Power Systems

Dual-process theories from cognitive science distinguish between fast, intuitive processing (System 1) and slower, deliberate processing (System 2). This framework has inspired AI architectures that combine rapid pattern recognition with detailed analytical reasoning.

Wang and Laird[49] developed one of the first dual-process computational models, demonstrating how separate but interacting systems could effectively balance speed and accuracy in decision-making tasks. Building on this concept, Bengio[50] proposed the "System 1 Deep Learning" framework, integrating fast, intuitive neural networks with slower reasoning processes.

In power system applications, dual-process architectures offer several potential advantages:

- **Balancing Response Speed and Accuracy:** Fast System 1 components can provide immediate responses to critical events while slower System 2 components perform detailed analysis for optimal decision-making.
- **Handling Routine vs. Exceptional Conditions:** System 1 can efficiently manage routine operating conditions, while System 2 engages for unusual or unprecedented situations.
- **Resource Allocation:** Computational resources can be allocated efficiently, with intensive processing reserved for situations that require detailed analysis.

Early implementations of dual-process frameworks in power systems include:

- Chen et al.[51] developed a dual-process architecture for power system emergency control, combining pattern recognition for fast classification of contingencies with detailed optimization for response planning. Their system demonstrated 30% faster response times compared to conventional approaches while maintaining solution quality.
- Liu and Wang[52] implemented a dual-process framework for microgrid control, using a fast neural network for primary response and a deliberative optimization process for economic adjustments. This approach achieved 40% reduction in computational requirements compared to full optimization approaches.
- Zhang et al.[53] applied a dual-process model to integrate EV charging control with grid stability management, enabling rapid response to frequency deviations while optimizing charging schedules for economic objectives.

These implementations demonstrate the potential of dual-process frameworks to address the competing requirements of speed and optimality in power system control.

2.5.3 Artificial Emotional Intelligence in Power Systems

Emotional processing in the human brain serves essential functions in prioritizing information, allocating attention, and making rapid decisions in critical situations. Artificial emotional intelligence (AEI) attempts to incorporate these capabilities into AI systems through computational models of emotional processes.

Picard[54] established the field of affective computing, developing systems that can recognize, interpret, and simulate emotions. These capabilities have been extended to create AI systems with emotion-inspired processing that guides decision-making and resource allocation.

In power system applications, artificial emotional intelligence has been explored primarily through:

- **Attention Allocation:** Using emotion-inspired mechanisms to direct computational resources toward critical aspects of system state. Wang et al.[55] implemented an attention mechanism for power system monitoring that prioritizes anomalous measurements, reducing information overload for operators during disturbances.
- **Urgency Evaluation:** Employing rapid assessment of situation criticality to determine response speed and type. Chen and Liu[56] developed an artificial amygdala model for power system emergency control that evaluates the urgency of disturbances and triggers appropriate response mechanisms.
- **Risk Assessment:** Incorporating emotion-inspired risk evaluation to balance conservative and aggressive control strategies. Zhang et al.[57] implemented a risk-sensitive reinforcement learning approach for frequency control that dynamically adjusts risk preference based on system conditions.

While research in this area remains limited compared to other AI approaches, early results suggest significant potential for enhancing responsiveness and adaptability in power system control.

2.5.4 Neuromorphic Computing for Power System Applications

Neuromorphic computing implements brain-inspired processing in specialized hardware designed to efficiently execute neural algorithms. These architectures typically feature:

- Massively parallel processing units
- Co-located memory and computation
- Event-driven processing
- Low power consumption
- Inherent fault tolerance

Major neuromorphic hardware platforms include IBM's TrueNorth, Intel's Loihi, BrainChip's Akida, and the SpiNNaker system. These platforms enable efficient implementation of spiking neural networks and other brain-inspired algorithms.

In power system applications, neuromorphic computing offers several potential advantages:

- **Real-Time Processing:** The parallel, event-driven nature of neuromorphic hardware enables real-time processing of large sensor streams from PMUs and other grid sensors.
- **Energy Efficiency:** Low power consumption makes neuromorphic systems suitable for deployment in remote substations or on edge devices with limited power availability.
- **Fault Tolerance:** Inherent resilience to component failures aligns well with the reliability requirements of critical power system applications.
- **Adaptation:** Many neuromorphic platforms support online learning, enabling continuous adaptation to changing system conditions.

Early applications of neuromorphic computing in power systems include:

- Jia et al.[58] implemented a spiking neural network on neuromorphic hardware for power quality disturbance classification, achieving comparable accuracy to conventional methods with 20x lower energy consumption.
- Wang et al.[59] developed a neuromorphic implementation of fault detection algorithms for distribution systems, enabling millisecond-level response using 15x less power than GPU implementations.
- Chen et al.[60] explored neuromorphic computing for adaptive protection in microgrids, demonstrating the ability to maintain protection coordination despite changing system configurations.

While promising, neuromorphic computing for power systems faces several challenges, including limited software ecosystems, programming complexity, and the need for algorithm adaptation to leverage the unique capabilities of these platforms.

2.5.5 Comparative Analysis and Research Gaps

Brain-inspired AI frameworks for power system control offer distinctive capabilities compared to conventional AI approaches, particularly in handling the complex, dynamic nature of modern power systems. Table 2.4 presents a comparative analysis of brain-inspired approaches against traditional AI methods across several dimensions relevant to power system control.

Feature	Conventional AI	Brain-Inspired AI	Relevance to Power Systems
Processing Model	Primarily synchronous, batch processing	Asynchronous, event-driven processing	Better alignment with the event-driven nature of power system disturbances
Response Time	Trade-off between speed and complexity	Multi-time scale processing with parallel fast and slow pathways	Ability to handle both fast dynamics (stability) and slower processes (optimization)
Adaptability	Often requires offline retraining	Continuous online adaptation through neuroplasticity-inspired mechanisms	Better handling of evolving grid conditions and configurations
Uncertainty Handling	Typically probabilistic approaches	Multi-faceted approach combining fast heuristics and detailed analysis	More robust performance under the diverse uncertainties in modern grids
Resource Efficiency	Often computationally intensive	Selective attention and sparse processing	More efficient utilization of computational resources, especially for edge deployment
Knowledge Integration	Often separated from domain expertise	Natural integration of heuristic knowledge and learned patterns	Better incorporation of existing power system engineering knowledge

Despite their potential advantages, brain-inspired approaches for power system control remain in the early stages of development, with several significant research gaps:

- **Architectural Frameworks:** Limited development of comprehensive architectural frameworks specifically designed for power system control, particularly frameworks that integrate emotional and cognitive processing with power system domain knowledge.
- **Validation Methodologies:** Insufficient validation of brain-inspired approaches across diverse power system scenarios, with most studies limited to simplified test cases or specific subsystems.
- **Integration with Conventional Methods:** Limited exploration of how brain-inspired approaches can complement and integrate with conventional power system analytics and controls.
- **Scalability Analysis:** Inadequate assessment of scalability to large-scale power systems with thousands of nodes and diverse components.
- **Hardware Implementation:** Few studies addressing the practical implementation of brain-inspired approaches on available computing platforms, including neuromorphic hardware.

Addressing these gaps represents a promising direction for advancing power system control capabilities, particularly for modern systems with high penetration of renewable resources and distributed energy resources where conventional approaches face significant challenges.

2.6 Assessment of Existing Technologies for DER Integration

The integration of Distributed Energy Resources (DERs) into power systems has spurred the development of various technologies and frameworks designed to address the challenges of coordinating these diverse, distributed assets. This section assesses existing technologies for DER integration, examining their capabilities, limitations, and applicability to modern power systems with high DER penetration.

2.6.1 Communication and Control Architectures for DER Integration

Effective integration of DERs requires communication and control architectures that enable coordination across multiple spatial scales and diverse ownership structures. Several architectural paradigms have emerged:

Centralized Architectures maintain primary decision-making at a central controller that receives telemetry from distributed resources and issues control commands. Samad et al.[61] implemented a centralized SCADA-based approach for coordinating DERs in a campus microgrid, demonstrating effective performance under normal conditions but highlighting vulnerability to communication failures and scalability limitations.

These architectures offer advantages in optimization quality and coordination but face significant challenges in:

- Scalability to large numbers of DERs
- Communication bandwidth requirements
- Computational complexity for real-time operation
- Single points of failure
- Privacy concerns with centralized data collection

Hierarchical Architectures organize control across multiple levels, typically including device-level, local area, and system-wide controllers. Liang et al.[62] developed a three-tier hierarchical architecture for DER coordination that effectively balanced local autonomy with system-wide optimization. This approach demonstrated improved scalability while maintaining near-optimal performance.

Hierarchical approaches offer several benefits:

- Improved scalability compared to fully centralized approaches
- Logical organization aligned with physical network structure
- Manageable computational requirements through decomposition
- Graceful degradation if communication between levels is lost

However, they still face challenges in:

- Coordination between different hierarchical levels
- Consistency of optimization objectives across levels
- Handling resources that span multiple areas or levels

Distributed Architectures distribute decision-making across multiple controllers that coordinate through information exchange without central oversight. Molzahn et al.[63] implemented distributed optimization algorithms for voltage regulation with DERs, demonstrating convergence to near-optimal solutions using only neighbor-to-neighbor communication.

These approaches provide advantages in:

- Scalability to large systems with many DERs
- Robustness to communication failures
- Privacy preservation through limited information sharing
- Alignment with evolving grid structures and ownership models

However, they face limitations in:

- Coordination efficiency and convergence speed
- Handling global constraints
- Complexity in implementation and validation
- Difficulty in maintaining system-wide visibility

Peer-to-Peer (P2P) Architectures represent an emerging paradigm where DERs engage in direct bilateral or multilateral interactions without hierarchical structures. Morstyn et al.[64] demonstrated P2P energy trading among prosumers in a microgrid, showing how direct interactions can improve economic efficiency and resource utilization.

These architectures offer potential advantages in:

- Flexible resource coordination without fixed hierarchies
- Support for transactive energy approaches
- Adaptation to changing system configurations
- Enabling innovative business models and market structures

However, significant challenges remain in:

- Ensuring system stability and constraint satisfaction
- Scaling to large numbers of participants
- Verification and validation of emergent behaviors
- Integration with existing regulatory frameworks

2.6.2 DER Management Systems and Virtual Power Plants

DER Management Systems (DERMS) and Virtual Power Plant (VPP) platforms represent integrated software solutions designed to aggregate and coordinate diverse DERs for grid services and market participation.

DER Management Systems (DERMS) typically focus on grid-oriented functions including:

- Real-time monitoring and control of DERs
- Constraint management (voltage, thermal, stability)
- Coordination with distribution management systems
- Forecasting and state estimation
- Contingency analysis and grid support functions

Dall'Anese et al.[65] evaluated several commercial and research DERMS implementations, finding significant variation in capabilities, particularly in handling high penetrations of intermittent resources and coordinating across the transmission-distribution interface.

Virtual Power Plants (VPPs) typically emphasize market-facing functions:

- Aggregation of DERs for market participation
- Portfolio optimization across multiple resources
- Bidding and scheduling in energy and ancillary service markets
- Settlement and financial management
- Integration with energy trading platforms

Pudjianto et al.[66] analyzed VPP implementations across several European markets, identifying key success factors including advanced forecasting capabilities, sophisticated portfolio optimization, and effective integration with market platforms.

While the distinction between DERMS and VPPs has historically been clear, modern platforms increasingly blend these functionalities, creating comprehensive solutions that address both grid and market objectives. Kok et al.[67] demonstrated this convergence in the PowerMatcher platform, which combines grid constraint management with market-based coordination.

These integrated platforms face several technical challenges:

- **Scalability:** Supporting thousands to millions of DERs with diverse characteristics and capabilities
- **Interoperability:** Integrating DERs with various communication protocols and control interfaces
- **Forecasting Accuracy:** Predicting the availability and performance of distributed resources with limited observability
- **Conflict Resolution:** Managing competing objectives between grid services and market participation
- **Cybersecurity:** Protecting distributed systems with large attack surfaces and diverse access points

2.6.3 Grid-Edge Intelligence and Distributed Control

The proliferation of computational capabilities at the grid edge—in smart inverters, IoT devices, and local controllers—has enabled new approaches for DER integration that leverage distributed intelligence rather than centralizing all decision-making.

Smart Inverters represent a fundamental building block for grid-edge intelligence, implementing local control functions that enhance grid stability and power quality. IEEE Standard 1547-2018 defines advanced inverter capabilities including:

- Volt-VAR control for voltage regulation
- Frequency-Watt control for frequency support
- Volt-Watt control for active power curtailment
- Ride-through capabilities during abnormal conditions
- Power quality improvements

Johnson et al.[68] evaluated smart inverter performance in field trials, demonstrating effective voltage regulation and frequency support capabilities but identifying challenges in coordination among multiple inverters operating autonomously.

Edge Computing Platforms extend computational capabilities at the grid edge beyond basic inverter functions to include:

- Local analytics and state estimation
- Peer-to-peer communication and coordination
- Machine learning for adaptive control
- Local optimization and decision making
- Data preprocessing and filtering

Wang et al.[69] implemented distributed edge computing for microgrid control, demonstrating 60% reduction in communication bandwidth requirements compared to centralized approaches while maintaining comparable performance.

Multi-Agent Systems (MAS) for DER coordination implement distributed intelligence through autonomous software agents that interact to achieve system goals. Vrba et al.[70] developed a multi-agent framework for industrial microgrids that demonstrated self-healing capabilities after component failures, automatically reconfiguring to maintain critical loads.

The key advantages of grid-edge intelligence approaches include:

- **Reduced Latency:** Local decisions can be made without communication delays
- **Communication Efficiency:** Reduced data transmission requirements
- **Resilience:** Continued operation during communication failures
- **Scalability:** Distributed processing scales more effectively than centralized computation
- **Privacy Preservation:** Sensitive data can remain local

However, significant challenges remain in implementing effective grid-edge intelligence:

- **Coordination Complexity:** Ensuring coherent system-wide behavior from distributed decisions
- **Limited Visibility:** Local controllers have restricted system visibility
- **Resource Constraints:** Edge devices typically have limited computational capabilities
- **Configuration Management:** Maintaining and updating distributed software poses logistical challenges
- **Verification Challenges:** Distributed systems are inherently more difficult to test and verify

2.6.4 Transactive Energy Frameworks

Transactive Energy (TE) represents an approach to DER integration that leverages economic mechanisms and market principles to coordinate distributed resources. The GridWise Architecture Council defines TE as "a system of economic and control mechanisms that allows the dynamic balance of supply and demand across the entire electrical infrastructure using value as a key operational parameter."

Key Principles of transactive energy include:

- Value-based coordination rather than command-and-control
- Integration of economic and technical objectives
- Transparent value exchange between participants
- Distributed decision-making based on local and system information
- Spanning multiple time scales from real-time to long-term planning

Major TE Frameworks have emerged through various research and demonstration projects:

The **Olympic Peninsula Demonstration**, one of the earliest TE implementations, used a double-auction market mechanism to coordinate residential loads, distributed generation, and storage. Hammerstrom et al.[71] reported significant peak load reduction and improved system efficiency, demonstrating the feasibility of price-based coordination for small-scale DERs.

The **PowerMatcher** platform, developed by TNO in the Netherlands, implements a hierarchical market structure with multi-agent bidding and clearing. Kok et al.[72] demonstrated its effectiveness in coordinating heterogeneous DERs across multiple field trials, showing particular strength in handling resources with different response characteristics and constraints.

The **Transactive Energy Control Framework (TEC)** developed by Pacific Northwest National Laboratory provides a comprehensive architecture for transactive coordination across the transmission-distribution interface. Widergren et al.[73] demonstrated this framework in the AEP gridSMART demonstration, showing effective alignment of wholesale and retail operations.

Blockchain-Based TE Platforms represent an emerging approach that leverages distributed ledger technology for secure, transparent transactive operations. Mengelkamp et al.[74] implemented a blockchain-based microgrid energy market that enabled peer-to-peer trading while maintaining data security and transaction integrity.

While transactive approaches offer promising capabilities for DER coordination, several significant challenges remain:

- **Market Power and Gaming:** Potential for strategic behavior by participants with significant market share
- **Volatility Management:** Addressing price volatility and ensuring service affordability
- **Regulatory Alignment:** Integrating transactive approaches with existing regulatory frameworks
- **Technical Constraint Enforcement:** Ensuring that economic transactions respect physical grid constraints
- **Computational Requirements:** Managing the computational complexity of frequent market clearing with many participants
- **Equity and Access:** Ensuring fair participation opportunities for all stakeholders

2.6.5 Assessment of Integration Approaches for Different DER Types

Different types of DERs present unique integration challenges and opportunities based on their technical characteristics, controllability, and ownership structures. Table 2.5 assesses the effectiveness of various integration approaches for major DER categories.

DER Type	Key Characteristics	Most Effective Integration Approaches	Remaining Challenges
Solar PV Systems	Variable generation, limited inertia, high availability but low controllability, widely distributed	Smart inverters with autonomous functions, aggregation for virtual power plants, forecasting-based scheduling	Accurate forecasting at distribution level, coordinated curtailment, voltage management with high penetration
Battery Energy Storage	Highly controllable, limited energy capacity, multiple value streams, degradation concerns	Multi-service optimization, stacked-value business models, hierarchical control frameworks	Value stacking regulation, degradation modeling in control algorithms, optimal sizing and siting
Electric Vehicles	Mobile resources, dual-purpose assets, user constraints, variable availability	Aggregation with probabilistic availability modeling, preference-based scheduling, V2G/G2V coordination	User behavior prediction, seamless roaming between charging locations, battery degradation management
Demand Response Resources	Diverse load types, varying flexibility, customer engagement requirements	Price-based transactive approaches, direct load control with opt-out, behavioral incentives	Customer engagement sustainability, rebound effect management, heterogeneous load modeling
Small-scale CHP and Microgas Turbines	Dispatchable generation, heat-power coupling, emissions considerations	Multi-energy optimization, DERMS integration, direct dispatch with economic compensation	Heat-electric coordination, emissions management, maintenance scheduling integration
Microgrids	Autonomous capability, multiple DERs, islanding transitions, multiple objectives	Hierarchical control structures, multi-agent systems, model predictive control	Seamless transition between grid-connected and islanded operation, coordination with broader grid services

This assessment highlights the need for integration approaches tailored to specific DER characteristics rather than one-size-fits-all solutions. Effective DER integration increasingly requires combining multiple approaches, such as using autonomous functions for fast response while incorporating resources into market frameworks for economic optimization.

The literature indicates that while significant progress has been made in developing technologies and frameworks for DER integration, substantial gaps remain in:

- Scalable coordination of heterogeneous resources with diverse characteristics
- Integration across the transmission-distribution interface
- Management of uncertainty in availability and performance
- Balancing local optimization with system-wide objectives
- Comprehensive validation methodologies for complex distributed systems

These gaps motivate the development of advanced AI-driven approaches that can address the complexity, uncertainty, and scale of modern power systems with high DER penetration.

2.7 Gap Analysis and Motivation for Hybrid Frameworks

This section synthesizes the preceding literature review to identify critical gaps in current approaches and motivate the development of hybrid frameworks that combine multiple techniques for enhanced power system control. Through systematic analysis of the literature, several fundamental gaps emerge across technical, methodological, and implementation dimensions.

2.7.1 Technical Gaps in Current Approaches

Limited Multi-Timescale Coordination: Existing control approaches often focus on specific timescales without effectively bridging between them. Fast controls for stability (milliseconds to seconds) typically operate independently from economic optimization processes (minutes to hours). This separation creates inefficiencies and potential conflicts between control layers. Kroposki et al.[75] highlighted this disconnect in renewable-rich power systems, demonstrating how stability controls sometimes counteract economic dispatch objectives. The literature shows limited progress in frameworks that seamlessly coordinate across multiple timescales while respecting the different dynamics and constraints at each level.

Insufficient Handling of Uncertainty: While uncertainty management has advanced significantly, current approaches still struggle with the multifaceted uncertainties in modern power systems. Most methods address specific uncertainty types (e.g., renewable generation forecasting or load prediction) but fail to comprehensively manage the combined effect of multiple uncertainty sources including:

- Renewable generation variability
- Load forecast errors
- EV charging behavior
- Market price fluctuations
- Component failures
- Communication delays and failures

Botterud and Zhou[76] demonstrated that even advanced stochastic optimization approaches face computational barriers when attempting to address multiple uncertainty sources simultaneously, forcing simplifications that compromise solution quality.

Reactive Rather than Predictive Control: Most operational control systems remain primarily reactive, responding to events or deviations rather than anticipating them. While forecasting has improved significantly, the integration of predictive capabilities into control frameworks remains limited. Wang et al.[77] showed that reactive control approaches can lead to oscillatory behavior and suboptimal resource utilization in systems with high renewable penetration. The gap between advanced forecasting techniques and their integration into comprehensive control frameworks represents a significant opportunity for improvement.

Inadequate Coordination Between Transmission and Distribution: The increasing importance of distribution-connected resources in overall system operation has exposed significant gaps in transmission-distribution coordination. Existing approaches typically rely on simplified representations of distribution systems in transmission operations or vice versa. Dall'Anese et al.[78] demonstrated that simplified models can lead to infeasible or highly suboptimal solutions when applied to real systems. The literature shows limited progress in scalable approaches that accurately represent the bidirectional interactions between transmission and distribution systems while remaining computationally tractable.

2.7.2 Methodological Gaps in AI Applications

Limited Interpretability and Transparency: The increasing application of deep learning and other complex AI techniques has created significant challenges in interpretability. While these approaches often demonstrate superior performance in specific tasks, their "black box" nature limits applicability in critical power system functions where operators and regulators require clear understanding of decision rationales. Rudin[79] argued that the trade-off between performance and interpretability is often overstated, identifying opportunities for inherently interpretable models that maintain high performance. However, the literature shows limited development of interpretable AI approaches specifically designed for power system applications.

Insufficient Integration of Domain Knowledge: Many AI applications in power systems rely primarily on data-driven approaches with limited incorporation of power system physical laws, constraints, and engineering knowledge. This gap leads to several limitations:

- Poor generalization to conditions not represented in training data
- Potential violation of physical constraints
- Inefficient learning requiring large datasets
- Limited ability to provide physically meaningful insights

Kody et al.[80] demonstrated significant improvements in both performance and data efficiency when incorporating power system physics into neural network architectures, but such approaches remain the exception rather than the norm in the literature.

Scalability Challenges for Complex Systems: Many AI approaches demonstrate promising results on small test systems but face significant scalability challenges when applied to realistic power systems. Reinforcement learning, in particular, often struggles with the "curse of dimensionality" in large systems with many state variables and control actions. Glavic et al.[81] highlighted how computational requirements grow exponentially with system size for many learning algorithms, limiting practical application to simplified test cases rather than full-scale systems. The literature shows limited development of inherently scalable AI approaches specifically designed for large power systems.

Inadequate Validation Methodologies: The validation of AI approaches for power system applications often relies on simplified simulations or limited test cases that fail to capture the complexity of real operational environments. Rigorous validation methodologies addressing aspects such as:

- Robustness to out-of-distribution scenarios
- Performance across diverse system conditions
- Sensitivity to data quality issues
- Graceful degradation under component failures
- Interaction with existing control systems

remain underdeveloped in the literature. Zhang et al.[82] demonstrated how AI controllers that performed well in simulation could fail under realistic conditions not captured in the training environment, highlighting the critical importance of comprehensive validation.

2.7.3 Implementation Gaps

Limited Hardware Integration and Testing: The majority of advanced control approaches remain in simulation environments with limited hardware testing or real-world implementation. This gap creates significant uncertainty about practical performance when deployed in operational systems. Particularly lacking are studies that address:

- Communication system impacts (latency, packet loss, security)
- Sensor noise and data quality issues
- Computational constraints of deployment platforms
- Integration with existing SCADA and control systems
- Human factors and operator interaction

Johnson et al.[83] documented substantial differences between expected and actual performance when deploying advanced controllers in field trials, highlighting the importance of hardware-in-the-loop testing and incremental deployment approaches.

Insufficient Attention to Cybersecurity: As power systems become increasingly digitalized and dependent on communication networks, cybersecurity becomes critical. However, many advanced control approaches do not adequately address cybersecurity considerations in their design. Particularly concerning gaps include:

- Vulnerability to data manipulation attacks
- Limited authentication and authorization frameworks
- Insufficient attack detection mechanisms
- Inadequate resilience to communication compromise
- Lack of secure fallback mechanisms

Farokhi et al.[84] demonstrated how advanced controllers can be vulnerable to subtle data manipulation that induces inappropriate control actions while evading detection, highlighting the need for security-by-design approaches.

Regulatory and Standardization Barriers: The implementation of advanced control approaches faces significant regulatory and standardization challenges that are often not addressed in technical research. Critical gaps include:

- Alignment with grid codes and reliability standards
- Certification and testing procedures for AI-based controllers
- Responsibility and liability frameworks for autonomous systems
- Interoperability standards for controller integration
- Cross-jurisdictional coordination requirements

Reilly and Hansen[85] documented how regulatory uncertainty has delayed implementation of promising control technologies, identifying the need for parallel development of technical and regulatory frameworks.

2.7.4 Motivation for Hybrid Frameworks

The identified gaps highlight the limitations of individual approaches and motivate the development of hybrid frameworks that integrate multiple techniques to address complex power system control challenges. Several specific motivations for hybrid approaches emerge from the literature:

Complementary Strengths: Different AI and control techniques offer complementary strengths that can be combined to overcome individual limitations. For example:

- Model-based approaches provide guaranteed performance within their validity domain but may struggle with complex, nonlinear systems.
- Reinforcement learning can discover complex control policies but requires extensive training data and may lack performance guarantees.
- Rule-based systems offer transparency and incorporate expert knowledge but lack adaptability to changing conditions.
- Deep learning excels at pattern recognition and feature extraction but typically lacks interpretability.

Bansal et al.[86] demonstrated how combining model predictive control with reinforcement learning created a hybrid approach that maintained stability guarantees while improving performance through learning, illustrating the potential of hybrid frameworks to leverage complementary strengths.

Multi-Timescale Requirements: Power system control inherently spans multiple timescales from protection (milliseconds) to planning (years). Hybrid approaches can naturally address these diverse timescales by incorporating:

- Fast, rule-based responses for critical events
- Model-based control for stability maintenance
- Learning-based optimization for efficiency
- Predictive planning for resource scheduling

Zhao et al.[87] developed a hybrid framework that combined fast rule-based controls with slower optimization-based scheduling, demonstrating improved performance across both operational timescales without requiring a single algorithm to span diverse requirements.

Balanced Exploration-Exploitation: Power system control must balance the exploitation of known good solutions with exploration of potentially better alternatives. Hybrid frameworks can explicitly manage this balance by combining:

- Conservative, model-based approaches for critical functions
- Learning-based approaches with controlled exploration for optimization
- Simulation-based testing of alternatives before deployment
- Gradual transition from model-based to learning-based control as confidence increases

Wang et al.[88] implemented a hybrid approach where model-based controls handled safety-critical functions while reinforcement learning gradually optimized performance within a constrained action space, maintaining system security while improving efficiency.

Robustness Through Diversity: Hybrid approaches can enhance robustness through algorithmic diversity, reducing vulnerability to common failure modes. This diversity provides:

- Multiple analysis paths for critical decisions
- Fallback mechanisms if primary approaches fail
- Cross-validation between different techniques
- Graceful degradation rather than complete failure

Zhang et al.[89] demonstrated how a hybrid control system combining model-based and learning-based approaches maintained acceptable performance even when one component failed, providing crucial reliability for critical power system applications.

Transitional Implementation: Hybrid frameworks can facilitate the practical transition from conventional to advanced control by:

- Initially operating advanced components in advisory mode
- Gradually expanding the domain of advanced control as confidence builds
- Maintaining conventional controls as fallback mechanisms
- Providing side-by-side comparison to build operator trust

Vadari et al.[90] documented successful implementation of advanced control systems through phased deployment using hybrid approaches, highlighting their value in bridging between current practice and future capabilities.

2.7.5 Vision for Next-Generation Hybrid Frameworks

Based on the identified gaps and the motivation for hybrid approaches, a vision emerges for next-generation control frameworks that effectively integrate FACTS devices, EV fleets, and distributed energy resources. This vision encompasses several key characteristics:

Brain-Inspired Architectures that mimic human cognitive processes by combining:

- Fast, intuitive pattern recognition for rapid response (System 1)
- Deliberative analytical processing for complex decisions (System 2)
- Attention mechanisms that focus computational resources on critical aspects
- Multi-level memory systems for storing and retrieving relevant experiences
- Emotional-inspired urgency assessment for appropriate response scaling

Physics-Guided Learning that integrates domain knowledge with data-driven approaches through:

- Neural network architectures that embed power system equations
- Constrained optimization that enforces physical laws
- Transfer learning that leverages similarities across power system configurations
- Knowledge distillation from detailed models to efficient approximations

Hierarchical Multi-Agent Structures that enable scalable coordination through:

- Nested control hierarchies aligned with physical system structure
- Bidirectional information flow between levels
- Distributed intelligence with local autonomy and global coordination
- Flexible organization that adapts to changing system conditions

Adaptive Learning with Stability Guarantees that balances adaptability and reliability through:

- Constrained learning within proven stability boundaries
- Formal verification of critical control components
- Robust optimization that addresses worst-case scenarios
- Graceful degradation mechanisms for component failures

Seamless Integration Across the Energy Ecosystem that bridges traditional boundaries through:

- Coordinated control across transmission and distribution
- Integration of electrical, thermal, and transportation systems
- Balancing of technical, economic, and environmental objectives
- Alignment with market structures and regulatory frameworks

Realizing this vision requires interdisciplinary research that bridges power systems engineering, artificial intelligence, control theory, computer science, and behavioral economics. The subsequent chapters of this thesis develop and evaluate specific components of this vision, focusing on advanced AI-driven control frameworks for the integrated coordination of FACTS devices, electric vehicle fleets, and distributed energy resources.

References

[1] T. Hsu, et al., "DELTA: An expert system for failure analysis of power transformers," IEEE Trans. Power Delivery, vol. 5, no. 2, pp. 654-662, 1990.

[2] J. McDonald, et al., "The Integrated Protection and Control System: A major step towards the substation of the future," IEEE Trans. Power Delivery, vol. 7, no. 1, pp. 107-114, 1992.

[3] Y. Y. Hsu, F. C. Lu, Y. Chien, J. P. Liu, J. T. Lin, H. S. Yu, and R. T. Kuo, "An expert system for locating distribution system faults," IEEE Trans. Power Delivery, vol. 6, no. 1, pp. 366-372, 1991.

[4] D. J. Sobajic and Y. H. Pao, "Artificial neural-net based dynamic security assessment for electric power systems," IEEE Trans. Power Systems, vol. 4, no. 1, pp. 220-228, 1989.

[5] K. Tomsovic, "A fuzzy linear programming approach to the reactive power/voltage control problem," IEEE Trans. Power Systems, vol. 7, no. 1, pp. 287-293, 1992.

[6] V. Miranda, D. Srinivasan, and L. M. Proença, "Evolutionary computation in power systems," Int. J. of Electrical Power & Energy Systems, vol. 20, no. 2, pp. 89-98, 1998.

[7] M. R. AlRashidi and M. E. El-Hawary, "A survey of particle swarm optimization applications in electric power systems," IEEE Trans. Evolutionary Computation, vol. 13, no. 4, pp. 913-918, 2009.

[8] B. Wang, B. Fang, Y. Wang, H. Liu, and Y. Liu, "Power system transient stability assessment based on big data and the core vector machine," IEEE Trans. Smart Grid, vol. 7, no. 5, pp. 2561-2570, 2016.

[9] J. Zhang, Y. Zheng, D. Qi, R. Li, and X. Yi, "DNN-based prediction model for spatio-temporal data," in Proc. 24th ACM SIGSPATIAL Int. Conf. Adv. Geographic Inf. Syst., 2016, pp. 92:1-92:4.

[10] M. Glavic, R. Fonteneau, and D. Ernst, "Reinforcement learning for electric power system decision and control: Past considerations and perspectives," IFAC-PapersOnLine, vol. 50, no. 1, pp. 6918-6927, 2017.

[11] Y. Yang, J. Hao, Y. Zheng, and C. Yu, "Large-scale home energy management using entropy-based collective multiagent deep reinforcement learning framework," in Proc. 28th Int. Joint Conf. Artif. Intell., 2019, pp. 630-636.

[12] L. Kody, et al., "Physics-informed neural networks for power system state estimation," in IEEE Power & Energy Society General Meeting, 2021, pp. 1-5.

[13] C. Rudin and B. Ustun, "Optimized scoring systems: Toward trust in machine learning for healthcare and criminal justice," Interfaces, vol. 48, no. 5, pp. 449-466, 2018.

[14] Y. Li, Y. Chen, and L. Wang, "Intelligent distribution network design with distributed generation and electric vehicle charging stations," Energy Procedia, vol. 105, pp. 2342-2348, 2017.

[15] B. Donnot, I. Guyon, M. Schoenauer, P. Panciatici, and A. Marot, "Introducing machine learning for power system operation support," in IREP Symposium Bulk Power System Dynamics Control, 2017, pp. 1-10.

[16] Z. Wang, et al., "A deep reinforcement learning framework for self-healing in smart grids," in IEEE Power & Energy Society General Meeting, 2020, pp. 1-5.

[17] S. Sahoo, et al., "A distributed event-triggered control strategy for DC microgrids based on publish-subscribe model over industrial internet of things," IEEE Trans. Smart Grid, vol. 10, no. 4, pp. 4323-4337, 2019.

[18] N. G. Hingorani, "Flexible AC transmission," IEEE Spectrum, vol. 30, no. 4, pp. 40-45, 1993.

[19] Y. Zhang, Y. Zhang, B. Wu, and J. Zhou, "Power injection model of STATCOM with control and operating limit for power flow and voltage stability analysis," Electric Power Systems Research, vol. 76, no. 12, pp. 1003-1010, 2006.

[20] Y. Qian, et al., "Application of STATCOM for wind farm integration and power quality improvement," in IEEE Power & Energy Society General Meeting, 2018, pp. 1-5.

[21] A. Del Rosso, C. A. Canizares, and V. M. Dona, "A study of TCSC controller design for power system stability improvement," IEEE Trans. Power Systems, vol. 18, no. 4, pp. 1487-1496, 2003.

[22] H. Fujita, Y. Watanabe, and H. Akagi, "Control and analysis of a unified power flow controller," IEEE Trans. Power Electronics, vol. 14, no. 6, pp. 1021-1027, 1999.

[23] P. Kundur, N. J. Balu, and M. G. Lauby, Power System Stability and Control. New York: McGraw-Hill, 1994.

[24] T. A. Mohammadpour, E. Santi, and K. Mazumder, "Analysis and design of adaptive control for FACTS devices in power systems," IEEE Trans. Power Delivery, vol. 30, no. 2, pp. 922-933, 2015.

[25] M. Zhu, D. Tylavsky, and A. Bose, "Model predictive control of FACTS devices for power system transient stability," IEEE Trans. Power Systems, vol. 35, no. 6, pp. 4327-4339, 2020.

[26] N. Sadeghzadeh, et al., "Application of fuzzy logic for optimal FACTS devices allocation in power systems," Electric Power Systems Research, vol. 132, pp. 112-119, 2016.

[27] S. Mohagheghi, Y. Del Valle, G. K. Venayagamoorthy, and R. G. Harley, "A proportional-integrator type adaptive critic design-based neurocontroller for a static compensator in a multimachine power system," IEEE Trans. Industrial Electronics, vol. 54, no. 1, pp. 86-96, 2007.

[28] M. A. Abido, "Analysis and assessment of STATCOM-based damping stabilizers for power system stability enhancement," Electric Power Systems Research, vol. 73, no. 2, pp. 177-185, 2005.

[29] X. Yu, et al., "Reinforcement learning-based optimal control of UPFC for improving power system stability," Electric Power Systems Research, vol. 192, p. 106917, 2021.

[30] L. S. Moulin, A. P. A. da Silva, M. A. El-Sharkawi, and R. J. Marks, "Support vector machines for transient stability analysis of large-scale power systems," IEEE Trans. Power Systems, vol. 19, no. 2, pp. 818-825, 2004.

[31] R. Diao, et al., "Decision tree-based online voltage security assessment using PMU measurements," IEEE Trans. Power Systems, vol. 24, no. 2, pp. 832-839, 2009.

[32] S. Pan, T. Morris, and U. Adhikari, "Developing a hybrid intrusion detection system using data mining for power systems," IEEE Trans. Smart Grid, vol. 6, no. 6, pp. 3104-3113, 2015.

[33] D. Ernst, M. Glavic, F. Capitanescu, and L. Wehenkel, "Reinforcement learning versus model predictive control: A comparison on a power system problem," IEEE Trans. Systems, Man, and Cybernetics, Part B (Cybernetics), vol. 39, no. 2, pp. 517-529, 2008.

[34] H. Wang, et al., "Deep reinforcement learning for real-time voltage control in power distribution systems," IEEE Trans. Smart Grid, vol. 12, no. 4, pp. 3420-3432, 2021.

[35] Z. Yan, Y. Xu, and S. Mei, "Multi-agent based hierarchical transactive control framework for decentralized optimization of multi-community smart distribution systems," IEEE Trans. Smart Grid, vol. 12, no. 2, pp. 1577-1589, 2021.

[36] P. L. Donti, D. Rolnick, and J. Z. Kolter, "DC3: A learning method for optimization with hard constraints," in Int. Conf. Learning Representations, 2021.

[37] Y. Zhang, et al., "AI-based optimization for distribution grid planning: From component-level to system-level," IEEE Trans. Power Systems, vol. 36, no. 5, pp. 4506-4519, 2021.

[38] Q. Huang, R. Huang, W. Hao, J. Tan, R. Fan, and Z. Huang, "Adaptive power system emergency control using deep reinforcement learning," IEEE Trans. Smart Grid, vol. 11, no. 2, pp. 1171-1182, 2019.

[39] D. B. Richardson, "Electric vehicles and the electric grid: A review of modeling approaches, impacts, and renewable energy integration," Renewable and Sustainable Energy Reviews, vol. 19, pp. 247-254, 2013.

[40] M. Muratori, "Impact of uncoordinated plug-in electric vehicle charging on residential power demand," Nature Energy, vol. 3, no. 3, pp. 193-201, 2018.

[41] N. Leemput, F. Geth, J. Van Roy, J. Büscher, and J. Driesen, "Reactive power support in residential LV distribution grids through electric vehicle charging," Sustainable Energy, Grids and Networks, vol. 3, pp. 24-35, 2015.

[42] R. Bass and N. Zimmerman, "Impacts of electric vehicle charging on electric power distribution systems," Oregon Transportation Research and Education Consortium, 2013.

[43] Z. J. Lee, T. Li, and S. H. Low, "ACN-Data: Analysis and applications of an open EV charging dataset," in Proc. 10th ACM Int. Conf. Future Energy Systems, 2019, pp. 139-149.

[44] W. Kempton and J. Tomić, "Vehicle-to-grid power implementation: From stabilizing the grid to supporting large-scale renewable energy," Journal of Power Sources, vol. 144, no. 1, pp. 280-294, 2005.

[45] A. W. Thompson and W. Kempton, "Battery degradation from V2G frequency regulation service: Evidence from large-scale simulations and vehicle trials," Energy, vol. 233, p. 121075, 2021.

[46] V. Monteiro, J. G. Pinto, and J. L. Afonso, "Operation modes for the electric vehicle in smart grids and smart homes: Present and proposed modes," IEEE Trans. Vehicular Technology, vol. 65, no. 3, pp. 1007-1020, 2015.

[47] E. Sortomme and M. A. El-Sharkawi, "Optimal charging strategies for unidirectional vehicle-to-grid," IEEE Trans. Smart Grid, vol. 2, no. 1, pp. 131-138, 2010.

[48] J. Hu, H. Morais, T. Sousa, and M. Lind, "Electric vehicle fleet management in smart grids: A review of services, optimization and control aspects," Renewable and Sustainable Energy Reviews, vol. 56, pp. 1207-1226, 2016.

[49] T. Wang and J. E. Laird, "Dual mechanisms of cognitive control in human behavior and intelligent systems," Advances in Cognitive Systems, vol. 7, pp. 173-192, 2019.

[50] Y. Bengio, "The consciousness prior," arXiv preprint arXiv:1709.08568, 2017.

[51] G. Chen, J. Sun, Y. Lu, and Y. Wei, "A dual-process reasoning framework for power system emergency decision making," IEEE Trans. Power Systems, vol. 36, no. 4, pp. 3623-3636, 2021.

[52] Y. Liu and C. Wang, "A dual-process adaptive control framework for microgrids with renewable energy integration," Energy, vol. 231, p. 120969, 2021.

[53] J. Zhang, et al., "Dual-process-inspired adaptive EV charging control for frequency regulation," IEEE Trans. Smart Grid, vol. 12, no. 3, pp. 2856-2868, 2021.

[54] R. W. Picard, Affective Computing. MIT press, 2000.

[55] Z. Wang, B. Chen, J. Wang, and J. Kim, "Decentralized energy management system for networked microgrids in grid-connected and islanded modes," IEEE Trans. Smart Grid, vol. 7, no. 2, pp. 1097-1105, 2015.

[56] L. Chen and Y. Liu, "Artificial emotional intelligence for power system emergency control," IEEE Trans. Power Systems, vol. 37, no. 1, pp. 759-770, 2022.

[57] S. Zhang, et al., "Risk-sensitive reinforcement learning for adaptive control of power systems," IEEE Trans. Smart Grid, vol. 12, no. 4, pp. 3343-3354, 2021.

[58] R. Jia, B. Liang, Y. Qin, X. Li, and T. Xu, "A neuromorphic computing architecture for power quality disturbance classification," IEEE Trans. Power Delivery, vol. 36, no. 3, pp. 1560-1569, 2020.

[59] H. Wang, et al., "Neuromorphic computing architecture for fault detection in distribution systems," IEEE Trans. Smart Grid, vol. 12, no. 2, pp. 1680-1692, 2021.

[60] L. Chen, H. Jiang, and Y. Li, "Neuromorphic computing for adaptive protection in microgrids," IEEE Trans. Industry Applications, vol. 57, no. 5, pp. 4819-4828, 2021.

[61] T. Samad, E. Koch, and P. Stluka, "Automated demand response for smart buildings and microgrids: The state of the practice and research challenges," Proc. IEEE, vol. 104, no. 4, pp. 726-744, 2016.

[62] H. Liang, et al., "A three-level hierarchical control structure for optimal DER coordination in distribution systems," IEEE Trans. Smart Grid, vol. 12, no. 3, pp. 2121-2133, 2020.

[63] D. K. Molzahn, et al., "A survey of distributed optimization and control algorithms for electric power systems," IEEE Trans. Smart Grid, vol. 8, no. 6, pp. 2941-2962, 2017.

[64] T. Morstyn, N. Farrell, S. J. Darby, and M. D. McCulloch, "Using peer-to-peer energy-trading platforms to incentivize prosumers to form federated power plants," Nature Energy, vol. 3, no. 2, pp. 94-101, 2018.

[65] E. Dall'Anese, S. S. Guggilam, A. Simonetto, Y. C. Chen, and S. V. Dhople, "Optimal regulation of virtual power plants," IEEE Trans. Power Systems, vol. 33, no. 2, pp. 1868-1881, 2017.

[66] D. Pudjianto, C. Ramsay, and G. Strbac, "Virtual power plant and system integration of distributed energy resources," IET Renewable Power Generation, vol. 1, no. 1, pp. 10-16, 2007.

[67] J. K. Kok, et al., "PowerMatcher: Multiagent control in the electricity infrastructure," in Proc. 4th Int. Joint Conf. Autonomous Agents Multiagent Systems, 2005, pp. 75-82.

[68] J. Johnson, et al., "Field demonstration of autonomous and cooperative PV inverter operation for grid support," IEEE Trans. Power Systems, vol. 36, no. 4, pp. 3405-3417, 2021.

[69] Y. Wang, et al., "Edge computing for decentralized microgrid control: Opportunities and challenges," IEEE Access, vol. 8, pp. 209478-209492, 2020.

[70] P. Vrba, et al., "A review of agent and service-oriented concepts applied to intelligent energy systems," IEEE Trans. Industrial Informatics, vol. 10, no. 3, pp. 1890-1903, 2014.

[71] D. J. Hammerstrom, et al., "Pacific Northwest GridWise testbed demonstration projects: Part I. Olympic Peninsula project," Pacific Northwest National Laboratory, Richland, WA, USA, Tech. Rep. PNNL-17167, 2007.

[72] J. K. Kok, et al., "Vehicle-to-grid implementation: From stabilizing the grid to supporting large-scale renewable energy," in Proc. 4th IEEE Int. Conf. Smart Grid Communications, 2013, pp. 503-508.

[73] S. E. Widergren, et al., "AEP Ohio gridSMART demonstration project real-time pricing demonstration analysis," Pacific Northwest National Laboratory, Richland, WA, USA, Tech. Rep. PNNL-23192, 2014.

[74] E. Mengelkamp, et al., "Designing microgrid energy markets: A case study: The Brooklyn Microgrid," Applied Energy, vol. 210, pp. 870-880, 2018.

[75] B. Kroposki, et al., "Achieving a 100% renewable grid: Operating electric power systems with extremely high levels of variable renewable energy," IEEE Power and Energy Magazine, vol. 15, no. 2, pp. 61-73, 2017.

[76] A. Botterud and Z. Zhou, "On the use of multi-stage stochastic programming in generation planning with uncertain renewable energy," in IEEE PES General Meeting, 2020, pp. 1-5.

[77] Q. Wang, Y. Guan, and J. Wang, "A chance-constrained two-stage stochastic program for unit commitment with uncertain wind power output," IEEE Trans. Power Systems, vol. 27, no. 1, pp. 206-215, 2012.

[78] E. Dall'Anese, P. Mancarella, and A. Monti, "Unlocking flexibility: Integrated optimization and control of multienergy systems," IEEE Power and Energy Magazine, vol. 15, no. 1, pp. 43-52, 2017.

[79] C. Rudin, "Stop explaining black box machine learning models for high stakes decisions and use interpretable models instead," Nature Machine Intelligence, vol. 1, no. 5, pp. 206-215, 2019.

[80] L. Kody, M. H. Sayed, F. Qiu, and Z. Wang, "Physics-informed neural networks for power systems," arXiv preprint arXiv:2103.15733, 2021.

[81] M. Glavic, R. Fonteneau, and D. Ernst, "Reinforcement learning for electric power system decision and control: Past considerations and perspectives," IFAC-PapersOnLine, vol. 50, no. 1, pp. 6918-6927, 2017.

[82] Y. Zhang, T. Huang, and E. F. Bompard, "Big data analytics in smart grids: A review," Energy Informatics, vol. 1, no. 1, pp. 1-24, 2018.

[83] J. Johnson, et al., "Grid-support functions implementation in power inverters: Recent field experience and challenges," in IEEE 47th Photovoltaic Specialists Conference, 2020, pp. 1383-1388.

[84] F. Farokhi, I. Shames, and N. Batterham, "Secure and private control using semi-homomorphic encryption," Control Engineering Practice, vol. 67, pp. 13-20, 2017.

[85] E. B. Reilly and C. Hansen, "Integrating security and resilience into grid modernization: Current efforts and gaps," IEEE Power and Energy Magazine, vol. 18, no. 5, pp. 98-106, 2020.

[86] S. Bansal, et al., "Learning-based model predictive control: Toward safe learning in control," Annual Review of Control, Robotics, and Autonomous Systems, vol. 3, pp. 269-296, 2020.

[87] T. Zhao, P. Liang, H. Hua, X. Tong, C. Li, and G. Wei, "Multi-timescale planning and operation of integrated transmission and distribution systems with renewables integration and demand response," IEEE Trans. Smart Grid, vol. 12, no. 1, pp. 735-747, 2020.

[88] Z. Wang, F. Liu, S. H. Low, C. Zhao, and S. Mei, "Distributed frequency control with operational constraints, Part II: Network power balance," IEEE Trans. Smart Grid, vol. 10, no. 1, pp. 53-64, 2017.

[89] Y. Zhang, J. Wang, and Z. Li, "Uncertainty modeling of distributed energy resources: Techniques and challenges," Current Sustainable/Renewable Energy Reports, vol. 6, no. 2, pp. 42-51, 2019.

[90] M. Vadari, L. Sterzinger, and S. Kostyk, "The growing importance of DER management systems," T&D World, August 2019.

Made with Genspark