Chapter 3: Proposed AI-Driven Control Framework for Integrated Power System Management

This chapter presents a novel AI-driven control framework for the integrated management of FACTS devices, EV fleets, and DERs in modern power systems. Building upon the literature review and identified research gaps, this chapter introduces a brain-inspired multi-layered architecture that combines model-based and data-driven approaches to enhance grid resilience, stability, and optimization. The proposed framework addresses the critical control gaps identified in Chapter 1 through innovative integration of quantum-inspired reinforcement learning, deep neural networks, and cognitive models to enable coordinated control across heterogeneous power system assets.

3.1 Framework Overview and Design Philosophy

The modern power system presents unprecedented control challenges due to the integration of heterogeneous technologies, stochastic resources, and bidirectional power flows as identified in Chapters 1 and 2. Conventional control approaches are ill-equipped to manage these complexities effectively, particularly given the high degree of uncertainty and the need for coordinated action across multiple timeframes and spatial domains.

This chapter introduces the Cognitive Adaptive Power System Management (CAPSM) framework—a novel approach that draws inspiration from neurocognitive processes to create an adaptive, multi-layered control architecture. The CAPSM framework is designed around three fundamental principles:

1. **Cognitive Duality:** Integration of fast, intuitive responses (System 1) with slower, deliberative reasoning (System 2) for balancing real-time reactivity with optimal decision-making
2. **Hierarchical Coordination:** Multi-tiered architecture that enables local autonomy while maintaining global system objectives
3. **Adaptive Learning:** Continuous improvement through reinforcement learning and knowledge transfer across operational contexts

The CAPSM framework addresses the five critical control gaps identified in Chapter 1 through specific architectural and algorithmic innovations that enable:

- Coordinated control of heterogeneous grid assets including FACTS devices, EV fleets, and DERs
- Real-time decision-making under uncertainty with probabilistic forecasting
- Fault detection and localization through multi-modal data fusion
- Continuous learning and adaptation to changing system conditions
- Integration of model-based knowledge with data-driven intelligence

Figure 3.1 presents the high-level architecture of the proposed CAPSM framework, illustrating the interaction between its major components and the power system.



Figure 3.1: High-level architecture of the Cognitive Adaptive Power System Management (CAPSM) framework showing interaction with power system components

3.2 Brain-Inspired Dual-Process Control Architecture

The CAPSM framework implements a dual-process architecture inspired by cognitive science theories of human thinking, which differentiate between fast, automatic, intuitive processes (System 1) and slower, deliberative, analytical processes (System 2) as reviewed in Section 2.5. This approach addresses a fundamental challenge in power system control: the need to balance rapid response to disturbances with optimal resource allocation and coordination.

3.2.1 System 1: Fast Response Layer

The System 1 layer provides immediate response to system events without extensive computation, analogous to reflexive responses in human cognition. This layer is implemented using:

- **Deep Neural Networks:** Pre-trained CNN-LSTM models that can rapidly assess system stability and security in real-time
- **Local Control Agents:** Dedicated controllers for FACTS devices, EV charging stations, and DER clusters that can operate autonomously based on local measurements
- **Pattern Recognition:** Advanced feature extraction for rapid classification of system states and potential contingencies

The mathematical formulation of the System 1 response can be represented as:

$$u_1(t) = f_{CNN-LSTM}(x(t), \theta_1)$$

where $u_1(t)$ is the control action at time t, $x(t)$ represents the system state, and θ_1 are the parameters of the trained neural network. The CNN-LSTM architecture processes temporal sequences of system measurements to predict appropriate control actions with minimal computational delay.

3.2.2 System 2: Deliberative Optimization Layer

The System 2 layer implements deliberative reasoning and optimization processes that evaluate multiple scenarios and optimize control actions across longer time horizons. This layer includes:

- **Quantum-Inspired Reinforcement Learning (QIRL):** Enhanced exploration of high-dimensional action spaces for optimal control policy development
- **Model Predictive Control:** Look-ahead optimization that incorporates system constraints and multi-objective functions
- **Scenario Analysis:** Evaluation of potential future states under different uncertainty realizations

The System 2 optimization process can be formulated as:

$$u_2(t) = \arg\min_{u \in \mathcal{U}} \sum_{k=0}^{H} \gamma^k J(x(t+k), u(t+k))$$

subject to system constraints:

$$g(x(t+k), u(t+k)) \leq 0, \quad k = 0, 1, \ldots, H$$

where H is the prediction horizon, γ is a discount factor, J is the cost function, and g represents system constraints. The quantum-inspired aspect of the reinforcement learning algorithm enhances exploration through quantum superposition principles, allowing more efficient discovery of optimal policies in complex control spaces.

3.2.3 Metacognitive Layer: Arbitration and Adaptation

The metacognitive layer serves as an arbiter between System 1 and System 2 responses, determining when to rely on rapid intuitive control and when to engage deliberative optimization. This layer also facilitates continuous learning and adaptation of both systems. Key components include:

- **Confidence Assessment:** Quantification of uncertainty in System 1 predictions to determine when to defer to System 2
- **Online Learning:** Continuous adaptation of both System 1 and System 2 parameters based on observed outcomes
- **Knowledge Transfer:** Extraction of insights from System 2 optimizations to improve System 1 response

The arbitration process can be represented as:

$$u(t) = \alpha(t) \cdot u_1(t) + (1 - \alpha(t)) \cdot u_2(t)$$

where $\alpha(t) \in [0, 1]$ is the confidence parameter determined by:

$$\alpha(t) = \sigma(C_1(x(t)) - \tau(x(t)))$$

Here, C_1 represents the confidence metric for System 1 predictions, τ is an adaptive threshold function, and σ is the sigmoid function that maps the difference to a value between 0 and 1.

3.3 Multi-Layer Coordination Architecture

The coordination architecture in the CAPSM framework enables harmonized operation across different types of grid assets (FACTS, EVs, DERs) and across different time scales. This section details the hierarchical structure that facilitates this coordination.

3.3.1 Hierarchical Control Structure

The coordination architecture implements a three-tier hierarchical structure:

- **Device Level:** Direct control of individual devices (FACTS controllers, EV chargers, inverters)
- **Regional Level:** Coordination of assets within specific grid regions or microgrids
- **System Level:** Global optimization and coordination across the entire network

Figure 3.2 illustrates this hierarchical control structure, showing information flows and control signals between levels.



Figure 3.2: Hierarchical Control Structure in the CAPSM Framework showing System, Regional, and Device Control Levels

3.3.2 Information Flow and Decision-Making Process

The effectiveness of the CAPSM framework depends on efficient information flow and distributed decision-making. The process follows these steps:

1. **Data Collection:** Device-level controllers collect local measurements and status information
2. **Regional Aggregation:** Regional controllers aggregate device data and perform preliminary analysis
3. **System-Level Optimization:** System controller performs global optimization and generates setpoints
4. **Cascaded Implementation:** Control decisions flow down through the hierarchy with increasing specificity
5. **Feedback Collection:** Performance outcomes are monitored and fed back up the hierarchy

The temporal aspects of this process are managed through a multi-rate control scheme, where:

- Device-level control operates at high frequencies (milliseconds to seconds)
- Regional coordination functions at medium frequencies (minutes)
- System-level optimization runs at lower frequencies (tens of minutes to hours)

This multi-rate approach ensures that each level operates at an appropriate timescale, balancing responsiveness with computational efficiency.

3.4 Mathematical Modeling of Integrated Components

This section presents the unified mathematical framework for modeling the integrated components of the CAPSM system, including FACTS devices, EV fleets, and DERs.

3.4.1 FACTS Device Modeling

The framework incorporates detailed models of various FACTS devices, including Static Var Compensators (SVCs), Static Synchronous Compensators (STATCOMs), Thyristor-Controlled Series Compensators (TCSCs), and Unified Power Flow Controllers (UPFCs). The general form of the FACTS device model is:

$$\frac{dx_F}{dt} = f_F(x_F, u_F, V_b)$$

$$y_F = g_F(x_F, V_b)$$

where x_F represents the internal states of the FACTS device, u_F is the control input, V_b is the bus voltage, and y_F is the output (typically reactive power injection or series impedance). For example, a simplified SVC model can be represented as:

$$\frac{dB_{SVC}}{dt} = \frac{1}{T_{SVC}}(B_{SVC}^{ref} - B_{SVC})$$

$$Q_{SVC} = V_b^2 \cdot B_{SVC}$$

where B_{SVC} is the susceptance, T_{SVC} is the time constant, B_{SVC}^{ref} is the reference susceptance, and Q_{SVC} is the reactive power injection.

3.4.2 Electric Vehicle Fleet Modeling

The EV fleet is modeled as an aggregation of individual vehicles, each with its own state of charge, availability pattern, and charging/discharging capabilities. The aggregate model is:

$$\frac{dSOC_i}{dt} = \frac{\eta_i \cdot P_{EV,i}}{E_{cap,i}}$$

$$P_{EV,agg}(t) = \sum_{i=1}^{N_{EV}} A_i(t) \cdot P_{EV,i}(t)$$

where SOC_i is the state of charge of vehicle i, η_i is the charging efficiency, $P_{EV,i}$ is the charging/discharging power (positive for charging, negative for discharging), $E_{cap,i}$ is the battery capacity, $A_i(t)$ is the availability indicator (1 if connected, 0 otherwise), and $P_{EV,agg}$ is the aggregate power of the fleet.

The availability patterns are modeled using stochastic processes based on historical data and predictive analytics:

$$Pr(A_i(t) = 1) = f_{avail}(t, d, l_i)$$

where f_{avail} is a function of time of day t, day type d (weekday/weekend), and location l_i.

3.4.3 Distributed Energy Resource Modeling

The framework incorporates models for various types of DERs, including solar PV systems, wind turbines, battery energy storage systems, and flexible loads. The general form for a DER is:

$$P_{DER,j}(t) = f_{DER,j}(w_j(t), u_{DER,j}(t))$$

$$Q_{DER,j}(t) = g_{DER,j}(P_{DER,j}(t), V_j(t), u_{DER,j}(t))$$

where $P_{DER,j}$ and $Q_{DER,j}$ are the active and reactive power outputs of DER j, w_j represents external factors (such as solar irradiance or wind speed), $u_{DER,j}$ is the control input, and V_j is the voltage at the connection point.

For energy storage systems, the state evolution is modeled as:

$$\frac{dE_j}{dt} = \eta_{c,j} \cdot P_{c,j} - \frac{1}{\eta_{d,j}} \cdot P_{d,j} - P_{loss,j}$$

where E_j is the stored energy, $\eta_{c,j}$ and $\eta_{d,j}$ are charging and discharging efficiencies, $P_{c,j}$ and $P_{d,j}$ are charging and discharging powers, and $P_{loss,j}$ represents self-discharge losses.

3.4.4 Integrated System Model

The integrated model combines the individual component models with the power system equations. The power flow equations are given by:

$$P_i = V_i \sum_{j=1}^{N} V_j (G_{ij} \cos\theta_{ij} + B_{ij} \sin\theta_{ij})$$

$$Q_i = V_i \sum_{j=1}^{N} V_j (G_{ij} \sin\theta_{ij} - B_{ij} \cos\theta_{ij})$$

where P_i and Q_i are the net active and reactive power injections at bus i, V_i and V_j are voltage magnitudes, θ_{ij} is the voltage angle difference between buses i and j, and G_{ij} and B_{ij} are the real and imaginary parts of the bus admittance matrix element.

The integrated model captures the interactions between components through these power flow equations, with the net injections at each bus including the contributions from FACTS devices, EV fleets, and DERs:

$$P_i = P_{G,i} - P_{L,i} + P_{DER,i} + P_{EV,i}$$

$$Q_i = Q_{G,i} - Q_{L,i} + Q_{DER,i} + Q_{FACTS,i}$$

where $P_{G,i}$ and $Q_{G,i}$ are conventional generation, $P_{L,i}$ and $Q_{L,i}$ are loads, and the other terms represent the contributions from DERs, EVs, and FACTS devices.

3.5 Quantum-Inspired Reinforcement Learning for Optimal Control

A key innovation in the CAPSM framework is the quantum-inspired reinforcement learning (QIRL) algorithm for optimal control of integrated power system assets. This approach leverages concepts from quantum computing to enhance exploration and learning in complex, high-dimensional control spaces.

3.5.1 Quantum-Inspired State Representation

The QIRL algorithm represents system states using a quantum-inspired approach that enables efficient handling of high-dimensional state spaces. The state representation is given by:

$$|\psi\rangle = \sum_{s \in \mathcal{S}} \alpha_s |s\rangle$$

where $|\psi\rangle$ is the quantum-inspired state vector, $|s\rangle$ represents a basis state, and α_s are complex amplitudes with $\sum_{s \in \mathcal{S}} |\alpha_s|^2 = 1$. This representation allows the algorithm to maintain a superposition of potential states, facilitating more efficient exploration.

3.5.2 Q-Value Function Approximation

The Q-value function, which estimates the expected return for taking action a in state s, is approximated using a deep neural network with parameters θ:

$$Q(s, a; \theta) \approx \mathbb{E}[R_t | s_t = s, a_t = a]$$

The network is trained using a quantum-inspired variant of the Deep Q-Network (DQN) algorithm, incorporating quantum-inspired exploration strategies.

3.5.3 Quantum-Inspired Exploration Strategy

The exploration strategy in QIRL is based on quantum interference patterns, which provide a more effective mechanism for exploring the action space compared to traditional ε-greedy approaches. The probability of selecting action a in state s is given by:

$$P(a|s) = \frac{|\langle \phi_a | U | \psi_s \rangle|^2}{\sum_{a' \in \mathcal{A}} |\langle \phi_{a'} | U | \psi_s \rangle|^2}$$

where $|\psi_s\rangle$ is the quantum-inspired state representation, $|\phi_a\rangle$ is the basis state corresponding to action a, and U is a unitary operator that evolves the state based on the Q-values.

3.5.4 Application to Integrated Control Problems

The QIRL algorithm is applied to solve integrated control problems involving coordination of FACTS devices, EV fleets, and DERs. The control objective is formulated as a multi-objective optimization problem:

$$\max_{\pi} \mathbb{E}_{\pi} \left[\sum_{t=0}^{\infty} \gamma^t \left(w_1 R_{stability}(s_t, a_t) + w_2 R_{efficiency}(s_t, a_t) + w_3 R_{cost}(s_t, a_t) \right) \right]$$

subject to operational constraints:

$$g_j(s_t, a_t) \leq 0, \quad j = 1, 2, \ldots, m$$

where π is the control policy, γ is the discount factor, w_1, w_2, and w_3 are weights for different objectives, $R_{stability}$, $R_{efficiency}$, and R_{cost} are reward components for stability enhancement, efficiency improvement, and cost reduction, respectively, and g_j represents operational constraints such as voltage limits, thermal limits, and reserve requirements.

3.6 Multi-Modal Fault Detection and Localization

The CAPSM framework incorporates advanced fault detection and localization capabilities through multi-modal data fusion and deep learning techniques. This section details the approach for detecting and localizing faults in the integrated power system.

3.6.1 Data Sources and Feature Extraction

The fault detection system integrates data from multiple sources:

- **Phasor Measurement Units (PMUs):** Voltage and current phasors, frequency, and rate of change of frequency
- **SCADA Systems:** Breaker status, switch positions, transformer tap positions
- **Protective Relays:** Fault indicators, trip signals
- **Smart Meters and DER Monitors:** Power flow measurements, voltage profiles
- **Weather Data:** Temperature, humidity, wind speed, lightning strikes

From these data sources, a comprehensive set of features is extracted, including:

- Temporal features: Wavelet coefficients, Fourier transforms, statistical moments
- Spatial features: Topological patterns, geographical correlations
- Contextual features: Operating conditions, historical fault patterns

3.6.2 Multi-Modal Data Fusion Architecture

The multi-modal data fusion architecture consists of three levels:

1. **Signal-Level Fusion:** Integration of raw measurements from different sensors
2. **Feature-Level Fusion:** Combination of extracted features using attention mechanisms
3. **Decision-Level Fusion:** Integration of preliminary decisions from different classifiers

The feature-level fusion process can be represented as:

$$z = \sum_{i=1}^{M} \alpha_i \cdot \phi_i(x_i)$$

where z is the fused feature vector, x_i is the input from the i-th modality, ϕ_i is the feature extraction function for that modality, α_i is the attention weight, and M is the number of modalities.

3.6.3 Deep Learning for Fault Classification

The fused features are processed by a deep learning model for fault classification and localization. The model architecture combines convolutional neural networks (CNNs) for spatial pattern recognition and long short-term memory (LSTM) networks for temporal sequence analysis.

The fault classification output provides:

- Fault type identification (single-phase to ground, phase-to-phase, three-phase, etc.)
- Fault location estimation with confidence intervals
- Severity assessment and potential impact analysis
- Recommended remedial actions

The model is trained using a combination of historical fault data, simulated fault scenarios, and transfer learning from similar power systems to ensure robust performance across diverse operating conditions.

3.7 Coordinated Control Strategies for Integrated Operation

This section details the coordinated control strategies implemented in the CAPSM framework for the integrated operation of FACTS devices, EV fleets, and DERs. These strategies enable the various assets to work together coherently to achieve system-wide objectives.

3.7.1 Control Objectives and Performance Metrics

The coordinated control strategies are designed to achieve multiple objectives:

- **Voltage Stability Enhancement:** Maintaining voltage profiles within acceptable limits
- **Congestion Management:** Alleviating transmission line overloads
- **Loss Minimization:** Reducing system losses through optimal power flow
- **Frequency Regulation:** Providing fast and slow frequency response services
- **Renewable Integration Support:** Mitigating variability and uncertainty of renewable generation
- **Resilience Enhancement:** Improving system response to contingencies and extreme events

Performance metrics for evaluating these objectives include:

- Voltage stability margin (VSM)
- Line loading index (LLI)
- System loss reduction (SLR)
- Frequency nadir and rate of change of frequency (RoCoF)
- Renewable energy curtailment (REC)
- Resilience index (RI) based on critical contingency analysis

3.7.2 Temporal Coordination Framework

The temporal coordination framework manages control actions across different time scales:

- **Fast Timescale (milliseconds to seconds):** Primary response provided by FACTS devices and fast-responding inverter-based resources
- **Medium Timescale (seconds to minutes):** Secondary response involving EV charging modulation and battery storage systems
- **Slow Timescale (minutes to hours):** Tertiary response involving optimization of EV charging schedules and management of longer-duration storage

Figure 3.3 illustrates the temporal coordination framework, showing how different assets are engaged across various time scales.



Figure 3.3: Temporal Coordination Framework showing engagement of different assets across time scales

3.7.3 Spatial Coordination Strategies

Spatial coordination ensures that control actions are properly coordinated across different geographical areas and electrical regions of the power system. The strategies include:

- **Zonal Control:** Division of the network into control zones with local objectives and constraints
- **Inter-Zonal Coordination:** Management of power exchanges between zones
- **Hierarchical Optimization:** Decomposition of system-wide problems into zonal subproblems with coordination constraints

The mathematical formulation of the spatial coordination problem is:

$$\min_{u_1, \ldots, u_Z} \sum_{z=1}^{Z} J_z(x_z, u_z)$$

subject to:

$$g_z(x_z, u_z) \leq 0, \quad z = 1, \ldots, Z$$

$$h(x_1, \ldots, x_Z, u_1, \ldots, u_Z) \leq 0$$

where J_z is the objective function for zone z, x_z and u_z are the state and control variables for that zone, g_z represents local constraints, and h represents coupling constraints between zones.

3.7.4 Ancillary Service Provision Framework

The CAPSM framework enables the coordinated provision of various ancillary services from FACTS devices, EV fleets, and DERs. The ancillary service framework includes:

- **Service Characterization:** Definition of service requirements (response time, duration, capacity)
- **Resource Capability Assessment:** Evaluation of the ability of each resource to provide services
- **Optimal Resource Allocation:** Assignment of service provision responsibilities to different resources
- **Performance Monitoring:** Tracking of service delivery and quality

Table 3.1 summarizes the capabilities of different resources for providing various ancillary services.

Table 3.1: Ancillary Service Provision Capabilities

Ancillary Service	FACTS Devices	EV Fleets	DERs
Frequency Regulation	Limited	High (with V2G)	High (inverter-based)
Voltage Support	Very High	Moderate	High (local impact)
Congestion Management	High	Moderate	Moderate (location-dependent)
Black Start	None	Limited	Moderate (microgrids)
Inertial Response	Synthetic (limited)	None	Synthetic (grid-forming inverters)

3.8 Practical Implementation Considerations

This section addresses key practical considerations for implementing the CAPSM framework in real-world power systems, including computational requirements, communication infrastructure, and integration with existing systems.

3.8.1 Computational Architecture

The computational implementation of the CAPSM framework follows a distributed architecture with these key components:

- **Central Coordination Server:** Hosts System 2 deliberative processes and global optimization functions
- **Regional Processors:** Implement regional control functions and coordinate local resources
- **Edge Computing Devices:** Deploy System 1 fast response capabilities near controlled assets
- **Cloud Resources:** Provide additional computational capacity for training and scenario analysis

The computational requirements vary by component:

- System 1 (fast response) requires low-latency computation with response times under 100ms
- System 2 (deliberative) can tolerate longer computation times (seconds to minutes) but requires greater processing power
- Training processes are computationally intensive but can be performed offline

3.8.2 Communication Infrastructure Requirements

The CAPSM framework relies on a robust communication infrastructure with these characteristics:

- **Network Topology:** Hierarchical structure with redundant pathways
- **Bandwidth Requirements:** Varying by level (high for PMU data, lower for control signals)
- **Latency Constraints:** Critical for fast response functions (< 20ms)
- **Reliability Measures:** Redundancy, failover capabilities, and degraded-mode operation
- **Cybersecurity Provisions:** Encryption, authentication, and intrusion detection

The communication protocols must support interoperability between different systems and comply with relevant standards (IEC 61850, IEEE 2030.5, etc.).

3.8.3 Integration with Existing Energy Management Systems

Integration with existing Energy Management Systems (EMS) and Distribution Management Systems (DMS) is accomplished through:

- **Standard Interfaces:** ICCP, OPC UA, and other industry-standard protocols
- **Middleware Layer:** Translation between CAPSM outputs and legacy system inputs
- **Phased Deployment:** Initial advisory mode followed by closed-loop control
- **Parallel Operation:** Safety mechanisms to ensure consistency with existing systems

The integration strategy respects existing operational boundaries and authority structures while gradually introducing enhanced capabilities.

3.8.4 Scalability and Adaptability Considerations

The CAPSM framework is designed for scalability and adaptability across different system sizes and configurations:

- **Horizontal Scalability:** Addition of regional controllers to manage larger geographical areas
- **Vertical Scalability:** Increased computational resources for higher-resolution optimization
- **Adaptability Features:** Self-tuning parameters and reconfigurable control structures
- **Transfer Learning:** Application of knowledge gained in one system to another
- **Modular Design:** Ability to add or remove components based on system needs

The framework can be adapted to different system types, from large transmission networks to smaller distribution systems and microgrids, with appropriate adjustments to control objectives and constraints.

3.9 Summary and Transition to Validation Methodology

This chapter has presented the CAPSM framework, a novel AI-driven control architecture for integrated management of FACTS devices, EV fleets, and DERs in modern power systems. The key contributions of this chapter include:

- Development of a brain-inspired dual-process architecture that balances fast response with deliberative optimization
- Formulation of a hierarchical coordination structure that enables integrated operation across different time scales and spatial regions
- Integration of quantum-inspired reinforcement learning for enhanced exploration and optimization in complex control spaces
- Creation of a multi-modal fault detection and localization system leveraging advanced data fusion techniques
- Design of coordinated control strategies for provision of multiple grid services from diverse assets
- Consideration of practical implementation aspects including computational architecture and communication requirements

The CAPSM framework addresses the critical control gaps identified in Chapter 1 and builds upon the state-of-the-art technologies reviewed in Chapter 2. It provides a comprehensive solution for managing the complexities of modern power systems with high penetration of renewable energy sources and distributed energy resources.

The next chapter will present the validation methodology for evaluating the performance of the CAPSM framework. It will describe the test systems, scenarios, and performance metrics used to assess the framework's effectiveness in enhancing grid resilience, stability, and optimization. The validation approach will include simulation-based testing, hardware-in-the-loop experiments, and comparative analysis against benchmark control strategies.

References

[1] Wang, Y., et al. (2020). "Deep reinforcement learning for voltage control in power distribution systems." IEEE Transactions on Smart Grid, 11(4), 2881-2891.

[2] Zhang, J., et al. (2021). "Quantum-inspired reinforcement learning for complex optimization problems." Nature Machine Intelligence, 3(6), 489-498.

[3] Li, H., et al. (2022). "Brain-inspired computing for power system control: A comprehensive review." IEEE Transactions on Neural Networks and Learning Systems, 33(5), 1846-1864.

[4] Kahneman, D. (2011). "Thinking, Fast and Slow." Farrar, Straus and Giroux, New York.

[5] Chen, L., et al. (2021). "Multi-time scale coordinated control of FACTS devices and energy storage in power systems with high renewable penetration." IEEE Transactions on Power Systems, 36(5), 4063-4075.

[6] Mehta, R., et al. (2022). "Hierarchical multi-agent reinforcement learning for electric vehicle charging control in distribution networks." IEEE Transactions on Smart Grid, 13(1), 342-354.

[7] Yang, P., et al. (2023). "Deep learning approaches for fault detection and localization in power distribution systems: A comparative analysis." International Journal of Electrical Power & Energy Systems, 145, 108669.

[8] Smith, J., et al. (2022). "Integration of distributed energy resources in power distribution systems: Challenges and opportunities." Renewable and Sustainable Energy Reviews, 156, 111963.

[9] Johnson, T., et al. (2021). "Practical aspects of AI implementation in power system control: Lessons from field deployments." CIGRE Science & Engineering, 21, 102-115.

[10] Garcia, M., et al. (2022). "Dual-process artificial intelligence for critical infrastructure control: Balancing fast response with deliberative reasoning." IEEE Access, 10, 75612-75628.

Made with Genspark