



DATASHEET FOR EXPANSION TANK

Document No: KEY080-PRC-DAT-003
Erdemir No: ERD-0417-BFN1-05-OTH-MIS-00007

Owner / İşveren	Ereğli Demir Çelik Fabrikaları T.A.Ş
Owner Document Number	ERD-0417-BFN1-05-OTH-MIS-00007
Project / Proje	Erdemir 1 Nolu Yüksek Fırın Sobalar Sıcak Hava Valfleri Kapalı Çevrim Soğutma Sistemi
Location / Konum	Karadeniz Ereğli, Zonguldak, Turkey

Approval / Onaylayan	ERHAN YILDIZ Project Manager	Sign. / İmza	
Verification / Doğrulayan	HALİL ÜNAL Sn. Piping Designer	Sign. / İmza	
Prepared / Revised by / Hazırlayan	NURİ ÖZTÜRK Piping Engineer	Sign. / İmza	



DATASHEET



	Document Number / Doküman Numarası	Page / Sayfa	
	KEY080-PRC-DAT-003		
	ERD-0417-BFN1-05-OTH-MIS-00007	Rev. No	C02
	DATASHEET FOR EXPANSION TANK	DATE / TARİH :	-

REVISION HISTORY / REVİZYON GEÇMİŞİ

Rev. / Yayın	Date / Tarih	Prepared / Revised by / Hazırlayan	Status and Description / Durum ve Açıklama
C00	2/28/2022	FURKAN ÇEVİK	ISSUED FOR COMMENT / YORUM İÇİN
C01	8/18/2022	NURİ ÖZTÜRK	ISSUED FOR COMMENT / YORUM İÇİN
C02	9/29/2022	NURİ ÖZTÜRK	FINAL ISSUE

			VESSEL PROCESS SPECIFICATION								
			DEMIN WATER EXPANSION VESSEL								
CLIENT:		ERDEMİR		PROJECT NO:							
LOCATION:		Zonguldak, Turkey		DOCUMENT NO:		ERD-0417-BFN1-05-OTH-MIS-00007					
UNIT:				ITEM NO:		V-001					
SERVICE:		DEMIN WATER		NO REQ'D:		1					
DESIGN DATA			NOZZLE CHART								
SERVICE (FLUID CONTAINED) :			Demin Water/ Nitrogen	NO.	SIZE	RATING	FACING	SERVICE	NO.REQ.	NOTES	
VESSEL DIA. (I.D.) :		[mm]	1600	1	6"			Gas Inlet	1	Note 1,4	
HEIGHT (TAN./TAN.) :		[mm]	2600	2	2"			Nitrogen	1		
DESIGN CODE :		ASME VIII Div.1 (Latest) Code Symbol "U" is required		3	2"			Demin Water Make-up	1	Note 1	
				4	2"			Temperature Inst. (TT/TI)	1	Note 7	
INTERNAL DESIGN PRESSURE @ TOP :		[barg]	3,5 (Note 3)	5	2"			PSV Inlet	1		
VACUUM DESIGN CONDITIONS :			F.V.	6	2"			Pressure Inst. (PT/PI)	1	Note 7	
STEAM-OUT CONDITIONS :			Not req'd.	7A	2"			Level Inst. (LT/LG/LI)	1	Note 7	
OPERATING PRESSURE :		[barg]	0,1	7B	2"			Level Inst. (LT/LG/LI)	1	Note 7	
DESIGN TEMPERATURE :		[°C]	120	8A	2"			Level Inst. (LT/LI)	1	Note 7	
OPERATING TEMPERATURE :		[°C]	55	8B	2"			Level Inst. (LT/LI)	1	Note 7	
MIN. DESIGN METAL TEMP. :		[°C]	-10	9	12"			Demin Water Balance	1		
P.W.H.T. :				10	2"			Vent / Purge	1		
RADIOGRAPHY :				11	6"			Overflow	1		
MAGNETIC PARTICLE TESTING :				MH	24"			Manhole	1		
CORROSION ALLOWANCE :											
WIND :				NOTES:							
SEISMIC :											
INSULATION / THK. :			Winterization (Note 5)								
				1. INLET DEVICE IS BAFFLE.							
				2. PED FLUID GROUP: 2nd LIQ. VAPOUR PRESSURE < 0.5 BARG.							
SURFACE PREP. / PAINT		3. DESIGN PRESSURE EXCLUDES STATIC HEAD OF LIQUID. MAX. OPERATING LEVEL:2000 mm (FROM BTL). SG: 0,99									
SURFACE PREP. :											
PRIMER (INSULATED) :											
FINISH / COLOR (INSULATED) :		4. TWO PHASE FLOW AT THE INLET OF DRUM.									
PRIMER (UN INSULATED) :		5. WINTERIZATION UP TO HIGH HIGH LIQUID LEVEL.									
FINISH / COLOR (UN INSULATED) :		6. DELETED									
				7. INSTRUMENT NOZZLE SIZES ARE TO BE CHECKED BY INSTRUMENT DEPT.							
				8. PLEASE SEE ATTACHMENT A FOR DEMIN WATER QUALITY.							
EXT. ATTACHMENTS											
LADDERS & LATFORMS :											
LIFTING LUGS / TAILING LUG :											
EARTHING LUG :											
MATERIAL											
SHELL :											
HEADS :											
PIPE :											
FITTINGS :											
FLANGES :											
REINFORCEMENT (IF REQUIRED) :											
SADDLE WEAR PLATE / SUPPORTS :											
INT. / EXT. ATTACHMENTS :											
BOLTING :											
GASKETS :											
GASKET SURFACES :											
FLANGES :											
SHEET 2 OF 3											

		VESSEL PROCESS SPECIFICATION	
		DEMIN WATER EXPANSION VESSEL	
CLIENT:	ERDEMIR	PROJECT NO:	
LOCATION:	Zonguldak, Turkey	DOCUMENT NO:	ERD-0417-BFN1-05-OTH-MIS-00007
UNIT:		ITEM NO:	V-001
SERVICE:	DEMIN WATER / NITROGEN	NO REQ'D:	1

