



TANKER BOŞALTIM POMPASI DATASHEET

Doküman No:KEY201-MEC-DAT-002

İşveren	BORU HATLARI İLE PETROL TAŞIMA A.Ş.
Proje Adı	PS-3 SİLOPİ İSTASYONU BİRİM BAŞMÜHENDİSLİĞİ KARA TANKERİ BOŞALTIM İSTASYONU MÜHENDİSLİK VE DANIŞMANLIK HİZMET ALIMI

REVİZYON NO	HAZIRLAYAN	KONTROL EDEN	ONAYLAYAN
0			
DOKÜMAN TARİHİ			
03.07.2026			
YAYIN DURUMU			
IFA	TOPRAK BULUT	ERHAN YILDIZ	HALİL ÜNAL

1	ITEM NO.(S)	P-201...214		DRIVER TYPE	Electrical Motor	
2	NUMBER REQ. (OPER. + STAND BY)	14		NO. OF STAGES	(1)	
3	PUMP TYPE	Inline		GOVERNING CASE	(1)	
4	APPLICABLE STANDARD	(1)		LOCATION	Outdoor	
5	OPERATING CONDITIONS			LIQUID DATA		
6	MIN. FLOW RATE	(m³/h)		LIQUID TYPE OR NAME : Crude Oil		
7	NORMAL FLOW RATE	75.0 (m³/h)		HAZARDOUS : ZONE 1 FLAMMABLE ; YES OTHERS :		
8	MAX. FLOW RATE	(m³/h)		PUMPING TEMP. (°C) : MIN. -10 NORM. 25 MAX. 50		
9	OTHER			VAPOUR PRES. (bar-a) @ P.T.		
10	SUCT. PRESS. (MAX. / RATED)	1.26 / 0.86 (bar)		DENSITY (kg/m³) @ P.T. 860 @ 60°F		
11	DISCHARGE PRESS.	3.2 (bar)		VISCOSITY (cSt) 12.6 @ P.T.		
12	DIFFERENTIAL PRESS.	2.34 (bar)		SPECIFIC HEAT, Cp 523 (kJ/kgmoleC)		
13	DIFFERENTIAL HEAD	27 (m) NPSHa 10.2 (m)		CHLORIDE CONCENTRATION (PPM)		
14	PROCESS VARIATIONS			SULFUR CONTENT (wt %)		
15	STARTING CONDITIONS			CORROSIVE / EROSION AGENT : YES / YES		
16	SERVICE	Continuous		MATERIALS		
17	PARALLEL OPERATION REQ'D	No		ANNEX H CLASS (1)		
18	SITE DATA			MIN. DESIGN METAL TEMP. (1) (°C)		
19	LOCATION	Outdoor		BARREL / CASE (1) IMPELLER (1)		
20	ELECT. AREA CLASSIFICATION	Zone 1, Ex nA IIC T4 Gc		CASE / IMPELLER WEAR RINGS (1)		
21	WINTERIZATION REQ'D	NO		SHAFT (1)		
22	TROPICALIZATION REQ'D	NO		DIFFUSERS -		
23	ALTITUDE +550 (m) BAROMETER	mm Hg		PERFORMANCE		
24	RANGE OF AMBIENT TEMPS (MIN./MAX.)	-10 / 50 (°C)		PROPOSAL CURVE NO. (1) RPM (1)		
25	RELATIVE HUMIDITY (AVERAGE/MAX.)	/ (%)		IMPELLER DIA. (mm) RATED (1) MAX. (1) MIN. (1)		
26	UNUSUAL CONDITIONS			IMPELLER TYPE (1)		
27	OTHER			HYDR. POWER (100% EFF.) (1) (kW) EFFICIENCY: (1) (%)		
28	DRIVER MOTOR			MIN. CONTINUOUS FLOW :		
29	MANUFACTURER	(1)		THERMAL (1) (m³/h) STABLE (1) (m³/h)		
30	POWER (1) (kW)	(1) (rpm)		PREFERRED OPER. REGION (m³/h)		
31	FRAME (1) ENCLOSURE	XPRF, IP 55		ALLOWABLE OPER. REGION (m³/h)		
32	INSTALL. POSITION	SERVICE FACTOR (1)		MAX. HEAD @ RATED IMPELLER (1) (m)		
33	EFFICIENCY (1)			NORMAL SHAFT POWER (ESTIMATED) (1) (kW)		
34	VOLTS / PHASE / HERTZ	400 / 3 / 50		MAX. POWER @ RATED IMPELLER (1) (kW)		
35	TYPE	SQUIRREL CAGE		NPSHR AT RATED FLOW (1) (m)		
36	MINIMUM STARTING VOLTAGE	(1)		MAX. SUCTION SPECIFIC SPEED (1)		
37	INSULATION (1) TEMP. RISE	(1)		MAX. SOUND PRESS. LEVEL REQ'D 85 (dBA)		
38	FULL LOAD AMPS	(1)		ESTIMATED MAX. SOUND PRESS. LEVEL (-1) (dBA)		
39	LOCKED ROTOR AMPS	(1)		ESTIMATED MAX. SOUND POWER LEVEL (-1) (dBA)		
40	STARTING METHOD	SS		UTILITY CONDITIONS		
41	LUBE	(1)		ELECTRICITY :		
42	BEARINGS (TYPE / NO.)			DRIVERS VOLTAGE 400 PHASE 3 Hz. 50		
43	RADIAL (1) /	(1)		SPACE HEATER VOLTAGE (1) PHASE Hz. (1)		
44	THRUST (1) /	(1)		SYSTEM VOLTAGE DIP OTHERS		
45	VERTICAL THRUST CAPA.			STEAM : MAX. PRESS. MAX. TEMP. MIN. PRESS. MIN. TEMP.		
46	UP (1) (N) DOWN (1) (N)			(kg/cm² g) (°C) (kg/cm² g) (°C)		
47	NOTES:			DRIVERS		
48				HEATING		
49				COOLING WATER : SOURCE		
50				SUPPLY TEMP. (°C) MAX. RETURN TEMP. (°C)		
51	NOTE: Shut-off pressure is calculated as the maximum suction pressure plus 110% of the (rated) differential pressure.				NORM. PRESS. kg/cm²-g DESIGN PRESS kg/cm²-g	
52	NOTE: Pump can be operated both locally and remotely.				MIN. RET. PRESS. kg/cm²-g MAX. ALLOW. D.P. kg/cm²-g	
53					CHLORIDE CONCENTRATION : ppm Na Cl	