Alert	
Unit ID: **2-VS-1 Upper**	Asset ID: **50254146**
Description: **2-VS-1 upper**	

Account Information

ID: **402009**
Name: **Greer Lime**
Address: **1088 Germany Valley Limestone Road, Riverton, WV 26814-0000 US**
Parent Account: **MATTHEWS LUBRICANTS, INC.**

Sample Information

Sample ID: **25069376060**
Service Level: **Essential**
Bottle ID: **a003617376**
Tested Lubricant: **MOBIL SHC 629**

Equipment Information

Asset Class: **Circulating System**
Manufacturer:
Model:
Lubricant: **MOBIL SHC 629**

Sample Data & Trends

Sample Info	Report Status	Alert	Alert	Alert	Alert	Alert
	Sample ID	22227101036	22313108053	24240313040	24312397015	25069376060
	Service Level	Essential	Essential	Essential	Essential	Essential
	Bottle ID	a005355909	a005568321	a029564319	a033573320	a003617376
	Tested Lubricant	MOBIL SHC 629	MOBIL SHC 629	MOBIL SHC 629	MOBIL SHC 629	MOBIL SHC 629
	Sampled	06 Aug 2022	01 Nov 2022	09 Aug 2024	25 Oct 2024	04 Mar 2025
	Reported	31 Aug 2022	14 Nov 2022	05 Sep 2024	11 Nov 2024	12 Mar 2025
	Equipment Age					
	Oil Age					
	Make-up Volume					
	Oil Changed	Yes	No			
	Filter Changed		No			
Lubricant	Contamination Rating	Normal	Caution	Normal	Alert	Alert
	Equipment Rating	Normal	Normal	Alert	Alert	Alert
	Lubricant Rating	Alert	Alert	Alert	Alert	Caution
	Visc@40C (cSt)	225.5	227.9	233.6	232.1	
	TAN (mg KOH/g)	0.37	0.37		0.26	0.30
	Water (Hot Plate)	NotDetected		NotDetected	Detected	Detected
Wear (ppm)	Ag (Silver)	0		0	0	0
	Al (Aluminum)	0		0	0	0
	Cr (Chromium)	0		0	0	0
	Cu (Copper)	7		8	9	8
	Fe (Iron)	26		58	76	69
	Mo (Molybdenum)	5		2	2	2
	Ni (Nickel)	0		0	0	0
	Pb (Lead)	1		0	0	1
	Sn (Tin)	0		0	1	0
Contaminant (ppm)	K (Potassium)	0		0	1	0
	Na (Sodium)	0		0	0	0
	Si (Silicon)	6		8	8	8
Additive (ppm)	B (Boron)	1		0	0	0
	Ba (Barium)	0		0	0	0
	Ca (Calcium)	53		65	84	95
	Mg (Magnesium)	1		0	1	1
	P (Phosphorus)	347		371	428	435
	Zn (Zinc)	9		9	10	10

Viscosity



Wear



Contaminants



Physical Properties



Alert

Unit ID: **2-VS-1 Upper** Asset ID: **50254146**

Description: **2-VS-1 upper**

Account Information

ID: **402009**

Name: **Greer Lime**

Address: **1088 Germany Valley Limestone Road, Riverton, WV 26814-0000 US**

Parent Account: **MATTHEWS LUBRICANTS, INC.**

Sample Information

Sample ID: **25069376060**

Service Level: **Essential**

Bottle ID: **a003617376**

Tested Lubricant: **MOBIL SHC 629**

Equipment Information

Asset Class: **Circulating System**

Manufacturer:

Model:

Lubricant: **MOBIL SHC 629**

Continued

Recommendation/Comments

ACTION REQUIRED - ELEVATED IRON LEVEL. Determine source of Iron (Fe) and take corrective action. If the iron level is elevated for the first time with no history of an increasing trend, then resample immediately to confirm condition. Possible sources of iron include: a. Machinery component wear; b. Metal-to-metal contact; c. Corrosion; d. Abrasive dirt contamination. The oil may be unfit for continued use and should be closely monitored for further condition regressions. Inspect the equipment for signs of damage. Change the oil after corrective measures have been implemented. Contact your ExxonMobil representative for further assistance if necessary.

ACTION REQUIRED - EXCESSIVE WATER CONTAMINATION. Determine source of water and take corrective action. Analyze the oil with an on-site water test if accessible. Possible sources of water include: a. Leaking seals; b. Condensation resulting from low operating temperatures or prolonged shutdowns; c. Compromised oil cooler; d. Direct exposure to atmosphere as a result of compromises to system components (i.e. improperly sealed tank fill access point). Remove water from oil using centrifuges or dehydration units, or drain the oil and recharge the system with new oil. Resample the system after corrective measures have been implemented. Contact your ExxonMobil representative for further assistance if necessary.

ADMINISTRATION - INSUFFICIENT SAMPLE VOLUME. The sample volume is insufficient to support a complete analysis. As a result, certain tests were not completed, and no analysis can be provided. Before sending future samples to the laboratory, please ensure that adequate volumes are collected. Contact your ExxonMobil representative for further assistance if necessary.

Sample Timeline

- 04 Mar 2025 1:28 PM UTC - Brad Roy - In Service Oil Sample Comments: Photo: