CANON MEXICANA, S. DE R.L. DE C.V.

TITLE: **LEVELS OF LIGHTING APPROPRIATE IN THE WORKPLACE**					
REF: **SERVGEN-012**	VALIDITY			VERSION	PAGE 1 OF 4
	DAY	MONTH	YEAR		
	01	06	18	**2 .0**	

I. Objective.

Establish guidelines to comply with the requirements of lighting facilities of Canon Mexicana, S. de R.L. de C.V., areas of workplaces, so that it has the amount of lighting required for each visual activity, in order to provide a safe and healthy environment in carrying out the tasks that workers develop.

II. Definitions.

For purposes of this policy, the following definitions should be considered:

Brightness: it is the luminous intensity showing a surface in a direction given, per unit area.

Critical condition of lighting: deficiency of lighting on the site work or very high levels that may require an additional visual worker effort or cause glare.

Dazzling: it is any brightness is discomfort that causes interference to the vision or visual fatigue.

Complementary lighting: is that provided by additional lighting to the considered in general lighting, to increase the light level in a given area or work surface.

MADE BY :	REVIEWED BY:	AUTHORIZED BY:
JORGE FLORES GENERAL AFFAIRS DATE: 30/05/18	SAMUEL MAQUEDA SUPERVISOR DATE: 30/05/18	CAROLINA MEJIA SENIOR DIRECTOR DATE: 30/05/18

Special lighting: is the amount of required specific light for activity that in accordance with the nature of the obligation has one high visual demands greater than 1000 Lux or less than 100 Lux, for the operating speed of the eye (size, distance and colors of the visual task) and the accuracy with which the activity takes place.

It is the knowledge of the company, which develops no activities of any area under special lighting conditions.

Lighting; luminance: is the ratio of luminous flux incident on a surface per unit area, expressed in Lux.

Localized lighting: is that provided by a lighting designed only to provide illumination on a work surface.

Luminaries; fixture: lighting equipment that distributes, filters or controls the light emitted by a lamp or lamps, that includes all the accessories necessary to secure, protect and operate these lamps, and those necessary to connect to the circuit of electrical use.

Light meter; Luminance meter: is an instrument designed and used to measure levels of lighting or illumination, in Lux.

Light level: quantity of luminous flux per unit area measured at a work surface where, activities expressed in Lux.

Lighting system: is the set of luminaries of an area or level of work, distributed in such a way that they provide a specific level of lighting for the activities.

III. obligations of Canon Mexicana.

In compliance with the applicable legal provisions, the Company undertakes to:

(a) have the levels of lighting in work areas or the Visual tasks according to the levels designated by the Ministry of labor and Social Welfare.

(b) carry out the recognition of the lighting conditions of the areas and jobs, at least once a year, with the report on results of the evaluation of the levels of lighting areas, activities or jobs.

(c) make the assessment of the levels of lighting every time you change the physical condition of the facilities.

(d) inform all workers about the risks that may cause a glare or a deficient level of lighting in their areas or jobs.

In fulfillment of the obligation contained in this paragraph, the company expressly instructs workers use systems lighting have been arranged and evaluated by the company, as well as to report any failure for immediate correction.

The luminaries will be activated by the security guard to be lit before the entry of workers and will be switched off until the retirement of the last employee of the facilities.

There is no activity within the undertaking that involves risk of glare toward workers. However, informs workers that any glare can be detrimental to your visual health, so it tells them to report any circumstances deemed risky by this concept.
(e) develop and implement a maintenance program for workplace lighting, including emergency lighting systems.

(f) installed electric lighting of emergency systems, in those areas of the workplace where the interruption of artificial light source represent a risk in the visual task of the job, or in areas considered as evacuation route that require it.

Obligations of workers.

(a) inform the company about any conditions unsafe, derived from the lighting conditions in your area or job, to arise.

(b) use lighting systems according to the instructions which have been provided by the Department of General Services, human resources or your top immediate boss.

(c) cooperate in assessments of the areas or job levels and observe the control measures implemented by the company.

Recognition of the lighting conditions.

In order to ensure optimum lighting conditions, the Department of General Services will be responsible for identifying those areas of the workplace and the Visual tasks associated with the jobs, in addition, identify those where there is a risk of poor lighting or excessive lighting that causes glare.

For this, on a monthly basis will be a journey through all areas of the workplace where workers perform their Visual tasks, and consider, where appropriate, the reports of workers, as well as to collect technical information.

In these travels, must be addressed:

(a) distribution of the areas of work, (number and distribution of lighting fixtures), lighting, machinery and work equipment;
(b) power of the lamps;
(c) description of the illuminated area: colors and surfaces of the premises or building type;
(d) description of Visual tasks and work areas;
(e) description of the jobs that require localized lighting, and
(f) information on the perception of the lighting by the worker conditions.

Maintenance.-

In the maintenance of the luminaries, the General Services Department should take into account the following:
(a) the cleaning of the luminaries;
(b) the ventilation of the luminaries;
(c) the replacement of the luminaries when they stop working, or after expiry of the default number of hours of operation established by the manufacturer;
(d) fluorescent lamp ballasts or heating elements.