STRUCTURAL CALCULATION REPORT

Project Reference: 2024-04- SE4 1ES

02 Towerfields Westerham Road
Bromley,BR2 6HF
Email: info@Pearlepp.co.uk
Website: www.pearlepp.co.uk

Document Control:

Purpose/Status	Date	Rev.	Comments	Structural Engineer
Approval Issue	01-04-2024	00	B'Regs Issue	MM

Disclaimer

This document has been prepared in accordance with the scope of **PEPP's** appointment with its client and is subject to the terms of that appointment. It is confidential, addressed to and for the sole use and reliance of **PEPP's** client. **PEPP's** accepts no liability for any use of this document other than by its client and only for the purposes stated in the document, for which it was prepared and provided. No person other than the client may copy (in whole or in part), use or rely on the contents of this document, without the prior written permission of a director of **PEPP's**. Any advice, opinions or recommendations within this document should be read and relied upon only in the context of the document. The contents of this document are not to be construed as providing legal, business or any advice or opinion.

PROJECT INFORMATION

Design Codes – Eurocodes and their respective National Annexes:

Design Codes	Eurocodes	National Annexes
BS EN 1990	Eurocode 0	'Basis of structural design'
BS EN 1991	Eurocode 1	'Actions on structures'
BS EN 1992	Eurocode 2	'Design of concrete structures'
BS EN 1993	Eurocode 3	'Design of steel structures'
BS EN 1995	Eurocode 4	'Design of timber structures'
BS EN 1996	Eurocode 6	'Design of masonry structures'
BS EN 1997	Eurocode 7	'Geotechnical Design'

PEPP PEARL ENGINEERS, PLANNERS & PROJECT MANAGERS 02 Towerfields Westerham Road Bromley,BR2 6HF Email: info@Pearlepp.co.uk Website: www.pearlepp.co.uk	**Project:**		**Sheet No./Rev.** 4
	Job Ref. 2024-04- SE4 1ES	**Structural Engineer** MM	**Date** 01-04-2024

1. LOADING DETAILS

The following loading is generally considered in the design of the structural elements.

PITCHED ROOF PERMANENT ACTIONS

Tiles w_{Gtiles} **= 0.55 kN/m^2**

Rafters, Battens and Felt $w_{Grafters}$ **= 0.15 kN/m^2**

Insulation w_{Ginsul} **= 0.10 kN/m^2**

Plasterboard & Skim $w_{Gplaster}$ **= 0.20 kN/m^2**

Total pitched roof permanent action = 1.00 kN/m^2

PITCHED ROOF VARIABLE ACTIONS

Pitched roof variable action $w_{Qsnow\ pitch}$ **= 0.60 kN/m^2**

FLAT ROOF PERMANENT ACTIONS

Chipping's and Bitumen w_{Gchip} **= 0.20 kN/m^2**

Three Layers Felt w_{Gfelt} **= 0.10 kN/m^2**

Boarding & Joists $w_{Gjoists}$ **= 0.30 kN/m^2**

Insulation w_{Ginsul} **= 0.10 kN/m^2**

Plasterboard & Skim $w_{Gplaster}$ **= 0.20 kN/m^2**

Total flat roof permanent action $w_{Gflatroof} = (w_{Gchip} + w_{Gfelt} + w_{Gjoists} + w_{Ginsul} + w_{Gplaster}) =$ **0.90 kN/m^2**

FLAT ROOF VARIABLE ACTIONS

Flat roof variable action $w_{Qsnow\ flat}$ **= 0.75 kN/m^2**

CEILING PERMANENT ACTIONS

Boarding & Joists $w_{Gjoists}$ **= 0.30 kN/m^2**

Insulation w_{Ginsul} **= 0.10 kN/m^2**

Plasterboard & Skim $w_{Gplaster}$ **= 0.20 kN/m^2**

CEILING VARIABLE ACTIONS

Ceiling variable action $w_{Qceiling} = 0.25\ kN/m^2$

FLOORS PERMANENT ACTIONS

Boarding & Joists $w_{Gjoists} = 0.30\ kN/m^2$

Plasterboard & Skim $w_{Gplaster} = 0.20\ kN/m^2$

Total floor permanent action $w_{Gfloor} = (w_{Gjoists} + w_{Gplaster} + w) = 0.7$[illegible] kN/m^2

FLOOR VARIABLE ACTIONS

Floor variable action $w_{Qfloor} = 1.50\ kN/m^2$

STUDWORK PARTITIONS

Studs and Noggins $w_{Gstud} = 0.10\ kN/m^2$

Insulation $w_{Ginsul} = 0.$[illegible]$0\ kN/m^2$

Plasterboard & Skim $w_{Gplaster} = 0.20\ kN/m^2$

Total $w_{Gpartitions} = (w_{Gstud} + w_{Ginsul} + w_{Gplaster}) = 0.40\ kN/m^2$

BLOCKWORK PARTITIONS

100mm blockwork $w_{Gblock} = 2.20\ kN/m^2$

Plasterboard & Skim $w_{Gplaster} = 0.20\ kN/m^2$

100mm BRICK WALL

100 Bricks $w_{Gbrick100} = 2.15\ kN/m^2$

Plasterboard & Skim $w_{Gplaster} = 0.20\ kN/m^2$

215mm BRICK WALL

215 Bricks $w_{Gbrick215} = 4.30\ kN/m^2$

Render & Skim $w_{Grender} = 0.70\ kN/m^2$

CAVITY WALL

102 Brick + 140 Block $w_{Gblock} + w_{Gbrick100} = 4.35\ kN/m^2$

Insulation $w_{Ginsul} = 0.10\ kN/m^2$

Plasterboard & Skim $w_{Gplaster} = 0.20\ kN/m^2$

GLASS

15mm thick toughened laminated $w_{Gglass} = 0.38\ kN/m^2$

2. STEEL DESIGN

2.1 Beam B1 (UB 203x102x23 S355)

Permanent

Wall Load =5kN/m² x 2.7m = ***13.5kN/m***

Floor Load =0.75kN/m² x 7.3m/2 = ***2.7kN/m***

Roof Load =1kN/m² x 7.3m/2 = ***3.6kN/m***

Total Permanent = 13.5+2.7+3.6 = ***19.8kN/m***

Variable

Floor Load =1.5kN/m² x 7.3m/2 = ***5.5kN/m***

Roof Load =0.6kN/m² x 7.3m/2 = ***2.2kN/m***

Total Variable= 2.2+5.5 = ***7.7kN/m***

STEEL BEAM ANALYSIS & DESIGN (EN1993-1-1:2005)

In accordance with EN1993-1-1:2005 incorporating Corrigenda February 2006 and April 2009 and the UK national annex

TEDDS calculation version 3.0.13







Support conditions

Support A Vertically restrained

	Rotationally free	
Support B	Vertically restrained	
	Rotationally free	

Applied loading

Beam loads	Permanent self weight of beam × 1	
	Permanent full UDL 19.8 kN/m	
	Variable full UDL 7.7 kN/m	

Load combinations

Load combination 1	Support A	Permanent × 1.35
		Variable × 1.50
		Permanent × 1.35
		Variable × 1.50
	Support B	Permanent × 1.35
		Variable × 1.50

Analysis results

Maximum moment;	M_{max} = **35[illegible]** kNm;	M_{min} = **0** kNm
Maximum shear;	V_{max} = **52.1** kN;	V_{min} = **-52.1** kN
Deflection;	δ_{max} = **4.3** mm;	δ_{min} = **0** mm
Maximum reaction at support A;	R_{A_max} = **52.1** kN;	R_{A_min} = **52.1** kN
Unfactored permanent load reaction at support A;	$R_{A\_Permanent}$ = **27** kN	
Unfactored variable load reaction at support A;	$R_{A\_Variable}$ = **10.4** kN	
Maximum reaction at support B;	R_{B_max} = **52.1** kN;	R_{B_min} = **52.1** kN
Unfactored permanent load reaction at support B;	$R_{B\_Permanent}$ = **27** kN	
Unfactored variable load reaction at support B;	$R_{B\_Variable}$ = **10.4** kN	

Section details

Section type;	**UB 203x102x23 (BS4-1)**
Steel grade;	**S355**

EN 10025-2:2004 - Hot rolled products of structural steels

Nominal thickness of element;	t = max(t_f, t_w) = **9.3** mm
Nominal yield strength;	f_y = **355** N/mm^2
Nominal ultimate tensile strength;	f_u = **470** N/mm^2
Modulus of elasticity;	E = **210000** N/mm^2

PEPP PEARL ENGINEERS, PLANNERS & PROJECT MANAGERS	**Project:**		**Sheet No./Rev.** 9
02 Towerfields Westerham Road Bromley,BR2 6HF Email: info@Pearlepp.co.uk Website: www.pearlepp.co.uk	**Job Ref.** 2024-04- SE4 1ES	**Structural Engineer** MM	**Date** 01-04-2024



Partial factors - Section 6.1

Resistance of cross-sections; γ_{M0} = **1.00**

Resistance of members to instability; γ_{M1} = **1.00**

Resistance of tensile members to fracture; γ_{M2} = **1.10**

Lateral restraint

Span 1 has full lateral restraint

Effective length factors

Effective length factor in major axis; K_y = **1.000**

Effective length factor in minor axis; K_z = **1.000**

Effective length factor for torsion; $K_{LT.A}$ = **1.000**;

$K_{LT.B}$ = **1.000**;

Classification of cross sections - Section 5.5

$\varepsilon = \sqrt{[235 \text{ N/mm}^2 / f_y]}$ = **0.81**

Internal compression parts subject to bending - Table 5.2 (sheet 1 of 3)

Width of section; c = d = **169.4** mm

$c / t_w = 38.6 \times \varepsilon <= 72 \times \varepsilon$; Class 1

Outstand flanges - Table 5.2 (sheet 2 of 3)

Width of section; $c = (b - t_w - 2 \times r) / 2$ = **40.6** mm

$c / t_f = 5.4 \times \varepsilon <= 9 \times \varepsilon$; Class 1

Section is class 1

Check shear - Section 6.2.6

Height of web; $h_w = h - 2 \times t_f$ = **184.6** mm

Shear area factor; η = **1.000**

$h_w / t_w < 72 \times \varepsilon / \eta$

Shear buckling resistance can be ignored

Design shear force; $V_{Ed} = \max(\text{abs}(V_{max}), \text{abs}(V_{min}))$ = **52.1** kN

Shear area - cl 6.2.6(3); $A_v = \max(A - 2 \times b \times t_f + (t_w + 2 \times r) \times t_f, \eta \times h_w \times t_w)$ = **1238** mm^2

Design shear resistance - cl 6.2.6(2); $V_{c,Rd} = V_{pl,Rd} = A_v \times (f_y / \sqrt{[3]}) / \gamma_{M0}$ = **253.7** kN

PASS - Design shear resistance exceeds design shear force

Check bending moment major (y-y) axis - Section 6.2.5

Design bending moment; $M_{Ed} = \max(\text{abs}(M_{s1\_max}), \text{abs}(M_{s1\_min}))$ = **35.2** kNm

Design bending resistance moment - eq 6.13; $M_{c,Rd} = M_{pl,Rd} = W_{pl.y} \times f_y / \gamma_{M0}$ = **83.1** kNm

PASS - Design bending resistance moment exceeds design bending moment

Check vertical deflection - Section 7.2.1

Consider deflection due to permanent and variable loads

Limiting deflection; $\delta_{lim} = L_{s1} / 250$ = **10.8** mm

Maximum deflection span 1; $\delta = \max(\text{abs}(\delta_{max}), \text{abs}(\delta_{min}))$ = **4.[illegible]4** mm

PASS - Maximum deflection does not exceed deflection limit

3. PADSTONE DESIGN

3.1 Padstone PD1 (300(lg)x300(w)x220(dp) C40)

MASONRY BEARING DESIGN TO BS5628-1:2005

TEDDS calculation version 1.0.06

Masonry details

Masonry type; **Aggregate concrete blocks (25% or less formed voids)**

Compressive strength of unit; p_{unit} = **20.0** N/mm^2

Mortar designation; **iii**

Least horizontal dimension of masonry units; l_{unit} = **100** mm

Height of masonry units; h_{unit} = **215** mm

Category of masonry units; **Category II**

Category of construction control ; **Normal**

Partial safety factor for material strength; γ_m = **[illegible]5**

Thickness of load bearing leaf; t = **220** mm

Effective thickness of masonry wall; t_{ef} = **220** mm

Height of masonry wall; h = **2400** mm

Effective height of masonry wall; h_{ef} = **2400** mm



Bearing details

Beam spanning in plane of wall

Width of bearing; B = **100** mm

Length of bearing; l_b = **300** mm

Compressive strength from Table 2 BS5628:Part 1 - aggregate concrete blocks (25% or less formed voids)

Mortar designation; Mortar = **"iii"**

Block compressive strength; p_{unit} = **20.0** N/mm^2

Characteristic compressive strength (Table 2c); f_{kc} = **5.55** N/mm^2

Characteristic compressive strength (Table 2d); f_{kd} = **11.05** N/mm^2

Height of solid block; h_{unit} = **215.0** mm ;

Least horizontal dimension; l_{unit} = **100.0** mm

Block ratio; ratio = h_{unit} / l_{unit} = **2.2**

Ratio between 0.6 and 4.5 - OK

Characteristic compressive strength; f_k = **11.05** N/mm^2

Loading details

Characteristic concentrated dead load; G_k = **27** kN

Characteristic concentrated imposed load; Q_k = **10** kN

Design concentrated load; F = (G_k × 1.4) + (Q_k × 1.6) = **53.9** kN

Characteristic distributed dead load; g_k = **0.0** kN/m

Characteristic distributed imposed load; q_k = **0.0** kN/m

Design distributed load; f = (g_k × 1.4) + (q_k × 1.6) = **0.0** kN/m

Masonry bearing type

Bearing type; **Not applicable**

Bearing safety factor; γ_{bear} = **1.00**

Check design bearing without a spreader

Design bearing stress; f_{ca} = F / (B × l_b) + f / t = **1.798** N/mm^2

Allowable bearing stress; f_{cp} = γ_{bear} × f_k / γ_m = **3.157** N/mm^2

PASS - Allowable bearing stress exceeds design bearing stress

Check design bearing at 0.4 × h below the bearing level

Slenderness ratio; h_{ef} / t_{ef} = **10.91**

Eccentricity at top of wall; e_x = **0.0** mm

From BS5628:1 Table 7

Capacity reduction factor; β = **0.99**

Length of bearing distributed at 0.4 × h; l_d = **1260** mm

Maximum bearing stress; f_{ca} = F / (l_d × t) + f / t = **0.195** N/mm^2

Allowable bearing stress; f_{cp} = β × f_k / γ_m = **3.126** N/mm^2

PASS - Allowable bearing stress at 0.4 × h below bearing level exceeds design bearing stress