LOGO	Address	Doc Code
LOGO	Addiess	DOC COUE

Preventive Maintenance Checklist - EV Charger

Location of EV Station	Brand / Model	Date	S/N
EV Station - Central Branch	ACME 120kW	2025-10-16	SN-123456
Charger No. 2			

No.	Item	pass	fail	N/A	Remark
1	1) Inspect general condition	1			
2	2) Check duct seal / silicone	1			
3	3) Check charging cable	1			
4	4) Check connector head	1			
5	5) Check emergency stop button	1			
6	6) Check QR code	1			
7	7) Warning label: electric shock			✓	
8	8) Warning label: ventilation	1			
9	9) Warning label: emergency button	1			
10	10) Measure control circuit voltage	1			
11	11) Check air filter	1			
12	12) Check electrical terminals	1			
13	13) Check contactors	1			
14	14) Check surge protection device		1		SPD indicator red; replace soon
15	15) Measure CP pin voltage	1			CP 12.0 V
16	16) Check phase sequence	1			
18	18) Charging test	1			
19	19) Cleaning	1			

Comment :			

Measure (Item 17)		
Point	Value	Unit
L1-L2	401	V
L2-L3	399	V
L3-L1	400	V
L1-N	231	V
L2-N	230	V
L3-N	229	V
L1-G	0	V
L2-G	0	V
L3-G	0	V
N-G	0	V

Summary of Inspection :	All checks completed. One SPD issue observed; replacement scheduled.

Performed by	Approved by	Witnessed by
(Inspector) Date :	() Date :	() Date :