

Manufacturer : Flexx Fast Location : พื้นที่อาคาร 4
 Model : 150KW Power : 150KW Firmware Version : 220525.68
 Serial Number : 115178910 Inspection Date : 17/10/2025

Equipment Identification Details

1 Manufacturer : Correso Model : minifester Serial Number : 79850689
 2 Manufacturer : _____ Model : _____ Serial Number : _____

Testing Topics for Safety (Specifically Power Supply/Input Side)

Testing Checklist				Test Results (Record as Pass/Fail) or Numeric Results						Remark
				1st TEST		2nd TEST		3rd TEST		
Electrical Safety	PE.Continuity protective conductors of Charger	Left Cover		0.1	/	0.1	/			
		Right Cover		0.1	/	0.1	/			
		Front Cover		0.1	/	0.1	/			
		Back Cover		0.1	/	0.1	/			
		Pin PE H.1		0.1	/	0.1	/			
		Pin PE H.2		0.1	/	0.1	/			
	RCD type A	<input checked="" type="checkbox"/>	mA							
	RCD type F	<input checked="" type="checkbox"/>	mA							
	RCD type B	<input checked="" type="checkbox"/>	mA							
	Isolation Transformer		<input checked="" type="checkbox"/>							
Power stand by			L1 1.8 A		L2 0 A		L3 0 A			

CHARGING PROCESS TESTING


Testing Checklist		Test Results (Record as Pass/Fail) or Numeric Results						Remark
		1st TEST		2nd TEST		3rd TEST		
Charger Safety	CCS2	H.1	H.2	H.1	H.2	H.1	H.2	
	None (Normal operate)	/	/	/	/			
	CP short -120 Ohm	/	X	/	/		/	
	PE-PP-Cut	X	/	/	/	/		
	Remote Stop	/	/	/	/			
	Emergency	/	/	/	/			
	LDC +	/	/	/	/			
	LDC -	/	/	/	/			
	HDC+	/	-	-	-			
	HDC -	/	-	-	-			

Remark : บัตรความปลอดภัยผ่าน


Symbol : ☒ PASS, ☒ Not PASS ☐ N/A (Not TEST) Phase Sequence ☐ L1-L2-L3 ☐ L3-L2-L1

Responsibility	Tested	Confirmed	Witnessed
Name			
Signature			
Date			
Company			


Manufacturer	:	0	Location	:	0		
Model	:	0	Power :		Firmware Version	:	0
Serial Number	:	0	Inspection Date	:	0-Jan-00		




Nameplate




Charger



Circuit Breaker



RCD



GUN 1



GUN 2

Remark : _____

Responsibility	Tested	Confirmed	Witnessed
Name			
Signature			
Date			
Company			