R-412, 4th Floor, Karawan Tower (B),
Al-Bustan District, Al-Khobar, Saudi Arabia

ارامكو السعودية
saudi aramco

Document Transmittal

SAUDI ARAMCO	Contract No. 6600050503 (IK)
To: H. C, Kim CONTRACTOR Representative	

Transmittal No.	Response Transmittal No
SA-JUS&ICS-TR-IK-24-1118	JUS&ICS-HJ-SA-TR-24-1450

Document No.	Document Title	Rev.	Date
JUS&ICS-AR-FMAR-0066	FMAR for Waterproofing PVC Membrane (IFR, Rev.A1)	A1	18/Aug/24

Areas / Discipline					
☐ GENERAL	☐ QM	☐ PLANNING	☐ INTERFACE	☐ PIPING	☐ ELECTRICAL
☐ PROJECTS	☐ HSE	☐ CIVIL/STRUCT	☐ PROCUREMENT	☐ PROCESS	☐ INSTRUMENT
☐ SAFTY	☐ HVAC/PLUMB	☑ ARCHITECTUR	☐ MECHANICAL	☐ PIPELINE	☐ TELECOM
☐ COMM					

Comments :

Technically the membrane is approved. However, CONTRACTOR and Vendor/Manufacturer shall provide a Guarantee Statement or Guarantee Certificate.

The comments in this transmittal shall not relieve CONTRACTOR of its reponsibilities under the terms and condition of the Contract. It is CONTRACTOR's responsibility to make sure, and to ensure the compliance of its suppliers and subcontractors, that all quantities, dimensions, coordination, etc. adhere to all requirements set out in the Contract. CONTRACTOR may receive additional comments to this document.

☐ REVIEWED WITH NO COMMENT	☑ REVIEWED WITH COMMENT
☐ REJECTED	

FAA Bakhaider, Turki A
Company Representative

08/20/2024
Date

Signature

Attachment: Y

No of Pages: 1
(Including cover sheet)

SAUDI ARAMCO ISSUED 20 AUG 2024 No. JCP PKG3 (IK)

CONSORTIUM OF HEC & HDEC RECEIVED 2024. 08. 20 No. JCP PKG3 (IK)

HYUNDAI ENGINEERING CO. LTD. HYUNDAI ENGINEERING & CONSTRUCTION

JFGP 2 - Jafurah Utilities, Sulfur and Interconnecting Systems (Package 3)
Contract No. 6600050506 (OOK) & 6600050503 (IK)

ارامكو السعودية Saudi Aramco

FIELD MATERIAL APPROVAL REQUEST (FMAR)

FMAR No.	JUS&ICS-AR-FMAR-0066	Rev. A1	Date: Aug. 4, 2024

Order by : Subcontractor | **Non Engineered / Non Inspectable Items**

Proposed Material and Vendor Details :

No.	Description of Material	9COM.	Level of Inspection	Vendor	Manufacturer	Value Category (10,000 USD)
1	**Waterproofing PVC Membrane** (Insuwrap PVC 2000 FB-UV / WMR-UV, Polymat Roof UV-R)	**6000000562** (Membrane)	**N/A**	**Khabeer Al Raida Contracting Company. Vendor code: 10110264**	**1) Insulation and Wrapping products, KSA. Vendor ID:10012922** **2) Bitumat Company Limited, KSA. Vendor ID: 10012346**	**Over 10,000 USD**
2	**Adhesive** (Polymat Adhesive R8B4)	**6000000442** (Adhesive)	**N/A**		**Bitumat Company Limited, KSA. Vendor ID: 10012346**	
3	**Sealant** (Vetoflex PU780)	**6000000521** (Sealant)	**N/A**		**Saudi Vetonit Company, KSA. Vendor ID: 10013854**	

Spare Part N/A

Specification Requirement

SAES-Q-001

Location of Use (Site & Unit Details) : JFGP UTILITIES, SULFUR & INTERCONNECTING SYSTEMS PKG#3

Compliance with Specification (Yes/No) : YES

Attachments :

1. Aramco Approval Letter
2. Drawings
3. Technical Data Sheets

Notes / Comments :

SUBCONTRACTOR (If Applicable)

Name of Subcontractor: GUSAN CONSTRUCTION ARABIA COMPANY

Submitted By: MIN GI KIM Signature: M.G. Kim Date: Aug. 04, 2024

Subcontractor Representative Designation: PLANNING MANAGER

EPC CONTRACTOR

Prepared By: Dong Chol Chon Signature: Date: Aug. 04, 2024

Designation: Architectural Manager

Reviewed By: Sung Tae Kim Signature: Date: Aug. 05, 2024

Designation: Architectural Section Manager

Reviewed By: HC Kim Signature: Date: Aug. 05, 2024

Designation: Contractor's Representative

COMPANY (ARAMCO)

☐ Reviewed ■ Reviewed with Comments ☐ Reject

Comments:

1. Technically the membrane is approved. However, CONTRACTOR and Vendor/Manufacturer shall provide a Guarantee Statement or Guarantee Certificate. This is mandatory for roof waterproofing material and application. The guarantee shall not ONLY to the supplied material but also the application at site.

Signature: Sary A. Alghamdy Name: Alghamdy, Sary Designation: Project Engineer Date: 18 Aug 24

Signature: Name: Bakhaider, Turki A Designation: COMPANY Representative Date: 08/20/2024