

Hylan Datacom & Electrical

Daily Work Report - Pole Work

Mobilitie ☐ Extenet ☐ Crown Castle ☒

Date: 8-29-17

Node #

CRAN-RNYS-00001-42

Job#

120-0004

Manpower Information

Name: Howard Olshewitz	Reg: 2	OT: 318
Name: Chris Dropp	Reg: 2	OT: 167
Name:	Reg:	OT: 291
Name:	Reg:	OT: 109

Description of Work	Qty	Total
REMOVE AND DISPOSE EXISTING POLE (ALL POLE TYPES).		
FURNISH AND INSTALL TYPE 'M' POLE		
REMOVE AND RE-INSTALL TYPE M POLE		
REMOVE AND REINSTALL TYPE OCTOGONAL POLE		
CONSTRUCT FS TYPE FOUNDATION		
CONSTRUCT SPIDER FOUNDATION		
TEMP OUT TRAFFIC SVCS. UP TO 10LF - \$650.00 *OVER 10LF WILL BE \$97.50 EA. LF*		
TEMP PYLON		
REMOVE AND REINSTALL SIGNS ON POLE EA. (Up to 3)		
REMOVE AND DISPOSE DUSKY LIGHT EA		
FURNISH & INSTALL OCTOGONAL POLE		
REPLACE BASE (FS)		
REPLACE BASE (M2)		
FURNISH AND INSTALL 8' ARM AND LUMINAIRE		
F & I (2) RUNS PER NYC DOT 13C/314 TRAFFIC CABLE / PER FOOT		
F & I (2) #10 & (1) #8 GROUND TRAFFIC FEED CABLE / PER FOOT		
GROUND 2" PIPE STUBS IN POLE BASE EA.		
SPLICE FEED EA.		
TAP & FUSE		
FURNISH AND INSTALL POWER CABLE (2) #14 IMSA / PER LF		
REMOVE & REPLACE FLOODLIGHT		
TRANSFER EXISTING ARM & LUMINAIRE		
REPLACE CONTROLLER		
FIX EXISTING DOOR		
FURNISH & INSTALL FIRE ALARM PHOTO ELECTRIC CELL		
PAINT POLE, ARM, AND BASE EA		
INSTALL 5' M-2A MAST ARM EXTENSION ASSEMBLY WITH FITTINGS		
FLAGMEN PER DAY *\$25.00 PER HOUR		
GFI RECEPTACLE INSTALL		
POWER AT LOCATION		

Job Location:

Little West St + Battery Pl

Description of Work:

we checked the Radium Box + Base of Pole. N/A - The 24HR Log Dead. Checked Surrounding area for Panel. We found panel. Waited for the Building electrician to open it. Blown fuse causing outage. Building ordered more waiting to be delivered.