

ATTACHMENT A – LIMITATIONS AND MONITORING REQUIREMENTS

Permit Number: WQ0004332

Version: 4.1

PPI 002 – WWTF Effluent

EFFLUENT CHARACTERISTICS		EFFLUENT LIMITS					MONITORING REQUIREMENTS	
PCS Code	Parameter Description	Units of Measure	Monthly Average	Monthly Geometric Mean	Daily Minimum	Daily Maximum	Measurement Frequency	Sample Type
00310	BOD, 5-Day (20 °C)	mg/L					Monthly ¹	Grab
00940	Chloride (as Cl)	mg/L					3 x Year ²	Grab
50060	Chlorine, Total Residual	mg/L					Weekly	Grab
31616	Coliform, Fecal MF, M-FC Broth, 44.5 °C	#/100 mL					Monthly ¹	Grab
50050	Flow, in Conduit or thru Treatment Plant	GPD	1,076,000				Continuous	Recorder
00610	Nitrogen, Ammonia Total (as N)	mg/L					Monthly ¹	Grab
00625	Nitrogen, Kjeldahl, Total (as N)	mg/L					Monthly ¹	Grab
00620	Nitrogen, Nitrate Total (as N)	mg/L					Monthly ¹	Grab
00600	Nitrogen, Total (as N)	mg/L					Monthly ¹	Grab
00400	pH	su					Weekly	Grab
00665	Phosphorus, Total (as P)	mg/L					Monthly ¹	Grab
70300	Solids, Total Dissolved – 180 °C	mg/L					3 x Year ²	Grab
00530	Solids, Total Suspended	mg/L					Monthly ¹	Grab

1. Based on historical data, the monitoring frequencies were reduced from 2 x Month to Monthly in the August 28, 2014 permit issuance.
2. 3 x Year sampling shall be conducted in April, August, and November.