Monthly breakdown report, September 2026

Acme Lifts lift service · compared with August 2026 and Sep 2025 · data pulled 22 Oct 2026 08:00 (synthetic demo data)

At a glance

Measure	Sep 2026	Aug 2026	Sep 2025
Callbacks	285	290	263
Actual breakdowns	167	195	167
Mantraps	32	30	40
Mantraps attended over 40 min	9	8	8
Non-mantrap calls attended over 40 min	106	110	89
Repeat breakdowns within 7 days	6	12	6
PM done	97.7%	96.9%	95.1%
Units with more than 2 actual breakdowns, FY2026 to date	267	242	257
Backlog not yet processed	598	–	–
Matched to CallDesk	93.7%	91.4%	93.9%

Do these first

1. Technical review of the 5 units with most breakdowns this month: U20188 (Maple Mall, ×2), U20271 (Summit Campus, ×2), U21507 (Kingsway Mall 2, ×2), U20795 (Harbour Office Park, ×2), U20983 (Lakeside Mall, ×2).
2. Priority fix and sign-off by a senior technician on repeat-mantrap units: U20258 (Silverleaf Hotel, 2 in 90 days), U20481 (Redwood Plaza, 2 in 90 days), U20862 (Bayview Medical Centre, 2 in 90 days), U20876 (Summit Office Park, 2 in 90 days), U21076 (Bayview Medical Centre 3, 2 in 90 days).
3. Mantraps over 40 min: 9 this month. Go through each late mantrap with the Central Riverside Z3 supervisor (3 late); check where the nearest engineer was when the call came in.
4. Joint inspection with the client at Bayview Medical Centre 2 (7 callbacks on 6 units, 5 actual).
5. Site-level plan (survey, modernisation quote or extra visits) for Maple Mall (8 units over 2).
6. Reschedule the 39 missed visits in the first week of next month, starting with North Harbour Z1.

Basis: FY = Oct-Sep; months by ERP Created date. Actual vs non-actual by fault code (non-actual = MISUSE, ROA, FIN, E13, E14); callbacks not yet processed are typed from their remarks (predicted). Attend = CallDesk Ack to At-site, matched callbacks only; target 40 min mantrap, 40 min non-mantrap (provisional); mantrap response over 1 day left out as a likely wrong match. Repeat = actual breakdown within 7 days of the previous actual on the same unit; the engineer named is the one on the earlier job. After hours = call time outside Mon-Fri 08:00-18:00 (CallDesk ticket time). Why lines show what the data shows; they do not prove cause.

1. Callbacks

167 actual

285

WHAT

285 callbacks in September 2026, down 5 (2%) on August and up 22 (8%) on Sep 2025.

WHY

- Split: 167 actual (down 28 (14%) on August), 110 non-actual (up 17 (18%) on August), 8 not yet typed.
- Zones with the biggest rise on August: South Airport Z7 5→12, South Coastal Z6 21→22.
- Biggest falls: Central Old Town Z4 31→26, North Uptown Z2 47→42, Central Business Park Z5 13→11.
- Top 5 sites gave 28 callbacks (10% of the month): Bayview Medical Centre 2 7 (6 units); Pinecrest Station 2 7 (6 units); Cedar Station 5 (4 units); Bayview Residences 2 5 (3 units); Cedar Medical Centre 4 (4 units).

WHAT NOW

- Joint inspection with the client at Bayview Medical Centre 2 (7 callbacks on 6 units, 5 actual).
- Joint inspection with the client at Pinecrest Station 2 (7 callbacks on 6 units, 4 actual).

2. Actual breakdowns

59% of callbacks

167

WHAT

167 actual breakdowns, down 28 (14%) on August and same as Sep 2025. Actual share 59% (67% in August).

WHY

- Fault groups that rose most on August: MOTOR / CAR 10→12.
- Groups that fell: DOOR 92→74, ESC 46→35, CONTROLLER 47→46.
- Most common faults: D01 Car door operator ×27; D02 Landing door lock ×21; D03 Door safety edge / sensor ×18; C02 Inverter / drive trip ×13.
- 12 units broke down 2 or more times in the month and gave 24 of the 167 actual breakdowns (14%).
- Sites with most actual breakdowns: Bayview Medical Centre 2 5 on 5 units; Cedar Medical Centre 4 on 4 units; Cedar Station 4 on 4 units.
- 17 of the 167 are not yet processed, so their type comes from the remarks (predicted).

WHAT NOW

- Technical review of the 5 units with most breakdowns this month: U20188 (Maple Mall, ×2), U20271 (Summit Campus, ×2), U21507 (Kingsway Mall 2, ×2), U20795 (Harbour Office Park, ×2), U20983 (Lakeside Mall, ×2).
- Check the fix method for D01 Car door operator: 27 cases on 27 units.

3. Mantraps

32 units

32

WHAT

32 mantraps, up 2 (7%) on August and down 8 (20%) on Sep 2025.

WHY

- Fault groups behind the mantraps: DOOR 13, CONTROLLER 10, MISUSE 6, ROA 2.
- Zones up most on August: Central Riverside Z3 6→8, North Harbour Z1 10→12, South Airport Z7 0→2.
- Sites with most mantraps: Bayview Medical Centre 2, Harbour Office Park 2, Bayview Medical Centre 3 1.
- 0 units had 2 or more mantraps this month; 7 of this month's mantrap units had 2 or more in the last 90 days.

WHAT NOW

- Priority fix and sign-off by a senior technician on repeat-mantrap units: U20258 (Silverleaf Hotel, 2 in 90 days), U20481 (Redwood Plaza, 2 in 90 days), U20862 (Bayview Medical Centre, 2 in 90 days), U20876 (Summit Office Park, 2 in 90 days), U21076 (Bayview Medical Centre 3, 2 in 90 days).
- 6 mantraps were misuse: send the list to building management at Ashford Plaza, Bayview Medical Centre.
- DOOR was the main real fault behind mantraps (13): check it on those 13 units at next PM.

4. Mantraps attended over 40 min

of 31 measured · median 29.4 min

9

WHAT

9 of 31 measured mantraps (29.0%) were attended over 40 min, up 1 (12%) on August and up 1 (12%) on Sep 2025. Median attend 29.4 min (27.2 in August).

WHY

- 31 of 32 mantraps have a CallDesk attend time; 1 are unmatched or missing At-site and are not counted.
- 5 of the 9 late ones were called in after hours or at weekends (outside Mon-Fri 08:00-18:00).
- Late by zone: Central Riverside Z3 3, North Harbour Z1 3, North Uptown Z2 2.
- Engineers with 2 or more late mantraps: Casey Moss 2, Remy Grove 2.
- Slowest: Cedar Office Park 3 88 min; Harbour Mall 86 min; Kingsway Apartments 2 83 min.

WHAT NOW

- Go through each late mantrap with the Central Riverside Z3 supervisor (3 late); check where the nearest engineer was when the call came in.
- Most late mantraps were after hours: check the standby roster covers those zones (inferred).
- Get CallDesk ticket numbers onto the 1 unmatched mantraps so their attend time counts.

5. Non-mantrap calls attended over 40 min

of 236 measured · provisional target

106

WHAT

106 of 236 measured non-mantrap callbacks (44.9%) took over 40 min, down 1.5 pts on August and up 2.9 pts on Sep 2025. Median 37.2 min (38.0 in August).

WHY

- Late by zone (share of that zone's measured calls): North Harbour Z1 35 (38%), North Uptown Z2 16 (43%), Central Riverside Z3 14 (45%).
- 50 of 106 late calls came in after hours or at weekends.

WHAT NOW

- Target is provisional: confirm whether 40 min is right for non-mantrap calls before chasing these.
- South Coastal Z6 was late on 65% of calls: check engineer coverage and travel distance there before setting its target (inferred).

6. Repeat breakdowns within 7 days

4% of actual

6

WHAT

6 actual breakdowns came within 7 days of the last one on the same unit, down 6 (50%) on August and same as Sep 2025.

WHY

- 3 of the 6 repeats had the same fault code as the visit before, so the first fix did not hold.
- They were on 6 units; most at Harbour Office Park 1, Harbour Tower 2 1, Kingsway Mall 2 1.
- Faults that came back most: D03 Door safety edge / sensor ×1, E02 Handrail drive ×1, E03 Comb plate safety ×1.

WHAT NOW

- Supervisor to check the repeat jobs with the same fault code: was the part replaced or only reset?

7. PM done

39 missed of 1,689 due

97.7%

WHAT

PM done 97.7% of due, up 0.8 pts on August and up 2.6 pts on Sep 2025.

WHY

- 39 PM visits due were not done. Most misses: North Harbour Z1 14 (2% of due), East Hillside Z8 7 (6% of due), North Uptown Z2 5 (2% of due).
- Engineers with most missed PM: Hayden Shaw 6, Rowan Pike 3, Sasha Vale 3.
- 1 of this month's 167 actual breakdowns were on units whose PM was missed this month. (FY analysis in analysis\worst_lifts.py found missed PM is not the main cause of repeat breakdowns.)

WHAT NOW

- Reschedule the 39 missed visits in the first week of next month, starting with North Harbour Z1.

8. Units with more than 2 actual breakdowns, FY2026 to date

of 1,821 units (14.7%)

267

WHAT

267 units, up 25 (10%) on end of August and up 10 (4%) on the same point of FY2025.

WHY

- 25 units crossed the line this month.
- They cluster: 21 sites have 3 or more such units (85 units in all), led by Maple Mall 8, Bayview Medical Centre 5 7, Pinecrest Station 2 6.
- 7% of these units' breakdowns this FY came within 7 days of the previous one (fixes not holding); missed PM is not the main driver (analysis\worst_lifts.py).

WHAT NOW

- Site-level plan (survey, modernisation quote or extra visits) for Maple Mall (8 units over 2).
- Add this month's new entries to the worst-lift list: U20271 (Summit Campus), U20723 (Granite Medical Centre), U20191 (Juniper Plaza 2), U20487 (Beacon Residences), U20340 (Northgate Mall).

9. Backlog not yet processed

as at 22 Oct 08:00

598

WHAT

598 callbacks (all years) are Open, Approved or Rejected at the last data pull. Snapshot only, so no month-on-month comparison yet.

WHY

- 32 of them were created in September 2026 (11% of the month not yet processed).
- 410 are over 90 days old; most in North Harbour Z1 150, North Uptown Z2 74, Central Riverside Z3 50.
- 464 were rejected and sent back for rework; most in North Harbour Z1 170, North Uptown Z2 79, Central Riverside Z3 58.

WHAT NOW

- Each zone clears its callbacks over 90 days, starting with North Harbour Z1.
- Fix and resubmit the 464 rejected callbacks: until processed they have no fault code, so actual vs non-actual for them is a prediction.

10. Matched to CallDesk

18 unmatched

93.7%

WHAT

93.7% of callbacks matched to a CallDesk ticket, up 2.3 pts on August and down 0.2 pts on Sep 2025.

WHY

- 18 callbacks were not matched; 4 of them have no CallDesk ticket number in ERP, 1 are mantraps.
- Most unmatched: North Harbour Z1 7 of 109, Central Riverside Z3 3 of 42, East Hillside Z8 3 of 21.

WHAT NOW

- Key the CallDesk ticket number on every callback in ERP, so it can be matched.