

## MICRO ONGRID INVERTER

### Technical Data Sheet

|                                             |                            |                   |
|---------------------------------------------|----------------------------|-------------------|
| <b>CAPACITY (KW)</b>                        | 0.6                        | 1.0               |
| <b>MODEL NO.</b>                            | VS-MI-061S                 | VS-MI-102S        |
| <b>PV String Input Data</b>                 |                            |                   |
| Max. PV Input Power (W)                     | 210-700(1 Piece)           | 210-700(2 Pieces) |
| Max. PV Input Voltage (V)                   | 60                         |                   |
| Start-up Voltage (V)                        | 20                         |                   |
| MPPT Voltage Range (V)                      | 25-55                      |                   |
| Rated PV Input Voltage (V)                  | 42.5                       |                   |
| Max. Operating PV Input Current (A)         | 18                         | 18+18             |
| Max. Input Short Circuit Current (A)        | 27                         | 27+27             |
| No. of MPP Trackers                         | 1                          | 2                 |
| No. of Strings MPP Tracker                  | 1                          |                   |
| <b>AC Output Side</b>                       |                            |                   |
| Rated AC Output Active Power (W)            | 600                        | 1000              |
| Max. AC Output Apparent Power (VA)          | 600                        | 1000              |
| Max. AC Output Current (A)                  | 2.2                        | 4.4               |
| Rated Output Voltage/Range (V)              | 230 / 0.85Un-1.1Un         |                   |
| Grid Connection Form                        | L/N/PE                     |                   |
| Rated Output Grid Frequency/Range(Hz)       | 50/45-55, 60/55-65         |                   |
| Max. Unit per Branch                        | 10                         | 5                 |
| Power Factor Adjustment Range               | 0.8 leading to 0.8 lagging |                   |
| Total Current Harmonic Distortion THDi      | <3%                        |                   |
| DC Injection Current                        | <0.5%In                    |                   |
| <b>Efficiency</b>                           |                            |                   |
| Max. Efficiency                             | 96.5%                      |                   |
| Euro Efficiency                             | 96.0%                      |                   |
| MPPT Efficiency                             | >99%                       |                   |
| <b>Equipment Protection</b>                 |                            |                   |
| DC Polarity Reverse Connection Protection   | Yes                        |                   |
| AC Output Overcurrent Protection            | Yes                        |                   |
| AC Output Overvoltage Protection            | Yes                        |                   |
| AC Output Short Circuit Protection          | Yes                        |                   |
| Thermal Protection                          | Yes                        |                   |
| DC Terminal Insulation Impedance Monitoring | Yes                        |                   |
| Power Network Monitoring                    | Yes                        |                   |
| Island Protection Monitoring                | Yes                        |                   |
| Earth Fault Detection                       | Yes                        |                   |
| Overvoltage Load Drop Protection            | Yes                        |                   |
| <b>General Data</b>                         |                            |                   |
| Operating Temperature Range (°C)            | (-40°C~65°C)               |                   |
| Permissible Ambient Humidity                | 0-100%                     |                   |
| Permissible Altitude (m)                    | 2000m                      |                   |
| Noise (dB)                                  | ≤25                        |                   |
| Ingress Protection(IP) Rating               | IP 67                      |                   |
| Inverter Topology                           | Isolated                   |                   |
| Over Voltage Category                       | OVC II(DC), OVC III(AC)    |                   |
| Communication                               | Wi-Fi                      |                   |
| Dimensions (W*H*D) mm                       | 249Wx147Hx38.8D            | 280.5Wx190Hx40D   |
| Weight (kg)                                 | 1.85                       | 3.0               |
| Warranty                                    | 10 Years                   |                   |
| Type of Cooling                             | Natural Cooling            |                   |



Our Ref: REGISTRATION/CRS 2022-5213/R-72007480 Date:15-10-2025

**Inclusion Id: 96577**

**Subject :Inclusion of Additional Model(s)**

|                      |                                                                                                                                                                   |                                                                                     |
|----------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|
| MANUFACTURING UNIT : | VSOLE SOLAR ENERGY PRIVATE LIMITED<br>PLOT NO-2, ANTHEM PARK-1, CANAL ROAD, KOSMADA, SURAT, GUJARAT<br>GUJARAT,India-395013<br>info@vssolesolar.com<br>9638136353 |  |
|----------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|

Dear Sir,

1. This has reference to your request for inclusion of models of "**Utility-Interconnected Photovoltaic Inverters**" as per **IS 16221 (Part 2) : 2015 / IEC 62109-2 : 2011,IS 17980: 2022/ IEC 62891:2020,IS 16169: 2019/IEC 62116: 2014 in Licence No. R-72007480** already granted to you which is valid upto 05-12-2026.
2. It is intimated that the additional Models as per details given below have been agreed to be included in your scope of Licence. **R-72007480 w.e.f. 15-10-2025:**

|                                                    |                                                                                                                                                                                                                                                                                 |
|----------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Product Category                                   | Utility-Interconnected Photovoltaic Inverters                                                                                                                                                                                                                                   |
| Product Name                                       | Utility-Interconnected Photovoltaic Inverters                                                                                                                                                                                                                                   |
| IS No.                                             | IS 16221 (Part 2) : 2015 / IEC 62109-2 : 2011,IS 17980: 2022/ IEC 62891:2020,IS 16169: 2019/IEC 62116: 2014                                                                                                                                                                     |
| Brand (As Declared by Manufacturer):               | VSOLE,VSOLE                                                                                                                                                                                                                                                                     |
| Inclusion of Additional Models (w.e.f. 15-10-2025) | [Brand -> VSOLE, Models -> VS-MI-051S, VS-MI-061S, VS-MI-102S, VS-MI-122S, VS-MI-142S, VS-MI-164S, VS-MI-184S, VS-MI-204S, VS-MI-224S], [Brand -> VSOLE , Models -> VS-MI-051S, VS-MI-061S, VS-MI-102S, VS-MI-122S, VS-MI-142S, VS-MI-164S, VS-MI-184S, VS-MI-204S, VS-MI-224S] |
| Factory Address                                    | PLOT NO-2, ANTHEM PARK-1, CANAL ROAD, KOSMADA, SURAT, GUJARAT<br>GUJARAT,India-395013                                                                                                                                                                                           |

3. Other terms and conditions of the licence shall remain same.
4. This letter is being issued with the approval of competent authority.

Kindly acknowledge receipt of this letter.

Thanking you,

Yours faithfully,  
(Aurosmita Kabiraj)  
Scientist D  
Telfax : +91-11-23230856  
E-mail: registration@bis.gov.in

Note: This is a system generated letter. Hence signature is not required.  
To verify authentication of letter, kindly scan the QR code on this letter.