

INDUSTRIAL ASSET TELEMETRY REPORT

Report ID: REP-775203

100% HEALTH (OPTIMAL)

Boiler Feed Pump Motor • Boiler House

Timeframe: 2026-09-24 10:35 to 2026-09-24 10:35 (UTC)

Signals Monitored

6

Threshold Breaches

0

Excursion Events

0

System Alerts

0

DIAGNOSTIC & ENGINEERING INSIGHTS

- Operating Health Score is evaluated at 100% (Optimal).
- Zero critical severity threshold events were triggered during this inspection interval.
- All monitored telemetry channels remained within manufacturer engineering boundaries.

TELEMETRY SIGNALS SUMMARY & STATISTICAL LIMITS

Signal / Channel	Unit	Safe Limits	Min	Max	Mean	Samples	Status
Winding_Temp_U	°C	10 - 130	80.1	80.1	80.1	1	NORMAL
Winding_Temp_V	°C	10 - 130	70.3	70.3	70.3	1	NORMAL
Winding_Temp_W	°C	10 - 130	84.0	84.0	84.0	1	NORMAL
Bearing_Temp_DE	°C	10 - 95	56.4	56.4	56.4	1	NORMAL
Bearing_Temp_NDE	°C	10 - 95	54.6	54.6	54.6	1	NORMAL
Ambient_Temp	°C	0 - 50	29.8	29.8	29.8	1	NORMAL

SIGNAL TREND OVERVIEW (UNAGGREGATED PROFILES)



RAW TELEMETRY READINGS LOG (UNAGGREGATED)

Chronological sequence of unaggregated sensor measurements. Each value is presented exactly as recorded in signal_data.

Signal: Winding_Temp_U (°C)

Operating Limits: [10.0 to 130.0] • Observed: Min 80.09, Max 80.09, Mean 80.09

All 1 Raw Readings

#	Time (UTC)	Value (°C)	Status
1	2026-09-24 10:35	80.09	OK

Signal: Winding_Temp_V (°C)

Operating Limits: [10.0 to 130.0] • Observed: Min 70.31, Max 70.31, Mean 70.31

All 1 Raw Readings

#	Time (UTC)	Value (°C)	Status
1	2026-09-24 10:35	70.31	OK

Signal: Winding_Temp_W (°C)

Operating Limits: [10.0 to 130.0] • Observed: Min 83.95, Max 83.95, Mean 83.95

All 1 Raw Readings

#	Time (UTC)	Value (°C)	Status
1	2026-09-24 10:35	83.95	OK

Signal: Bearing_Temp_DE (°C)

Operating Limits: [10.0 to 95.0] • Observed: Min 56.43, Max 56.43, Mean 56.43

All 1 Raw Readings

#	Time (UTC)	Value (°C)	Status
1	2026-09-24 10:35	56.43	OK

Signal: Bearing_Temp_NDE (°C)

Operating Limits: [10.0 to 95.0] • Observed: Min 54.59, Max 54.59, Mean 54.59

All 1 Raw Readings

#	Time (UTC)	Value (°C)	Status
1	2026-09-24 10:35	54.59	OK

Signal: Ambient_Temp (°C)

Operating Limits: [0.0 to 50.0] • Observed: Min 29.84, Max 29.84, Mean 29.84

All 1 Raw Readings

#	Time (UTC)	Value (°C)	Status
1	2026-09-24 10:35	29.84	OK