New Application Applications

← Applications / AP-VAASTU-20260327062016

AP-VAASTU-20260327062016

Guntur First Grade Municipality 2026-03-27

← Back

Print

Compliance Results

✕ Non-Compliant

RULE	SUBMITTED	REQUIRED	REFERENCE
✕ **Front Setback** Front setback 1.5m is less than required 4.0m *Increase front setback by 2.5m*	1.5 meters	4.0 meters	Table 17, G.O.Ms.No.119
✕ **Rear Setback** Rear setback 1.0m is less than required 2.5m *Increase rear setback by 1.5m*	1.0 meters	2.5 meters	Table 17, G.O.Ms.No.119
✕ **Side 1 Setback** Side 1 setback 0.5m is less than required 2.0m *Increase side 1 setback by 1.5m*	0.5 meters	2.0 meters	Table 17, G.O.Ms.No.119
✕ **Side 2 Setback** Side 2 setback 0.5m is less than required 2.0m *Increase side 2 setback by 1.5m*	0.5 meters	2.0 meters	Table 17, G.O.Ms.No.119
✕ **Parking Requirement** Parking 3.6% is less than required 30% *Add 370.0 sq.m parking area or apply for parking fee waiver*	3.6 % of built-up	30 % of built-up	Table 11, G.O.Ms.No.119

RULE	SUBMITTED	REQUIRED	REFERENCE
✗ **Habitable Room Area** Room area 8.0 sq.m is less than minimum 9.5 sq.m	8.0 sq.m	9.5 sq.m	Table 5, G.O.Ms.No.119
✗ **Habitable Room Width** Room width 2.0m is less than minimum 2.4m	2.0 meters	2.4 meters	Table 5, G.O.Ms.No.119
✗ **Kitchen Area** Kitchen area 3.5 sq.m is less than minimum 4.5 sq.m	3.5 sq.m	4.5 sq.m	Table 5, G.O.Ms.No.119
✗ **Floor Area Ratio** FAR 2.80 exceeds maximum permissible 1.75 *Reduce built-up area by 525.0 sq.m*	2.8 ratio	1.75 ratio	Chapter VII, G.O.Ms.No.119
✓ **Ground Coverage** Ground coverage 70.0% is within limit of 70%	70.0 %	70 %	Chapter VII, G.O.Ms.No.119
✗ **Rain Water Harvesting** Rain water harvesting is mandatory for plots >= 200 sq.m *Add rain water harvesting structure as per Chapter XI-1 guidelines*	0 provision	1 provision	Chapter XI-1, Rule 152
✓ **Fire Department NOC** Fire NOC not required for this building	0 clearance	0 clearance	Chapter VI, G.O.Ms.No.119

Building Details

BUILDING TYPE

Residential

PLOT AREA

500.0 sq.m

NUMBER OF FLOORS
4

BUILDING HEIGHT
14.0 m

TOTAL BUILT-UP AREA
1400.0 sq.m

BUILDING CLASSIFICATION
Non-High-Rise

Setbacks Provided

FRONT SETBACK
1.5 m

REAR SETBACK
1.0 m

SIDE 1 SETBACK
0.5 m

SIDE 2 SETBACK
0.5 m

Provisions

RAIN WATER HARVESTING
No

SOLAR PANELS
No

SEWAGE TREATMENT PLANT

No

16%

Non Compliant

2	0	10
PASSED	WARNINGS	VIOLATIONS

Review Status

Submitted

UPDATE STATUS

Review | Approve | Reject

Fee Estimate

Permit Fee	Rs. 16,800
Development Charge	Rs. 112,000

Impact Fee	Rs. 70,000
Total Estimated	Rs. 198,800

SCS 2025

Eligible for Self Certification

Eligible for instant approval via OBPS