Pressure drop behaviour of the LOBI installation

Commission of the European Communities - Pressure Losses In Piping Systems



Description: -
-Pressure drop behaviour of the LOBI installation
-
Shirley Institute publication -- S.28
Shirley Institute publication ; S28
EUR6971
Nuclear science and technologyPressure drop behaviour of the LOBI installation
Notes: At foot of title page: Joint Research Centre, Ispra Establishment - Italy.
This edition was published in 1981

Filesize: 22.16 MB

Tags: #3.4 #Valve #Sizing

Pressure Losses In Piping Systems

The calculated pressure is slightly underestimated in the first part of the transient before 700 s and overestimated in the final part of the transient after 700 s. The pressure drop that occurs in a conduction is the loss of dynamic energy of the fluid due to the friction of the fluid particles against one another and against the walls of the conduit that contains them. The accumulator levels shows an acceptable trend if compared to the experimental Figure 23.

Flux Behavior in Membrane Processes

The trend is well reproduced by the code during steady state and the beginning of the transient demonstrating that the RELAP5 model was correctly setup. Design - Shortcut calculation method 4. If you know one CFM, S.

3.4 Valve Sizing

System Effect System Effect occurs in an air system when two or more elements such as fittings, a hood and a fitting, or a fan and a fitting occur within close proximity to one another.

Pressure Losses In Piping Systems

Thus, the control system will tend to over-react at low flow rates and under-react at high flow rates, simply because the control valve fails to exert the same degree of control over process flow at different flow rates. Note : changing only the may not be enough to increase the throughput Product build-up at Too high air velocity Review if air velocity can be decreased, be careful not to have too low speed at product pick-up, if the minimum pick-up velocity is not reached, a blockage at the start of the line could happend.

Control Valve Characterization

Figure 7 shows PS total mass. This information was then used to optimise designs for the end-of-line flame arresters whilst avoiding the need for costly plant trials. In this blog post, we will be focusing on electric fans as that is what is typically used for sports cars.

Control Valve Performance with Constant Pressure Drop

At 42 s PS reached the saturation pressure of the fluid in the lower plenum. Boundary conditions during the test follow the behavior of the reference plant after leak detection. This curve shows the relationship between the air flow rate and the pressure of an air system.

Pressure drop calculation form

Figure 21 shows SS steam dome pressure in the broken loop vols. A balloon blown up with air is a similar case in which there is only static pressure. DISCLOSURE: I may be an affiliate for products that I recommend.

Related Books