
**Rough Draft** 

**V2** 

David Fugate November 6, 2014



OAK RIDGE National Laboratory

#### FRP 2 Building Equipment Summary


- The 2 story FRP is 3,200 ft2 and is targeted for study of the energy efficiency of a variety of light commercial buildings.
- The baseline brick/block-wall building with lowslope roof has eight HVAC zones.
- Rooftop unit that is variable air volume with electric reheat shutoff terminal boxes.




Two-story light commercial building flexible research platform



- Roof-top-unit is a Trane YCD150 12 ½ Ton Unit.
- Variable Air Volume (VAV) systems distribute the conditioned air.



FRP 2 Building Equipment Summary





- Roof-top-unit is a Trane YCD150 12 ½ Ton Unit.
  - Gas Heat
  - DX Cooling
  - Loads
    - Blower (Evaporator) Fan
    - Condenser Coil
      Fan
    - Two Compressors
    - Combustion Fan Motor






Table ED-1 — Electrical Characteristics — Evaporator Fan Motors — 60 Cycle

			Standard Evaporator Fan Motor					Oversized Evaporator Fan Motor					
	Unit		Amps				nps					Amps	
Tons	Model No.	No.	Volts	Phase	HP	FLA	LRA	No.	Volts	Phase	HP	FLA	LRA
<b>12</b> ½	YC*150D3, YC*151C3 YC*150D4, YC*151C4	1	460	3	3.00	4.8	40.5	1	200-230 460	3	5.00 5.00	7.6	54.9
	YC*150DVV,YC*151CVV YC*150DK	1	5/5 380	3 3	3.00 5.0	3.9 9.2	31.0 66.5	1 -	5/5 -	3 -	5.00 -	6.1 -	41.6 -
15	YC*180B3, YC*181C3 YC*180B4, YC*181C4	1 1	208-230 460	3	3.00 3.00	10.6 4.8	81.0 40.5	1	208-230 460	3	5.00 5.00	16.7 7.6	109.8 54.9
	YC*180BW,YC*181CW YC*180BK	1 1	575 380	3 3	3.00 5.0	3.9 9.2	31.0 66.5	1 -	5 <b>7</b> 5	3	5.00	6.1	41.6 -
<b>17</b> ½	YC*210C3, YC*211C3 YC*210C4, YC*211C4	1 1	208-230 460	3	5.00 5.00	16.7 7.6	109.8 54.9	1	208-230 460	3	7.50 7.50	24.2 11.0	120.4 74.0
	YC*210CW,YC*211CW YC*210CK	1 1	575 380	3 3	5.00 7.5	6.1 13.3	41.6 83.5	1 –	5 <b>7</b> 5	3	7.50	9.0	60.0
20	YC*240B3,YC*241C3 YC*240B4,YC*241C4	1 1	208-230 460	3	5.00 5.00	16.7 7.6	109.8 54.9	1	208-230 460	3	7.50 7.50	24.2 11.0	120.4 74.0
	YC*240BW,YC*241CW YC*240BK	1 1	575 380	3	5.00 7.5	6.1 13.3	41.6 83.5	1 -	575 -	3	7.50	9.0	60.0
25	YC*300B3, YC*301C3 YC*300B4, YC*301C4	1 1	208-230 460	3 3	7.50 7.50	24.2 11.0	120.4 74.0	_	_	_	_	_	_
	YC*300BW,YC*301CW YC*300BK	1 1	575 380	3 3	7.50 7.5	9.0 13.3	60.0 83.5	_	_	_	_	_	_


Table ED-2 — Electrical Characteristics — Compressor Motor And Condenser Motor — 60 Cycle — Standard Efficiency

		Compressor Motor						Condenser Fan Motors						
	Unit	Amps <sup>1</sup>						Amps <sup>1</sup>						
Tons	Model No.	No.	Volts	Phase	HP8	RPM	RLA	LRA	No.	Phase	HP	FLA	LRA	
121/2	YC*150D3 YC*150D4	2	208-230 460	3	6.0 6.0	3450 3450	20.4 10.8	75	2	1	.50 .50	3.2 1.6	3.8	
/2	YC*150DW YC*150DK	2 2	5/5 380	3 3	6.0 6.0	3450 3450	8.3 13.1	54 70	2 2	1	.50 .50	1.3 1.9	3.2 5.2	

#### FRP 2 Building Equipment Summary

- Variable Air Volume (VAV) systems distribute the conditioned air.
- JCI TSS model VAV Units
  - Air Heater
  - Air flow modulation





# FRP 2 Building Summary Current Measurements

Total of 12 CT's.

Measurement Location	Description	Voltage	Current	Quantity of CT's
C1	FRP Incoming Power Feed	480vac/3ph	100A	3
C2	ACU-1 Power Feed	480vac/3ph	60A	3
C3	VAV -11, 12, 13	480vac/3ph	20A	3
C4	VAV -14, 15	480vac/3ph	20A	3
C5	?	?	?	?
C6	?	?	?	?



# FRP 2 Building Summary Current Measurements

- Total of 3 VT measurements.
  - 1 3 phase VT's.

Measurement Location	Description	Voltage	Curre nt	Quantity of CT's	Notes
V1	FRP Incoming Power Feed	480vac/3ph	100A	3	Use extra/unused 3-phase circuit breaker



#### ORNL Requirements for Richman Surrey Equipment

- 1. UL listed components and enclosure.
- 2. Minimum rating of Nema 1 for enclosure.

