

2700 Dover Street inspection & furniture plan

A room-by-room worksheet for your own observations, the inspector's findings, likely repair follow-up, and a practical furniture plan for three upper bedrooms plus a lower-level office.

INSPECTION DATE

INSPECTOR

BUYER / ATTENDEE

REPORT DUE

ATTORNEY DEADLINE

AGENT / CONTACT

Use this as a question and note guide—not a defect report. Photos cannot confirm moisture, structure, code compliance, permits, sewer condition, radon, termites, tank history, property lines or repair cost.

Do not miss

1. Lower-level ceiling area and door-base damage — photos 27–28.
2. Porch roof boards, skylight and house flashing — photos 3, 29–30.
3. Deck ledger, stairs, footings and grill gas connection — photos 31–32.
4. Main roof, chimney, vents and three skylights — photos 12, 36–37.
5. Rear drainage, sewer route, trees and boundaries — photos 33–39.


Appointment setup

- ☐ Utilities and appliances are on
- ☐ Attic, garage, panels and shutoffs accessible
- ☐ Seller permits moving stored items where allowed
- ☐ Written permission for sewer/tank work confirmed
- ☐ Inspector credentials and insurance verified
- ☐ Radon, WDI and specialist scope confirmed

My biggest questions before the inspection starts

Three upper bedrooms for sleeping; lower room for office

Suggested arrangement if the primary bedroom is for adults and the other two rooms are shared by four children. This is a use diagram, not a measured floor plan.



Children's-room safety before furniture

- ☐ Measure each wall, door swing and closet opening
- ☐ Keep egress windows and HVAC/baseboard heat clear
- ☐ Anchor dressers, shelves and TVs to framing
- ☐ Do not place a bunk near ceiling fan or window
- ☐ Confirm smoke/CO alarms and night escape route
- ☐ Use bunks only when age-appropriate and compliant

Lower-office setup

- ☐ Ceiling and door-area moisture readings documented
- ☐ Enough grounded outlets without extension cords
- ☐ Reliable Wi-Fi / Ethernet route confirmed
- ☐ Heating, cooling and ventilation comfortable
- ☐ Desk positioned away from damaged door area
- ☐ Background/privacy and closed storage planned

Measurements to take before buying anything

ROOM	USABLE WALL 1	USABLE WALL 2	DOOR / WINDOW NOTES
Primary			
Kids A + B			
Kids C + D			

ROOM-BY-ROOM INSPECTION

Exterior, roof, attic and site

Photos 1, 8, 33–39



Photo 01 • Front exterior



Photo 36 • Roof aerial




Photo 37 • Skylights / roof

Check each item

- ☐ Roof covering age, layers, wear and remaining life
- ☐ All skylights, chimney and vent flashing
- ☐ Attic underside for stains, rot, mold and daylight
- ☐ Gutters/downspouts at every roof edge; discharge location
- ☐ Siding, trim, penetrations and foundation clearance
- ☐ Grading and standing-water evidence around additions
- ☐ Trees/limbs/roots affecting roof, fence or sewer
- ☐ Driveway, walks, fence, shed and property boundaries

Photo-guided focus

- At least three skylights increase flashing/leak exposure.
- Rear additions create several roof-to-wall and drainage joints.
- Survey, easements, park boundary and sewer route are not visible.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Screened porch, rear deck and garage

Photos 3, 29–34; garage not shown




Photo 03 · Porch roof




Photo 31 · Deck surface




Photo 32 · Stairs / grill

Check each item

- ☐ Porch roof boards/rafters probed for softness or rot
- ☐ Porch skylight and roof-to-house flashing
- ☐ Screens, framing, floor and exterior-rated wiring/GFCI
- ☐ Deck ledger bolts, flashing, joist hangers and posts
- ☐ Footings, guards, stair dimensions and handrails
- ☐ Weathered boards, fasteners and awning wind connection
- ☐ Grill gas line, shutoff, leak test and permit
- ☐ Garage door auto-reverse, fire separation and outlets

Photo-guided focus

- Dark marks and uneven porch-roof paint may be weathering, old leakage or mildew.
- Deck ledger, footings and most connectors are concealed in photos.
- Do not use unsafe deck/stairs until structural findings are resolved.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Entry, living and family areas

Photos 2, 4, 9–14




Photo 09 · Entry / family room



Photo 12 · Skylight room




Photo 14 · Open living area

Check each item

- ☐ Ceilings/walls for stains, cracks, patches and movement
- ☐ Floors for slope, squeaks, soft areas and hidden damage
- ☐ Windows/doors for operation, locks, seals and drafts
- ☐ Front/rear thresholds and floor moisture
- ☐ Outlets, switches, lighting and accessible receptacles
- ☐ HVAC registers/baseboard heat and room comfort
- ☐ Stair guards, handrails, tread/riser safety and lighting
- ☐ Large wall openings checked against permits/support

Photo-guided focus

- Skylights require ceiling moisture readings even without a visible stain.
- Large openings may represent prior alterations; verify permits if relevant.
- Furniture may conceal outlets, flooring, walls and baseboards.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Kitchen, dining and breakfast areas

Photos 2, 4, 15–19




Photo 02 · Dining area




Photo 17 · Kitchen appliances



Photo 19 · Kitchen / rear access

Check each item

- ☐ Sink, dishwasher, refrigerator lines and cabinet floor leaks
- ☐ Gas shutoff, range anti-tip bracket and ignition
- ☐ Microwave/range exhaust route and fan operation
- ☐ GFCI protection, outlets and two-refrigerator circuit load
- ☐ All appliances tested; model/serial/age recorded
- ☐ Counters, cabinet doors, drawers and wall/floor behind units
- ☐ Dining/rear door operation, sill and moisture
- ☐ Water pressure, hot water and drain flow

Photo-guided focus

- Confirm in writing which appliances stay, including the second refrigerator.
- Appliances hide floor, wall, electrical and plumbing conditions.
- Dining set appears to seat the household well; measure before negotiating.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Upper bedroom 1 — primary / adults

Photos 20–22



Photo 20 · Primary bedroom



Photo 21 · Ceiling / fan




Photo 22 · Bath-side view

Check each item

- ☐ Ceiling seams/patch-like areas moisture-metered
- ☐ Attic/plumbing source above or beside room investigated
- ☐ Windows operate, lock, seal and satisfy escape needs
- ☐ Ceiling fan support and concealed TV wiring
- ☐ Outlets, lighting, smoke/CO alarm and HVAC airflow
- ☐ Baseboard heat clear of curtains and planned furniture
- ☐ Closets, doors, floor perimeter and furniture-hidden areas
- ☐ Bed/nightstand/dresser wall measurements recorded

Photo-guided focus

- Uneven ceiling finish may be normal, movement or a prior moisture repair.
- Nearby bathroom adds a possible plumbing source.
- Buy hard furniture only after measuring; decline the mattress.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Upper bedroom 2 — children A + B

Photos 23–24



Photo 23 · Two-window bedroom



Photo 24 · Closet / opposite view

Check each item

- ☐ Both windows open, lock and meet escape requirements
- ☐ Clear escape path not blocked by beds/desks
- ☐ Ceiling fan clearance from any bunk or raised bed
- ☐ Smoke/CO alarm location and audible operation
- ☐ Outlets, covers, cords and HVAC airflow
- ☐ Closet, door swing and usable wall dimensions
- ☐ Walls/floors behind existing furniture inspected
- ☐ Dresser/shelves/TV can be anchored to framing

Photo-guided focus

- Likely best shared-kids room because it shows two windows and useful floor area.
- Two twins or a trundle may be simpler than a bunk if fan/window clearance is tight.
- Existing hard furniture may fit; inspect stability and anchor points.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Upper bedroom 3 — children C + D

Photo 25




Photo 25 · Bedroom / desk / bed




Photo 05 · Desk candidate




Photo 23 · Twin-frame candidate

Check each item

- ☐ Window opens, locks and meets escape requirements
- ☐ Bed placement leaves window and door path clear
- ☐ Ceiling fan clearance from bunks/raised furniture
- ☐ Smoke/CO alarm and night lighting
- ☐ Outlets, wiring, HVAC and baseboard clearance
- ☐ Closet and room dimensions for two sleeping positions
- ☐ Floor/walls behind bed, dresser and desk
- ☐ All tall furniture can be anchored

Photo-guided focus

- This room appears tighter; measure before promising two separate twin frames.
- An age-appropriate bunk or trundle may preserve play/study space.
- Do not buy the pictured mattress; consider desk/dresser/frame only.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Bathrooms and wet areas

Photos 7, 22, 26




Photo 07 - Bathroom



Photo 22 - Primary bath side




Photo 26 - Second bathroom

Check each item

- ☐ Run every sink, tub and shower; check hot/cold pressure
- ☐ Drain speed, traps, supply valves and cabinet floors
- ☐ Toilet stability, seal, flush and floor around base
- ☐ Shower pan/tub edge moisture readings
- ☐ Grout, caulk, tile, wall and floor condition
- ☐ GFCI protection and safe fixture placement
- ☐ Exhaust fan operation and exterior discharge
- ☐ Ceiling below/adjacent rooms checked for leaks

Photo-guided focus

- Older shower materials can conceal pan or substrate leakage.
- No exhaust grille is obvious in the second-bath photo.
- Repair water sources before cosmetic tile or paint work.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Lower-level room — planned office

Photos 27–28



Photo 27 • Ceiling concern




Photo 28 • Door-base concern

Check each item

- ☐ Moisture meter and thermal camera at ceiling irregularity
- ☐ Area above traced for plumbing/roof/exterior source
- ☐ Door/jamb, adjacent floor and wall probed for softness
- ☐ Humidity, musty odor, efflorescence and water history
- ☐ Grounded outlets, circuit capacity and task lighting
- ☐ Heating/cooling, ventilation and comfortable work temperature
- ☐ Internet/Wi-Fi/Ethernet route and phone signal
- ☐ Permit/finished-space status documented even for office use

Photo-guided focus

- Do not repaint the ceiling or door until moisture is ruled out.
- Keep desk/electronics away from the suspect area until dry and repaired.
- Office use avoids relying on this room as a legal bedroom.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

ROOM-BY-ROOM INSPECTION

Electrical, plumbing, HVAC and life safety

Systems are mostly absent from listing photos



Check each item

☐ Main panel brand, capacity, labels, double taps and open slots
 ☐ GFCI/AFCI protection and representative outlet testing
 ☐ Service grounding/bonding and visible unsafe wiring
 ☐ Water main/shutoffs, visible supply/drain material and leaks
 ☐ Water heater age, venting, relief pipe and hot-water delivery
 ☐ Heating/cooling equipment age, service history and operation
 ☐ Smoke/CO alarms at required sleeping/floor locations
 ☐ Gas lines, shutoffs, leaks and combustion venting

Photo-guided focus

- Listing photos do not clear any major system.
- Record model, serial, age and expected remaining life for each unit.
- Obtain specialist estimates for material safety defects before deadline.

Measurements / age / model

Inspector result:

☐ Good
 ☐ Monitor
 ☐ Repair
 ☐ Specialist
 ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

2700 Dover inspection notebook • Page 12

ROOM-BY-ROOM INSPECTION

Sewer, tank, radon, WDI, permits and records

Photos 35, 38–39 provide site context only



Photo 35 · Trees / rear yard




Photo 38 · Lot aerial



Photo 39 · Park-side context

Check each item

- ☐ Sewer camera reaches public main; full video and map delivered
- ☐ Pipe material, roots, bellies, offsets and cleanout documented
- ☐ Tank sweep area/scope, scan map, photos and written result
- ☐ Radon test location, duration, closed-house conditions and result
- ☐ WDI inspection, credentials, report and inaccessible areas
- ☐ Municipal permits/CO for additions, porch, deck and finished room
- ☐ Survey, easements, fence/park boundary and encroachments
- ☐ Flood determination, drainage history and insurance questions

Photo-guided focus

- Obtain written seller permission before invasive sewer/tank work.
- Keep complete reports, receipts, videos and specialist credentials.
- Tree roots and park-side vegetation increase the value of locating the sewer route.

Measurements / age / model

Inspector result: ☐ Good ☐ Monitor ☐ Repair ☐ Specialist ☐ Request credit

What I noticed / questions I asked

Inspector answer / report page / estimated cost

Best items to ask about first

These items appear to fit the photographed rooms. Availability, ownership, brand, condition and inclusion are not confirmed.

- 1

Dining table and six-chair set • photos 2, 15–16. Strong first ask because it already fits the dining area and seats a six-person family. Inspect joints, chair wobble and upholstery.
- 2

Gray sectional / family-room seating • photos 9–11. More practical for children than the light-colored sofa. Buy only if odor-, pest-, smoke- and stain-free with supportive cushions.
- 3

Hard bedroom furniture • photos 20–25. Dressers, nightstands, desks and twin bed frames can save moving cost because they already fit. Anchor all tall pieces. Decline mattresses.
- 4

Desk and chair for the lower office • photos 5, 23 or 25. Ask about the best-sized desk; test chair height/support and leave room around baseboard heat and outlets.
- 5

Porch dining set • photos 3, 29–30. Useful if metal joints are sound and there is no rust, mildew or cushion odor. Treat as a low-cost add-on.

Good family-fit candidates

☐ Dining table + chairs

☐ Gray sectional if clean

☐ Twin frames / trundle frames

☐ Dressers with anchor hardware

☐ Desks and hard-surface storage

☐ Dry, sound porch table/chairs

Usually decline or buy only after testing

☐ Used mattresses, pillows and bedding

☐ Mildewed outdoor cushions or rugs

☐ Light sofa unless covers are washable

☐ Unanchored tall dressers / unstable bunks

☐ Grill before gas connection is leak-tested

☐ Old refrigerator without model/age test

Protect the purchase: list every agreed item, price, condition and removal obligation in a written attorney/agent-approved addendum or separate bill of sale. Ask the lender how personal property must be handled. Do not rely on listing photos or a verbal promise.

Seller's first response / bundle price

SELLER FURNITURE

Furniture worksheet — main living and dining areas

Inspect in person and compare with local used-market prices. Do not pay for items simply because they appear in listing photos.

ITEM	PHOTOS	FAMILY FIT	INSPECT / ASK	DECISION / OFFER
Dining table + six chairs	2, 15–16	ASK FIRST Strong family fit; already scaled to room.	Joints, wobble, leaf, upholstery, stains.	☐ Buy ☐ Pass Offer \$ _____
Gray sectional / sofa	9–11	ASK FIRST Practical seating for children if clean.	Odor, smoke, pets, pests, stains, frame/springs.	☐ Buy ☐ Pass Offer \$ _____
White sofa + chairs	12–14	CONSIDER Fits room, but light upholstery is less child-friendly.	Washable covers, stains, cushion support.	☐ Buy ☐ Pass Offer \$ _____
Coffee / side tables	9–14	CONSIDER Useful only as low-cost bundle pieces.	Sharp corners, wobble, finish, dimensions.	☐ Buy ☐ Pass Offer \$ _____
Dining hutch / cabinet	15–16	CONSIDER Storage value if anchored and walkway stays clear.	Tip risk, shelves, glass, wall anchor.	☐ Buy ☐ Pass Offer \$ _____
Breakfast table / movable seating	4	CONSIDER Smaller daily-use option; confirm what is built in.	Dimensions, stability, inclusion status.	☐ Buy ☐ Pass Offer \$ _____
Rugs, lamps and decor	Multiple	USUALLY SKIP Low move-in value unless nearly free and wanted.	Odor, allergens, pests, cord and shade damage.	☐ Buy ☐ Pass Offer \$ _____

Seller answer, included accessories and pickup/removal agreement

SELLER FURNITURE

Furniture worksheet — bedrooms, office and outdoor

Inspect in person and compare with local used-market prices. Do not pay for items simply because they appear in listing photos.

ITEM	PHOTOS	FAMILY FIT	INSPECT / ASK	DECISION / OFFER
Twin / daybed frames	23–25	ASK FIRST Good for shared kids' rooms after measuring.	Slats, fasteners, recalls, guardrails; no mattress.	☐ Buy ☐ Pass Offer \$ _____
Dressers / nightstands	20–25	ASK FIRST Good hard-furniture candidates that already fit.	Drawer stops, stability, damage, anchor hardware.	☐ Buy ☐ Pass Offer \$ _____
Desks / shelving	5, 23, 25	ASK FIRST Useful for lower office or children's study area.	Dimensions, wobble, outlets, anchor need.	☐ Buy ☐ Pass Offer \$ _____
Desk / gaming chairs	5, 25	CONSIDER Use only if supportive and correctly sized.	Lift, wheels, tilt, upholstery and ergonomics.	☐ Buy ☐ Pass Offer \$ _____
Primary bed frame	20–22	CONSIDER May fit room, but compare moving and disassembly cost.	Frame condition and dimensions; decline mattress.	☐ Buy ☐ Pass Offer \$ _____
Porch table + chairs	3, 29–30	ASK FIRST Good low-cost add-on for screened porch.	Rust, joints, mildew, outdoor rating.	☐ Buy ☐ Pass Offer \$ _____
Deck seating / canopy items	31	CONSIDER Buy only if dry, stable and not part of unsafe deck work.	Fabric, anchors, rust, wind damage.	☐ Buy ☐ Pass Offer \$ _____
Grill	32	CONSIDER Only after appliance and gas connection are tested.	Age, burners, rust, hose/shutoff, leak test.	☐ Buy ☐ Pass Offer \$ _____
Second refrigerator	17–18	CONSIDER Useful for a large family if efficient and reliable.	Model/serial, age, temperature, seals, energy use.	☐ Buy ☐ Pass Offer \$ _____
Mattresses / pillows / bedding	20–27	USUALLY SKIP Hygiene, allergen and pest risk outweigh convenience.	Do not include unless you independently choose otherwise.	☐ Buy ☐ Pass Offer \$ _____

Seller answer, included accessories and pickup/removal agreement

Repairs, credits and before-move priorities

Transfer confirmed issues from the written inspection and specialist reports—not from the listing photos alone.

CONFIRMED ISSUE	PHOTO / REPORT PAGE	SPECIALIST	ESTIMATE	CREDIT / SELLER	DECISION
			\$		
			\$		
			\$		
			\$		
			\$		
			\$		
			\$		
			\$		
			\$		
			\$		
			\$		

Contractor names, estimate dates and follow-up questions

Move-in priorities, totals and my decision

Separate safety and active-water work from cosmetic projects and optional furniture.

Must resolve before move-in

- ☐ Active water entry / wet materials
- ☐ Unsafe deck, stairs, railings or gas
- ☐ Electrical shock / fire hazards
- ☐ Sewer blockage, collapse or tank concern
- ☐ Unsafe bedroom egress or missing alarms
- ☐ Radon / WDI response if results require it

Can normally wait if safe and dry

- ☐ Painting and cosmetic patching
- ☐ Optional bathroom modernization
- ☐ Furniture replacement / decor
- ☐ Deck cleaning and sealing after repairs
- ☐ Landscaping not affecting drainage
- ☐ Non-safety lighting upgrades

Repair estimate total
\$ _____

Credit / seller work total
\$ _____

Furniture offer total
\$ _____

Immediate cash needed
\$ _____

My final decision and reasons

