

# RSLogix Micro Project Report



Processor Information

---

Processor Type: Bul.1763      MicroLogix 1100 Series B

Processor Name: UNTITLED

Total Memory Used: 316 Instruction Words Used - 57 Data Table Words Used

Total Memory Left: 6340 Instruction Words Left

Program Files: 7

Data Files: 9

Program ID: 1a31

I/O Configuration

0	Bul.1763	MicroLogix 1100 Series B
1		
2		
3		
4		

## Channel Configuration

## CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex

CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Edit Resource/Owner Timeout: 60  
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Passthru Link ID: 1  
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Write Protected: No  
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Comms Servicing Selection: Yes  
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Message Servicing Selection: Yes  
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex 1st AWA Append Character: \d  
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex 2nd AWA Append Character: \a

Source ID: 1 (decimal)  
Baud: 19200  
Parity: NONE  
Control Line : No Handshaking  
Error Detection: CRC  
Embedded Responses: Auto Detect  
Duplicate Packet Detect: Yes  
ACK Timeout(x20 ms): 50  
NAK Retries: 3  
ENQ Retries: 3

## CHANNEL 1 (SYSTEM) - Driver: Ethernet

CHANNEL 1 (SYSTEM) - Driver: Ethernet Edit Resource/Owner Timeout: 60  
CHANNEL 1 (SYSTEM) - Driver: Ethernet Passthru Link ID: 1  
CHANNEL 1 (SYSTEM) - Driver: Ethernet Write Protected: No  
CHANNEL 1 (SYSTEM) - Driver: Ethernet Comms Servicing Selection: Yes  
CHANNEL 1 (SYSTEM) - Driver: Ethernet Message Servicing Selection: Yes

Hardware Address: 00:00:00:00:00:00  
IP Address: 0.0.0.0  
Subnet Mask: 0.0.0.0  
Gateway Address: 0.0.0.0  
Msg Connection Timeout (x 1mS): 15000  
Msg Reply Timeout (x mS): 3000  
Inactivity Timeout (x Min): 30  
Bootp Enable: Yes  
Dhcp Enable No  
SNMP Enable: No  
HTTP Enable: Yes  
Auto Negotiate Enable: Yes  
Port Speed Enable: 10/100 Mbps Full Duplex/Half Duplex  
Contact:  
Location:

Program File List

Name	Number	Type	Rungs	Debug	Bytes
[SYSTEM]	0	SYS	0	No	0
	1	SYS	0	No	0
MAIN	2	LADDER	5	No	39
IO	3	LADDER	11	No	265
CTRL	4	LADDER	12	No	411
ALARMS	5	LADDER	11	No	323
HOA	6	LADDER	9	No	272

Data File List

Name	Number	Type	Scope	Debug	Words	Elements	Last
OUTPUT	0	O	Global	No	12	4	O:3
INPUT	1	I	Global	No	18	6	I:5
STATUS	2	S	Global	No	0	66	S:65
BINARY	3	B	Global	No	2	2	B3:1
TIMER	4	T	Global	No	12	4	T4:3
COUNTER	5	C	Global	No	3	1	C5:0
CONTROL	6	R	Global	No	3	1	R6:0
INTEGER	7	N	Global	No	5	5	N7:4
FLOAT	8	F	Global	No	2	1	F8:0

PROJEKTBESCHREIBUNG: BEI DIESEM PROJEKT GEHT ES UM DIE SICHERHEIT DER PUMPE. DIE SICHERHEIT DER PUMPE WIRD DURCH EINE KOMBINATION VON ZWEI SENSOREN GEWÄHRLEISTET: 1) STRÖMUNGSSCHALTER 2) DRUCKSENSOR. DER STRÖMUNGSSCHALTER WIRD VOR DER PUMPE UND DER DRUCKSENSOR NACH DER PUMPE MONTIERT. SOBALD DIE PUMPE AN IST UND FÜR FÜNF SEKUNDEN LÄUFT, WIRD ES FESTGESTELLT, OB DER STRÖMUNGSSCHALTER GESCHLOSSEN IST UND/ODER OB DER DRUCK NACH DER PUMPE KLEINER ALS 30 PSI IST. WENN ES NICHT DER FALL IST, WIRD EIN ALARM AUSGELÖST UND DIE PUMPE AUSGESCHALTET. SOLANGE DANN DER ALARM-RESET NICHT BETÄTIGT WIRD, KANN DIE PUMPE NICHT WIEDER IM BETRIEB GENOMMEN WERDEN. AUßERDEM WIRD DIE PUMPE MITTELS HAND/AUTOMATIK/AUS SCHALTER BETRIEBEN. SOLANGE DIE HANDTASTE GEDRUCKT BLEIBT, LÄUFT DIE PUMPE. SOBALD DIE HANDTASTE LOSGELASSEN WIRD GEHT DIE PUMPE WIEDER IN DEN OFF-MODUS, DAS VOR DEM HAND-MODUS AKTIV WAR. IN AUTO-MODUS LÄUFT DIE PUMPE IN EINEM ZYKLUS. DAS HEIßT, DIE PUMPE IST FÜR 30 SEKUNDEN AN UND DANN BLEIBT AUS FÜR 10 SEKUNDEN UND DANN WIEDER AN FÜR 30 SEKUNDEN UND SO WEITER. IM OFF-MODUS (AUS) BLEIBT DIE PUMPE AUS. FOLGEND SIND DIE IO FÜR DAS PROGRAMM:

- 1) I:0/0 - STRÖMUNGSSCHALTER
- 2) I:0/1 - ALARM-RESET
- 3) I:0/2 - ALARMSTUMMSCHALTER
- 4) I:0/3 - HANDTASTE
- 5) I:0/4 - OFFTASTE
- 6) I:0/5 - AUTOTASTE
- 7) N7:0 - DRUCKSENSOR (0-16383) DA DIESES PROGRAMM AUF EMULATE GETESTET WURDE, WURDE DER SENSOR DURCH EINE INTEGER ERSETZT.
- 8) O:0/0 - PUMPE
- 9) O:0/1 - STRÖMUNGSSCHALTERDEFEKTLEUCHTE
- 10) O:0/2 - DRUCKSENSORDEFEKTLEUCHTE

## IO

JSR

Jump To Subroutine  
SBR File Number

U:3

## HOA

JSR

Jump To Subroutine  
SBR File Number

U:6

## ALARMS

JSR

Jump To Subroutine  
SBR File Number

U:5

## TESTKRITERIEN:

- 1) ZUNÄCHST BLEIBT DIE PUMPE AUS. SETZE N7:0 AUF 8192 UND DER DRUCK SOLLTE 27,5 PSI BETRAGEN.
- 2) HANDTASTE WIRD GEDRUCKT BZW EINGESCHALTET. DIE PUMPE GEHT AN UND BLEIBT AN FÜR 5 SEKUNDEN UND DANN WIEDER AUS. DER ALARM WIRD AUSGELÖST UND DIE STRÖMUNGSSCHALTERDEFEKTLEUCHTE LEUCHTET.
- 3) HANDTASTE WIRD LOSGELASSEN UND DER ALARMSTUMMSCHALTER WIRD BETÄTIGT UND DIE LEUCHTE GEHT WIEDER AUS. HANDTASTE WIRD FÜR EINIGE SEKUNDEN GEDRUCKT UND WIEDER LOSGELASSEN ABER DIE PUMPE GEHT NICHT AN.
- 4) AUTOTASTE WIRD GETOGGELT. DIE PUMPEZYKLUS SOLLTE NICHT AN GEHEN
- 5) ALARMRESET WIRD BETÄTIGT UND DANN WIRD STRÖMUNGSSCHALTER GESCHALTET. NUN WIRD AUTOTASTE GETOGGELT. DIE PUMPE SOLLTE IM ZYKLUS LAUFEN.
- 6) NUN WIRD HANDTASTE GEDRUCKT FÜR UNGEFÄHR 20 SEKUNDEN. DIE PUMPE SOLLTE AUS DEM ZYKLUS RAUS UND STÄNDIG LAUFEN. WIRD DIE HANDTASTE WIEDER GELASSEN SOLLTE DIE PUMPE WIEDER IM ZYKLUS LAUFEN.
- 7) SETZE N7:0 AUF 10000 UND DIE PUMPE SOLLTE NACH 5 SEKUNDEN AUS GEHEN. DER ALARM WIRD AUSGELÖST UND DIE DRUCKSENSORDEFEKTLEUCHTE LEUCHTET. DER DRUCKWERT BETRÄGT 33,5 PSI.

## STEUERUNG

JSR

Jump To Subroutine  
SBR File Number

U:4

⟨END⟩





0009

Druckwerte (0-16383)

LIM

Limit Test

Low Lim00<

TestN7:00<

High Lim1638316383<

DRUCK IN PSI

SCP

Scale w/Parameters

InputN7:00<

Input Min.0.00.0<

Input Max.16383.016383.0<

Scaled Min.0.00.0<

Scaled Max.55.055.0<

OutputF8:00.0<

Druckwerte (0-16383)

LES

Less Than (A<B)

Source AN7:00<

Source B00<

DRUCK IN PSI

MOV

Move

Source0.00.0<

DestF8:00.0<

Druckwerte (0-16383)

GRT

Greater Than (A>B)

Source AN7:00<

Source B1638316383<

DRUCK IN PSI

MOV


Move


Source55.055.0<


DestF8:00.0<

0010


END



















PUMP_PROTECTION.RSS																	
Data File 00 (bin) -- OUTPUT																	
Offset	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0	
O:0.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763      MicroLogix 1100 Series B
O:0.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763      MicroLogix 1100 Series B
O:0.2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763      MicroLogix 1100 Series B
O:0.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763      MicroLogix 1100 Series B

PUMP_PROTECTION.RSS																	
Data File I1 (bin) -- INPUT																	
Offset	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0	
I:0.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763 MicroLogix 1100 Series B
I:0.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763 MicroLogix 1100 Series B
I:0.2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763 MicroLogix 1100 Series B
I:0.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763 MicroLogix 1100 Series B
I:0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763 MicroLogix 1100 Series B-Anal
I:0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763 MicroLogix 1100 Series B-Anal

**Main**

Processor Mode S:1/0 - S:1/4 = Remote Program Mode  
On Power up Go To Run (Mode Behavior) S:1/12 = 0  
First Pass S:1/15 = No  
Free Running Clock S:4 = 0000-0000-0000-0000

**Proc**

OS Catalog Number S:57 = 1100                      User Program Type S:63 = 8001h  
OS Series S:58 = A                                  Compiler Revision Number S:64 =  
OS FRS S:59 =  
Processor Catalog Number S:60 =  
Processor Series S:61 = A  
Processor FRN S:62 =

**Scan Times**

Maximum (x10 ms) S:22 = 0  
Watchdog (x10 ms) S:3 (high byte) = 10  
Last 100 uSec Scan Time S:35 = 0  
Scan Toggle Bit S:33/9 = 0

**Math**

Math Overflow Selected S:2/14 = 0                      Math Register (lo word) S:13 = 0  
Overflow Trap S:5/0 = 0                              Math Register (high word) S:14-S:13 = 0  
Carry S:0/0 = 0                                      Math Register (32 Bit) S:14-S:13 = 0  
Overflow S:0/1 = 0  
Zero Bit S:0/2 = 0  
Sign Bit S:0/3 = 0

**Chan 0**

Processor Mode S:1/0- S:1/4 = Remote Program Mode  
Node Address S:15 (low byte) = 0                      Outgoing Msg Cmd Pending S:33/2 = 0  
Baud Rate S:15 (high byte) = ?  
Channel Mode S:33/3 = 0  
Comms Active S:33/4 = 0  
Incoming Cmd Pending S:33/0 = 0  
Msg Reply Pending S:33/1 = 0

**Debug**

Suspend Code S:7 = 0  
Suspend File S:8 = 0

**Errors**

Fault Override At Power Up S:1/8 = 0                      Fault Routine S:29 = 0  
Startup Protection Fault S:1/9 = 0                      Major Error S:6 = 0h  
Major Error Halt S:1/13 = 0  
Overflow Trap S:5/0 = 0                              Error Description:  
Control Register Error S:5/2 = 0  
Major Error Executing User Fault Rtn. S:5/3 = 0  
Battery Low S:5/11 = 0  
Input Filter Selection Modified S:5/13 = 0  
ASCII String Manipulation error S:5/15 = 0

**Protection**

Deny Future Access S:1/14 = No  
Data File Overwrite Protection Lost S:36/10 = False

**Mem Module**

Memory Module Loaded On Boot S:5/8 = 0  
Password Mismatch S:5/9 = 0  
Load Memory Module On Memory Error S:1/10 = 0  
Load Memory Module Always S:1/11 = 0  
On Power up Go To Run (Mode Behavior) S:1/12 = 0  
Program Compare S:2/9 = 0  
Data File Overwrite Protection Lost S:36/10 = 0

**Forces**

Forces Enabled S:1/5 = Yes  
Forces Installed S:1/6 = No

PUMP_PROTECTION.RSS																	
Data File B3 (bin) -- BINARY																	
Offset	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0	(Symbol) Description
B3:0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
B3:1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Offset	EN	TT	DN	BASE	PRE	ACC	(Symbol)	Description
T4:0	0	0	0	1.0 sec	30	0	PUMPE AN	INTERVAL
T4:1	0	0	0	1.0 sec	10	0	PUMPE AUS	INTERVAL
T4:2	0	0	0	1.0 sec	5	0	Überdruckalarm	
T4:3	0	0	0	1.0 sec	5	0	Strömungstörungsalar	m

Offset	CU	CD	DN	OV	UN	UA	PRE	ACC	(Symbol)	Description
C5:0	0	0	0	0	0	0	0	0		

Offset	EN	EU	DN	EM	ER	UL	IN	FD	LEN	POS	(Symbol)	Description
R6:0	0	0	0	0	0	0	0	0	0	0		

Offset	0	1	2	3	4	5	6	7	8	9
N7:0	0	0	0	0	0					



Wednesday, July 30, 2025 - 15:43:41

## Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code	ABV	BL
B3:0/0			Hand-Schalter				
B3:0/1			OFF-Schalter				
B3:0/2			AUTO-Schalter				
B3:0/3			Pumpe				
B3:0/4			Strömungsschalter- Defekt-Leuchte				
B3:0/5			Drucksensor-Defekt- Leuchte				
B3:0/6			Pumpe-AUTO-Trigger				
B3:0/7			ONS				
B3:0/8			Strömungsschalter				
B3:0/9			Alarm-Reset				
B3:0/10			Alarm-Stummschalter				
B3:0/11			ONS				
B3:0/12			ONS				
B3:0/13			StörmungstörungsAlar m-Trigger				
B3:0/14			ONS				
B3:0/15			StrömungsstörungsAla rm-Bit				
B3:1/0			ONS				
B3:1/1			StrömungstörungsAlar mmeldung-Trigger				
B3:1/2			Störungstörung- Alar mmeldung-Bit				
B3:1/3			ONS				
B3:1/4			ONS				
B3:1/5			Überdruckalarm-Bit				
B3:1/6			Überdruckalarmmeldung g-Bit				
B3:1/7			Überdruckalarm- Trigger				
B3:1/8			Überdruckalarmmeldung g-Trigger				
B3:1/9			ONS				
B3:1/10			Pumpe-HAND-Trigger				
F8:0			DRUCK IN PSI				
I:0/0			Strömungsschalter- Eingang				
I:0/1			Alarm-Reset-Eingang				
I:0/2			Alarm- Stummschalter- Eingang				
I:0/3			HAND-Schalter- Eingang				
I:0/4			OFF-Schalter-Eingang				
I:0/5			Auto-Schalter- Eingang				
N7:0			Druckwerte (0-16383)				
N7:1			Druck in Psi				
N7:2			HOA-MODI 1 = HAND 0 = OFF 2 = AUTO				
N7:3			PUMPE-ZYKLUS-MODI 0 = PUMPE AN 1 = PUMPE AUS				
N7:4			MODUS VOR HAND				
O:0/0			Pumpe-Ausgang				
O:0/1			Strömungsschalter- Defekt- Leuchteausgang				
O:0/2			Drucksensor-Defekt- Leuchte-Ausgang				
S:0			Arithmetic Flags				
S:0/0			Processor Arithmetic Carry Flag				
S:0/1			Processor Arithmetic Underflow/ Overflow Flag				
S:0/2			Processor Arithmetic Zero Flag				
S:0/3			Processor Arithmetic Sign Flag				
S:1			Processor Mode Status/ Control				
S:1/0			Processor Mode Bit 0				
S:1/1			Processor Mode Bit 1				
S:1/2			Processor Mode Bit 2				
S:1/3			Processor Mode Bit 3				
S:1/4			Processor Mode Bit 4				
S:1/5			Forces Enabled				
S:1/6			Forces Present				
S:1/7			Comms Active				
S:1/8			Fault Override at Powerup				
S:1/9			Startup Protection Fault				
S:1/10			Load Memory Module on Memory Error				
S:1/11			Load Memory Module Always				
S:1/12			Load Memory Module and RUN				
S:1/13			Major Error Halted				
S:1/14			Access Denied				
S:1/15			First Pass				
S:2/0			STI Pending				
S:2/1			STI Enabled				
S:2/2			STI Executing				
S:2/3			Index Addressing File Range				
S:2/4			Saved with Debug Single Step				
S:2/5			DH-485 Incoming Command Pending				
S:2/6			DH-485 Message Reply Pending				
S:2/7			DH-485 Outgoing Message Command Pending				
S:2/15			Comms Servicing Selection				
S:3			Current Scan Time/ Watchdog Scan Time				
S:4			Time Base				
S:5/0			Overflow Trap				
S:5/2			Control Register Error				
S:5/3			Major Err Detected Executing UserFault Routine				
S:5/4			M0-M1 Referenced on Disabled Slot				
S:5/8			Memory Module Boot				
S:5/9			Memory Module Password Mismatch				
S:5/10			STI Overflow				
S:5/11			Battery Low				
S:6			Major Error Fault Code				
S:7			Suspend Code				
S:8			Suspend File				
S:9			Active Nodes				
S:10			Active Nodes				
S:11			I/O Slot Enables				
S:12			I/O Slot Enables				

## Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code	ABV	BL
S:13			Math Register				
S:14			Math Register				
S:15			Node Address/ Baud Rate				
S:16			Debug Single Step Rung				
S:17			Debug Single Step File				
S:18			Debug Single Step Breakpoint Rung				
S:19			Debug Single Step Breakpoint File				
S:20			Debug Fault/ Powerdown Rung				
S:21			Debug Fault/ Powerdown File				
S:22			Maximum Observed Scan Time				
S:23			Average Scan Time				
S:24			Index Register				
S:25			I/O Interrupt Pending				
S:26			I/O Interrupt Pending				
S:27			I/O Interrupt Enabled				
S:28			I/O Interrupt Enabled				
S:29			User Fault Routine File Number				
S:30			STI Setpoint				
S:31			STI File Number				
S:32			I/O Interrupt Executing				
S:33			Extended Proc Status Control Word				
S:33/0			Incoming Command Pending				
S:33/1			Message Reply Pending				
S:33/2			Outgoing Message Command Pending				
S:33/3			Selection Status User/DF1				
S:33/4			Communicat Active				
S:33/5			Communicat Servicing Selection				
S:33/6			Message Servicing Selection Channel 0				
S:33/7			Message Servicing Selection Channel 1				
S:33/8			Interrupt Latency Control Flag				
S:33/9			Scan Toggle Flag				
S:33/10			Discrete Input Interrupt Reconfigur Flag				
S:33/11			Online Edit Status				
S:33/12			Online Edit Status				
S:33/13			Scan Time Timebase Selection				
S:33/14			DTR Control Bit				
S:33/15			DTR Force Bit				
S:34			Pass-thru Disabled				
S:34/0			Pass-Thru Disabled Flag				
S:34/1			DH+ Active Node Table Enable Flag				
S:34/2			Floating Point Math Flag Disable,F1				
S:35			Last 1 ms Scan Time				
S:36			Extended Minor Error Bits				
S:36/8			DII Lost				
S:36/9			STI Lost				
S:36/10			Memory Module Data File Overwrite Protection				
S:37			Clock Calendar Year				
S:38			Clock Calendar Month				
S:39			Clock Calendar Day				
S:40			Clock Calendar Hours				
S:41			Clock Calendar Minutes				
S:42			Clock Calendar Seconds				
S:43			STI Interrupt Time				
S:44			I/O Event Interrupt Time				
S:45			DII Interrupt Time				
S:46			Discrete Input Interrupt- File Number				
S:47			Discrete Input Interrupt- Slot Number				
S:48			Discrete Input Interrupt- Bit Mask				
S:49			Discrete Input Interrupt- Compare Value				
S:50			Processor Catalog Number				
S:51			Discrete Input Interrupt- Return Number				
S:52			Discrete Input Interrupt- Accumulat				
S:53			Reserved/ Clock Calendar Day of the Week				
S:55			Last DII Scan Time				
S:56			Maximum Observed DII Scan Time				
S:57			Operating System Catalog Number				
S:58			Operating System Series				
S:59			Operating System FRN				
S:61			Processor Series				
S:62			Processor Revision				
S:63			User Program Type				
S:64			User Program Functional Index				
S:65			User RAM Size				
S:66			Flash EEPROM Size				
S:67			Channel 0 Active Nodes				
S:68			Channel 0 Active Nodes				
S:69			Channel 0 Active Nodes				
S:70			Channel 0 Active Nodes				
S:71			Channel 0 Active Nodes				
S:72			Channel 0 Active Nodes				
S:73			Channel 0 Active Nodes				
S:74			Channel 0 Active Nodes				
S:75			Channel 0 Active Nodes				
S:76			Channel 0 Active Nodes				
S:77			Channel 0 Active Nodes				
S:78			Channel 0 Active Nodes				
S:79			Channel 0 Active Nodes				
S:80			Channel 0 Active Nodes				
S:81			Channel 0 Active Nodes				
S:82			Channel 0 Active Nodes				

Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code	ABV	BL
S:83			DH+ Active Nodes				
S:84			DH+ Active Nodes				
S:85			DH+ Active Nodes				
S:86			DH+ Active Nodes				
T4:0			PUMPE AN INTERVAL				
T4:0/EN							
T4:1			PUMPE AUS INTERVAL				
T4:1/DN							
T4:2			Überdruckalarm				
T4:3			Strömungstörungsalarm				
T4:3/DN							
T4:4			Überdruckalarm				
T4:4/DN							
U:3			IO				
U:4			STEUERUNG				
U:5			ALARMS				
U:6			HOA				

Address	Instruction	Description
---------	-------------	-------------

```
Group_Name  Description
```