

08 11 13 - Hollow Metal Doors and Frames

Steel Doors:

- Exterior: Full flush doors (ANSI A250.8-1998 (SDI-100)), 1-3/4 inches thick, galvanized steel (ASTM A653/A653M-07), 14 gage closer reinforcement top and bottom with snap-in top caps.
- Interior: Full flush doors (ANSI A250.8-1998 (SDI-100)), 1-3/4 inches thick, 14 gage closer reinforcement top and bottom.
- Hardware preparation and reinforcement: Prepare for commercial hardware (ANSI A250.6-1997) and mortised locks (ANSI A115.1), no face holes unless coordinated with hardware schedule. Factory reinforce for surface applied hardware – 14 gage for closer. Locations per ANSI/DHI A115.
- Preferred Manufacturer and Model: Steelcraft L16 Series

Steel Door Frames:

- Exterior: 16 gage welded door frames; A60 hot dipped galvanized steel.
- Flush Frames: F-Series Frames, 16 gage.
http://www.steelcraft.com/downloads/pdfs/steelcraft_spec_l1.pdf
- Interior: 16 gage knock-down door frames.
 - Drywall Frames: DW-Series (using Baseboards) and K-Series (Not using Baseboards), 16 gage.
 - http://www.steelcraft.com/pc_frames_drywall.asp
 - http://www.steelcraft.com/downloads/pdfs/steelcraft_spec_dw1.pdf
- Reinforcement: 14 gage for closer, 4-7/8 inches ASA strike, and 4-1/2 inches hinges.
- Preferred Manufacturer: Steelcraft.

Timely door frames are not preferred.