

## SECTION 22 47 00 – DRINKING FOUNTAINS AND WATER COOLERS

### PART 1 GENERAL

#### 1.01 SECTION INCLUDES

- A. Electric water coolers.
- B. Drinking fountains/Hydration Stations.

#### 1.02 RELATED REQUIREMENTS

- A. Section 22 05 00 – Common Work Results for Plumbing
- B. Section 22 10 05 – Plumbing Piping.
- C. Section 22 11 16 – Domestic Water Piping
- D. Section 22 13 00 – Facility Sanitary Sewerage
- E. Section 22 30 00 – Plumbing Equipment.
- F. Section 22 40 00 – Plumbing Fixtures

#### 1.03 SUBMITTALS

- A. Product Data: Provide catalog illustrations of fixtures, sizes, rough-in dimensions, utility sizes, trim, and finishes.

### PART 2 PRODUCTS

#### 2.01 GENERAL REQUIREMENTS

- A. Potable Water Systems: Provide plumbing fittings and faucets that comply with NSF 61 and NSF 372 for maximum lead content; label pipe and fittings.

#### 2.02 DRINKING FOUNTAINS AND WATER COOLERS

- A. Water Cooler: Electric, mechanically refrigerated; surface mounted, ADA compliant; stainless steel top, vinyl on steel body, elevated anti-squirt bubbler with stream guard, automatic stream regulator, push button, mounting bracket; integral air-cooled condenser and stainless-steel grille.
  - 1. Capacity: 8 gallons per hour (30.3 liters per hour) of 50 degrees F (10 degrees C) water with inlet at 80 degrees F (27 degrees C) and room temperature of 90 degrees F (32 degrees C), when tested in accordance with ASHRAE Std 18.

2. Electrical: 115 V, 60 Hertz compressor, 6 foot (2 m) cord and plug for connection to electric wiring system including grounding connector.
- B. Hydration Station:
1. Elkay Model LZWSSM Surface Mount bottle filling station. Sanitary, touchless activation with auto 20-second shut-off.
    - a. WaterSentry Plus 3000-gallon capacity filtration system, certified to NSF/ANSI 42 & 53 (Lead, Class 1 Particulate, Chlorine, Taste & Odor)
    - b. Integrated silver ion anti-microbial protection
    - c. Fill rate: 1.5 gpm; 1.1 gpm when connected to a remote chiller
    - d. Laminar flow to reduce splash
    - e. Real drain system
    - f. Visual user interface display includes:
      - g. Green Ticker counts bottles saved from waste
      - h. LED visual filter monitor indicates when to replace filter
      - i. Optional remote chiller can be installed within 15 feet of unit to deliver chilled drinking water.

## 2.03 EMERGENCY EYE AND FACE WASH

- A. Emergency Wash: ANSI Z358.1; wall-mounted, self-cleaning, non-clogging eye and face wash with quick opening, full-flow valves, stainless steel eye and face wash receptor, twin eye wash heads and face spray ring, stainless steel dust cover, copper alloy control valve and fittings.

## PART 3 EXECUTION

### 2.04 INSTALLATION

- A. Install components level and plumb.

END OF SECTION 22 47 00