

## 09 91 23 - Interior Painting

### 3.3 APPLICATION

- A. Apply paints according to manufacturer's written instructions.
  - 1. Use applicators and techniques suited for paint and substrate indicated.
  - 2. Paint surfaces behind movable equipment and furniture same as similar exposed surfaces. Before final installation, paint surfaces behind permanently fixed equipment or furniture with prime coat only.
  - 3. Paint front and backsides of access panels, removable or hinged covers, and similar hinged items to match exposed surfaces.
  - 4. Do not paint over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
  - 5. Primers specified in painting schedules may be omitted on items that are factory primed or factory finished if acceptable to topcoat manufacturers.
- B. Tint each undercoat a lighter shade to facilitate identification of each coat if multiple coats of same material are to be applied. Tint undercoats to match color of topcoat, but provide sufficient difference in shade of undercoats to distinguish each separate coat.
- C. If undercoats or other conditions show through topcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
- D. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.
- E. Painting Fire Suppression, Plumbing, HVAC, Electrical, Communication, and Electronic Safety and Security Work:
  - 1. Paint the following work where exposed in equipment rooms:
    - a. Equipment, including panelboards.
    - b. Uninsulated metal piping.
    - c. Uninsulated plastic piping.
    - d. Pipe hangers and supports.
    - e. Metal conduit.
    - f. Plastic conduit.
    - g. Tanks that do not have factory-applied final finishes.
    - h. Duct, equipment, and pipe insulation having cotton or canvas insulation covering or other paintable jacket material.
  - 2. Paint the following work where exposed in occupied spaces:
    - a. Equipment, including panelboards.
    - b. Uninsulated metal piping.
    - c. Uninsulated plastic piping.
    - d. Pipe hangers and supports.

- e. Metal conduit.
  - f. Plastic conduit.
  - g. Duct, equipment, and pipe insulation having cotton or canvas insulation covering or other paintable jacket material.
  - h. h. Other items as directed by Contractor's Architect.
- 3. Paint portions of internal surfaces of metal ducts, without liner, behind air inlets and outlets that are visible from occupied spaces.
- F. Paint all exposed surfaces, except where the paint schedules indicate that a surface or material is not to be painted or is to remain natural. If the paint schedules do not specifically mention an item or a surface, paint the item or surface the same as similar adjacent materials or surfaces whether or not schedules indicate colors. If the schedules do not indicate color or finish, the Contractor's Architect will select from standard colors and finishes available.
  - 1. Painting includes field painting of exposed bare and covered pipes and ducts (including color coding), hangers, exposed steel and iron work, and primed metal surfaces of mechanical and electrical equipment.
- G. Do not paint prefinished items, concealed surfaces, finished metal surfaces, operating parts, and labels, unless otherwise specifically indicated to be painted.
  - 1. Prefinished items include the following factory-finished components:
    - a. Architectural woodwork and casework.
    - b. Acoustical wall panels.
    - c. Metal toilet enclosures.
    - d. Metal lockers.
    - e. Unit kitchens.
    - f. Elevator entrance doors and frames.
    - g. Elevator equipment.
    - h. Finished mechanical and electrical equipment.
    - i. Light fixtures.
    - j. Distribution cabinets.
  - 2. Concealed surfaces include walls or ceilings in the following generally inaccessible spaces:
    - a. Foundation spaces.
    - b. Furred areas.
    - c. Ceiling plenums.
      - 1) Portions of plenums visible through grilles, registers, or other openings are considered an exposed surface and require painting.
    - d. Utility tunnels.
    - e. Pipe spaces.

- f. Duct shafts.
  - 1) Portions of duct shafts visible through grilles, registers, or other openings are considered an exposed surface and require painting.
- g. Elevator shafts.
- 3. Finished metal surfaces include the following:
  - a. Anodized aluminum.
  - b. Stainless steel.
  - c. Chromium plate.
  - d. Copper.
  - e. Bronze and brass.
- 4. Operating parts include moving parts of operating equipment and the following:
  - a. Valve and damper operators.
  - b. Linkages.
  - c. Sensing devices.
  - d. Motor and fan shafts.
- 5. Labels: Do not paint over Underwriters Laboratories (UL), Factory Mutual (FM), or other code-required labels or equipment name, identification, performance rating, or nomenclature plates.

#### **Interior Painting Schedule:**

Gypsum Board – flat finish on ceilings:

Provide the following system over interior gypsum board ceiling surfaces:

1<sup>st</sup> Coat: Premium Interior Acrylic Wall & Wood Primer B28W8111

2<sup>nd</sup> Coat: Pro Mar 400 0 VOC Interior Acrylic Flat B30W4651 Series

3<sup>rd</sup> Coat: Pro Mar 400 0 VOC Interior Acrylic Flat B30W4651 Series

Gypsum Board – satin finish:

Provide the following system over interior gypsum board:

Option 1:

1<sup>st</sup> Coat: Premium Interior Acrylic Wall & Wood Primer B28W8111

2<sup>nd</sup> Coat: Super-Paint Interior Acrylic Satin Enamel A87W1151 Series

3<sup>rd</sup> Coat: Super-Paint Interior Acrylic Satin Enamel A87W1151 Series

Option 2:

1<sup>st</sup> Coat: DE Ultra-Grip Premium Int/Ext Primer UGPR 00-1

2<sup>nd</sup> Coat: DE Everest Interior Eg-Shel Paint EVER 30

3<sup>rd</sup> Coat: DE Everest Interior Eg-Shel Paint EVER 30

Gypsum Board – semi-gloss finish:

Provide the following system over interior gypsum board:

Option 1:

1<sup>st</sup> Coat: Premium Interior Acrylic Wall & Wood Primer B28W8111

2<sup>nd</sup> Coat: Super-Paint Interior Acrylic Semi-Gloss Enamel A88W1151 Series

3<sup>rd</sup> Coat: Super-Paint Interior Acrylic Semi-Gloss Enamel A88W1151 Series

Option 2:

1<sup>st</sup> Coat: DE Ultra-Grip Premium Int/Ext Primer UGPR 001

2<sup>nd</sup> Coat: DE Everest Interior Semi-Gloss Paint EVER 50

3<sup>rd</sup> Coat: DE Everest Interior Semi-Gloss Paint EVER 50

Wood – paint-grade:

Provide the following paint finish system over new interior wood surfaces:

Option 1:

1<sup>st</sup> Coat: Premium Interior Acrylic Wall & Wood Primer B28W8111

2<sup>nd</sup> Coat: Pro Classic Interior Acrylic Semi-Gloss Enamel B31W1151 Series

3<sup>rd</sup> Coat: Pro Classic Interior Acrylic Semi-Gloss Enamel B31W1151 Series

Option 2:

1<sup>st</sup> Coat: DE Ultra-Grip Premium Int/Ext Primer UGPR 001

2<sup>nd</sup> Coat: Everest Interior Semi-Gloss Paint EVER 50

3<sup>rd</sup> Coat: Everest Interior Semi-Gloss Paint EVER 50

***Ferrous Metal:***

Provide the following paint finish system over ferrous metal:

Option 1:

1<sup>st</sup> Coat: Pro-Cryl Universal Acrylic Metal Primer B66W310 Series

2<sup>nd</sup> Coat: Pro Industrial HP Acrylic Semi-Gloss Coating B66W651 Series

3<sup>rd</sup> Coat: Pro Industrial HP Acrylic Semi-Gloss Coating B66W651 Series

Option 2:

1<sup>st</sup> Coat: Pro-Cryl Universal Acrylic Metal Primer B66W310 Series

2<sup>nd</sup> Coat: PPG Pitt-Tech Satin Industrial Enamel 90-474

3<sup>rd</sup> Coat: PPG Pitt-Tech Satin Industrial Enamel 90-474

Zinc-Coated Metal:

Provide the following finish system over interior zinc-coated (galvanized) metal:

Option 1:

1<sup>st</sup> Coat: Pro-Cryl Universal Acrylic Metal Primer B66W310 Series

2<sup>nd</sup> Coat: Pro Industrial HP Acrylic Semi-Gloss Coating B66W651 Series

3<sup>rd</sup> Coat: Pro Industrial HP Acrylic Semi-Gloss Coating B66W651 Series

Option 2:

1<sup>st</sup> Coat: Pro-Cryl Universal Acrylic Metal Primer B66W310 Series

2<sup>nd</sup> Coat: PPG Pitt-Tech Satin Industrial Enamel 90-474

3<sup>rd</sup> Coat: PPG Pitt-Tech Satin Industrial Enamel 90-474