

21 12 00 - Fire-Suppression Standpipes

Buried piping and fittings: Cement-mortar lined, ductile iron pipe conforming to AWWA C-151, Class 200, 21/45 with Tyton or as approved, mechanical joints and fittings conforming to NFPA-24. Install pipe joints anchored with tie rods and restraints. Provide concrete thrust blocks at elbows and offsets conforming to NFPA-13 and NFPA-24. Other types of UL/FM reviewed piping including PVC C900 Class 200 may be used as approved by University's Representative and the State Fire Marshal. Thrust block installation shall be inspected by State Fire Marshal.

Above ground piping and fittings: Standard weight, Schedule 40, welded and seamless black steel, ASTM A-135 or A-53 pipe conforming to NFPA-13. Fittings for pipe sizes 2-1/2 inch and smaller shall be malleable iron, black, 150 lb. standard or cast iron, 175 lb. WP, screwed ends. Fittings for pipe sizes 3 inch and larger may be as above or weld fittings, ANSI 16.9, Schedule 40, flanged or welded fittings, cast iron, 175 lb. WP. Clamp type UL/FM approved fittings may be used on concealed piping where listed by the State Fire Marshal. Piping installed outdoors shall be galvanized.

Alternate piping system to be Victaulic, Grinnel, or equal grooved piping systems.

CPVC piping may be used in locations approved by NFPA 13 and the State Fire Marshal.

Commented [MDS2]: Albert to check