

07 84 13 - Penetration Firestopping

Wall and floor penetrations of cabling for telecommunications, fire alarm and security.

Manufacturer: Specified Technologies Inc. Model Series: EZ Path Fire Rated Pathways. Website:

[http://sti.fmpdata.net/ftp/Estimation Installation/ZIS1029 Grid Install Sheet.pdf](http://sti.fmpdata.net/ftp/Estimation%20Installation/ZIS1029%20Grid%20Install%20Sheet.pdf)

- Wall – Model: EZDP433GK-C with four colored pathways to be organized as follows: ORANGE = Fire Alarm, BLUE = Communications-Horizontal Cabling, YELLOW = Security and Door Access, and WHITE = Communications-Backbone Cabling (between telecom rooms).
- Floor – Model: Series 44 Modular Grid System in either one, two or four modules with pathways in banks of four with the option to utilize blank firestop filler panels in multi-slot grids. Four colored pathways to be organized as follows: ORANGE = Fire Alarm, YELLOW = Security and Door Access, and WHITE = Communications-Backbone Cabling (between telecom rooms).

Firestopping at fire rated openings for conduit and cable trays.

Through Penetration Firestopping of Fire Rated Assemblies: ASTM E814 with 0.10 inch water gage (24.9 Pa) minimum positive pressure differential to achieve fire F-Ratings and temperature T-Ratings not less than 1-hour.

- Wall Penetrations: Fire F-Ratings not less than 1-hour.
- Floor Penetrations: Fire F-Ratings and temperature T-Ratings not less than 1-hour.
- Through Penetration Firestopping of Non-Fire Rated Floor Assemblies: Materials to resist free passage of flame and products of combustion.
- Noncombustible Penetrating Items: Noncombustible materials for penetrating items connecting maximum of three stories.
- Penetrating Items: Materials approved by authorities having jurisdiction for penetrating items connecting maximum of two stories.

Firestopping Products:

Preferred Manufacturers and Models:

- Hilti (add more detail here and adjust full spec to reflect use of Hilti)
- 3M Fire Protection Products
- Tremco Inc.
- Spray on acoustic fireproofing (Universal Fireproofing patch) UL R25834
- Monokote?

Cable Tray:

- 3M, Model W-L-4004 - 24" x 4" steel or aluminum cable tray, 32% fill. Also referred as WL4004.
- Tremco, Model TREMstop PS, fire containment pillow system.
- Prohibited: Intumescent putty.

Metal Pipe:

- 3M, Model C-AJ-1001 or CAJ-1009
- Tremco, Model C-AJ-1179 or C-AJ-1187

Non-Metallic Pipe:

- 3M, Model C-AJ-2005
- 3M Fire Barrier FS-195+ Wrap/Strip – 2"x24", Intumescent elastomeric strip with foil on one side (UPC # 00051115071157), and Plastic Pipe Device PPD6 (UPC # 00051115082535) for 6" pipe, or Restricting Collar RC-1-2" (UPC #00054007083245) for 2" pipe
- Tremco, Model C-AJ-2082 or FA-2024

Cabling:

- 3M, Models

Single, Fire Barrier Pass-Through Devices:

- 2-1/2" Square (UPC # 00051115165962) and Mounting Brackets 2-1/2" SQ Single Mount (Pair) (UPC # 00051115187506)
- Fire Barrier Pass-Through Device 4" Square (UPC # 00051115165979) and Mounting Brackets 4" SQ Single Mounting (Pair) (UPC # 00051115187520)
- Fire Barrier Pass-Through Device 4" Round (UPC #00051115165986) and Mounting Brackets 4" Round Single Mount (Pair) (UPC # 00051115187544)

Multiple, Square Pass-Through:

- Fire Barrier Pass-Through Device 4" Square and Mounting Brackets 4" SQ Triple Mount (Pair) UPC # 00051115187537).
- Tremco