

22 06 00 - Schedule for Plumbing

Boiler / Chiller Room Plumbing

Provide floor drains / sinks for relief valve drains and to allow for drain down of closed loop systems. Coordinate locations with equipment layout so that piped equipment drains will not be a trip hazard in service aisles. Select floor drains/sinks to contain spill over and splashing due to equipment drain discharge.

Provide make up water through a RP backflow preventer for each closed loop system.

Plaster / Sand Use.

Rooms where plaster or other sediment material is used shall be equipped with a dedicated above grade sand trap on the drain outlet of each sink. Typical applications include art studios using plaster, anthropology labs using plaster for bone castings, etc.

Dark Rooms

Provide RP back flow preventers for hot and cold water to dark room sinks.

Fume Hoods

For each plumbing fume hood plumbing service, provide a manual isolation valve and union at the piping drop above each fume hood so that the hood can be easily removed with minimal disruption of building piping.

Commercial Kitchens

Per City of San Luis Obispo Waste Water Discharge Ordinance, a large outdoor grease trap is typically required. Position grease trap to allow for easy access for pumping and minimal nuisance odors at occupied locations while pumping.