

22 42 13 - Commercial Water Closets, Urinals, and Bidets

Toilets

- Student Apartments:
 - Toilet shall be 1.28 GPF vitreous china round front bowl, with direct flow priming jet and reverse trap. Hydraulic performance exceeding ANSI A112.19.2 requirements.
 - Seat: All plastic, closed front with cover, stainless steel hinge.
 - Campus Preference:
 - 1.28 HET Floor Mount Floor Discharge – American Standard 2234.001.020 1.1 - 1.6
 - 1.28 HET Floor Mount Floor Discharge (ADA) – American Standard 3461.001.020 1.1 - 1.6
- Public Restrooms (including dormitories):
 - Toilets shall be 1.28 GPF, wall hung with support carrier, vitreous china, elongated, flush valve type exceeding ANSI A112.19.2 requirements.
 - Campus Preference:
 - American Standard 2257.101.020 with Afwall 1.1 – 1.6 (1.28)
 - 1.28 GPF HET manual Toilet (No Piston Valve) – Zurn Z6000 AV Model
 - 1.28 GPF HET Sensor Toilet (No Piston) – ZER6000 CPM Model
 - Flush valve: 1.28 GPF
 - Flush Valves - Toilets (with infrared sensors):
 - Zurn ZER6000AV-ONE-CPM high efficiency flushometer valve
 - Campus no longer installs Flush Valves - Toilets without infrared sensors.
 - Seat: All plastic, open front elongated without cover; stainless steel hinge.
- Alternate toilet for single stall public rest rooms where light use is expected: Toilet shall be 1.28 GPF with hydro-pneumatic pressure assisted flush, vitreous china, floor mounted, elongated bowl, exceeding ANSI A112.19.2 requirements. Seat: All plastic, open front elongated without cover; stainless steel hinge.
- Toilet carrier manufactures Zurn, Josam, Mifab and J.R. Smith
- Not Recommended:
 - Toilet: Zurn Z5615 Series, Zurn Z5655 Series, and Zurn Z5665 Series 1.28 GPF Elongated vitreous china toilet. The toilet bowls are too shallow for proper water scouring when flushed.
 - Toilet Seat: Elongated Open Front Seat – Bemis 1955SCT

Urinals

Campus Standard, as appropriate for use/scope:

- Washbrook 0.125 GPF FloWise Washout Top Spud Urinal, or
- Z5758 “The Retrofit Pint” 0.125 gpf Ultra Low Consumption Urinal System (21” – 24” Footprint)
- Zurn-ZER 6003AV-CPM Model Sensor Operated Battery Powered Flush Valve for ¾” Urinals

Trap Adapters:

Standard: Use when waste line has a tubular trap. Purpose is to allow for easier maintenance.

Preferred Manufacturer and Model: Arrowhead Brass Products, #6001A, 1-1/2" M.I.P. x 1-1/2" Tube Size – Brass Nut, Brass Ferrule with stop. Male in Female UPC-1003.2.

<http://www.arrowheadbrass.com/products/>

Flushometers:

Flush Valves: Standard: Zurn