

26 05 29 - SUPPORTING DEVICES

PART 1 – GENERAL

1.01 SECTION INCLUDES

- A. Supporting devices for conduit, boxes, and equipment.

PART 2 – PRODUCTS

2.01 ACCEPTABLE MANUFACTURERS

- A. Hangers, straps and beam clamps:
 - 1. Efcor.
 - 2. Raco, Inc.
 - 3. Steel City
 - 4. O.Z./Gedney Co.
 - 5. Caddy Fastening System by ERICO Products Inc.
- B. Channels and fittings:
 - 1. Kindorf.
 - 2. Unistrut Corp.
- C. Anchors:
 - 1. Acherman-Johnson Corp.
 - 2. Phillips Drill Co.
 - 3. Rawl Products Co.

2.02 MATERIAL AND FABRICATION

- A. Hangers, steel cadmium-plated.
- B. Straps: One-hole and two-hole malleable iron, hot-dipped galvanized or steel, cadmium- or zinc-plated.
- C. Beam clamps, malleable iron, hot-dipped galvanized or cadmium-plated.
- D. Channels and fittings:
 - 1. Channels, hot-dipped galvanized.
 - 2. Fittings, galvanized.

- E. Anchors, self-drilling and expansion bolt types. No wood or fiber plugs or concrete nails are acceptable.

PART 3 – EXECUTION

3.01 INSTALLATION

- A. Fasten pad-mounted switchgear, capacitors, switches, and transformers in accord with manufacturer's recommendation for seismic zone 4. Submit manufacturers details for zone 4 fasteners and attachment or submit details prepared by a California licensed structural engineer.

END OF SECTION 26 05 29