

28 05 28 - Pathways for Electronic Safety and Security

Fire Alarm Cables:

Standard: Fire alarm sensor and network cables shall be in conduit.

Keys for Cabinets and Padlocks:

- Cabinets and Equipment: Provide 2 keys per panel. Coordinate with Section 08 06 05 – Key Schedule.
- Padlocks: Coordinate with Section 08 06 05 – Key Schedule.
- Closeout Submittal: Provide panel keys separated and labeled. Provide location, room number, quantity, manufacturer name and model numbers of keys, and coordinate closeout submittal with Section 08 06 05 – Key Schedule.