

31 23 33 - Trenching and Backfilling

Standard: Coordinate backfilling with installation of underground duct markers for utilities. Backfill with sand to 12 inches above utility duct. Install duct markers 6 inches below finished surface.

Schedule: Storm and Sanitary Piping: Cover pipe and bedding with inches

Utilities	Fill Type	Bedding and Cover Thickness, minimum	Compaction, minimum	Underground Duct Markers
Water Utilities Including Irrigation	Sand	1" below 3" above		
Sanitary Sewerage Utilities				
Storm Drainage Utilities				
Natural-Gas Distribution Utilities				
Hydronic Utilities			95%	
Electrical Utilities				
Communication			95%	