

نهر نظام معالجة المياه مع الصفيفة الترسيب

RIVER WATER TREATMENT SYSTEM WITH LAMELLA CLARIFIER




The design driver is fitting the most plate surfaces, at the most effective angle into the smallest per square foot space. This design allows the "settling area" or surface area to be as much as 10 times more than the actual floor space occupied by the clarifier. A significant reduction of the required floor space is achieved by reducing separation between plates to a few inches, and stacking the settling surfaces.

PRODUCT FEATURES


- Based on physical and chemical treatment
- Two standard systems having capacity of 50 m³/h and 100 m³/h; for higher capacities, custom designs are made with using multi-systems.
- 10 times the equivalent settling area of traditional clarifiers
- Corrosion-resistant and completely submerged PVC plates
- Plates installed at 55 degree for optimal solids settling
- Self-cleaning plates and no moving parts translate to low maintenance costs
- Space-saving footprint allows for efficient use of land

APPLICATIONS

- These compact treatment systems, which includes pre-chlorination, coagulation-flocculation, lamella clarification, sand filtration and post-chlorination, can be used ideally in which require separation of suspended solids, leaving effluent clear for discharge.
- The raw water will be collected from Iraqi rivers or other freshwater aquatic ecosystems, in order to produce potable water for several domestic purposes. (human consumption and other common uses).



The Area of Clarifier vs Lamella Settler



The treatment line of this water treatment plant includes:

1. PRE-CHLORINATION

The pre-treatment of raw water with chlorine previously to sedimentation or filtration is a very necessary operation, in order to obtain a quality for the treated, according to the WHO standards.

2. COAGULATION-FLOCCULATION

The aim of flocculation-coagulation process is to remove the very thin particles, called colloids that are very important water constituents. They cause turbulence and a lot of times form stable colloidal suspensions

3. LAMELLA CLARIFICATION

The clarification of the raw water after chemical treatment is usually carried out by gravity sedimentation. In order to reduce the required sedimentation surface, it is very common to use lamellar sedimentation. Effectively, in contrast to conventional sedimentation, lamella sedimentation offers a high sedimentation surface when available terrain surface is reduced. After sedimentation, the treated water passes to a storage tank (regulation tank), from which the water is pumped using horizontal centrifugal pumps to pressure sand filters.

4. SAND FILTRATION

The main purpose of the sand filtration is to remove all small particles and flocks that have not been removed in clarification process, in order to obtain clear water ready for public supply.

5. DISINFECTION (POST-CHLORINATION)

In order to ensure the final quality of the treated water, post-chlorination is necessary operation; specially regarding to required residual free chlorine levels.

WE HAVE THE EXPERIENCE