

LEDGERWOOD REFRIGERATION SERVICES, INC.
Remote Monitoring —Monthly Product Temperature Log

Site: Brightleaf Markets —Millbrook —Store 14

Agreement: SA-2019-4412

Period: July 1–31, 2020

Generated: August 14, 2020, 03:00 (automated)

Distribution: W. Achterberg (Brightleaf Facilities), cc P. Vandehey

System summary

Rack	Service	Setpoint	Mean	Max	Hours out of spec	Status
A-1	Dairy / deli	36 °F	35.9 °F	38.6 °F	0.0	In spec
A-2	Produce / prep	38 °F	38.2 °F	41.0 °F	0.0	In spec
B-3	Frozen food, aisle 12 + walk-in	–10 °F	–2.8 °F	+19.6 °F	96.0	Exception
B-4	Ice cream reach-in	–12 °F	–11.2 °F	–9.1 °F	0.0	In spec
C-1	Beverage / grab-and-go	38 °F	37.6 °F	40.0 °F	0.0	In spec

Rack B-3 —exception detail

Sixteen excursions recorded, aggregate 96.0 hours out of spec, against 31.5 hours in the January 2020 period. Peak product temperature +19.6 °F on July 22. Excursion interval has shortened from roughly nine days to roughly two.

Discharge-side telemetry is not captured by the remote monitoring package on this site. Discharge temperature is available only by gauging at the rack.

This log is generated and transmitted automatically on the 14th of each month under §6.2 of SA-2019-4412. It is not reviewed by Ledgerwood personnel prior to transmission. Exceptions do not generate a service order. To request service, open an order through the customer portal.