

Solar[®] Turbines

A Caterpillar Company

Wire List

PD/Unit Number:

4M231 / 1

Project Name:

PROP-92

Sheet Name:

MCC PNL,SMT130

Revision:

0.1

PERSONNEL / SWS SIGN-IN

BADGE #	DATE	TIME	WIRER	IPV
-----	--/--/----	--:-- --	☐	☐
-----	--/--/----	--:-- --	☐	☐
-----	--/--/----	--:-- --	☐	☐
-----	--/--/----	--:-- --	☐	☐
-----	--/--/----	--:-- --	☐	☐
-----	--/--/----	--:-- --	☐	☐

Table of Contents

#	SECTION	ROWS	PAGE
LOCATION: MCC PNL SMT130			
1	Grounds	8	3
2	Clips	2	3
3	FU Jumpers	3	3
	L-FU0290-FU0295	3	3
4	AF/AU Jumpers	10	3
5	Single Connections	71	3
	L-FU0290	1	3
	L-FU0295	1	3
	L-XT0295	1	3
	L-XT0290	2	3
	L-XT2920	7	3
	L-XT0292	1	3
	L-KA2960	2	3
	L-AU0290	2	3
	L-AF0291	22	3
	L-AF0292	4	3
	L-AF0293	4	3
	L-AF0296	16	3
	L-AF0297	8	3
6	Cables	17	6

4M231 PROP-92 - Wire List

Unit: 1 Rev: 0.1 Rows: 111

LOCATION:
MCC PNL,SMT130

Grounds (8)

FROM					TO				
✓	DEVICE ID	NO.	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
☐	AF0293:SH	AU0290G	GRN	14	☐	AU0290:GND	MCC PANEL	☐	
☐	AF0295:SH	IEG22403	GRN	14	☐	IEG2240:3	PANEL A	☐	
☐	AF0293:SH	AF0294G	GRN	14	☐	AF0294:SH	MCC PANEL	☐	
☐	AF0294:SH	AF0295G	GRN	14	☐	AF0295:SH	MCC PANEL	☐	
☐	GR0291	GR0291	GRN/YEL	14	☐	FRAME	MCC PANEL	☐	
☐	GR0290	GR0290	GRN	14	☐	IEG2240:1	PANEL A	☐	
☐	PEG2240:14	PEG224014	GRN/YEL	8	☐	PEG0140:0	GEN CMPNT	☐	
☐	PEG2240:1	-0V	GRN/YEL	14	☐	XT0104:6	PANEL A	☐	

Clips (2)

FROM			TO				
✓	DEVICE ID	WIRE ID	✓	DEVICE ID	LOCATION	IPV	NOTES
☐	XT0295:1	CLIP	☐	XT0295:2	MCC PANEL	☐	
☐	XT0295:2	CLIP	☐	XT0295:3	MCC PANEL	☐	

FU Jumpers (3)

FROM					TO				
✓	DEVICE ID	NO.	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
FU0290-FU0295									
☐	FU0290:LI	FU0136	WHT	14	☐	FU0291:LI	MCC PANEL	☐	
☐	FU0291:LI	FU0136	WHT	14	☐	FU0294:LI	MCC PANEL	☐	
☐	FU0294:LI	FU0136	WHT	14	☐	FU0295:LI	MCC PANEL	☐	

AF/AU Jumpers (10)

FROM					TO				
✓	DEVICE ID	NO.	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
☐	AF0292:V+	AF0292P	WHT	16	☐	AF0293:V+	MCC PANEL	☐	
☐	AF0292:COM	AF0292N	WHT	16	☐	AF0293:COM	MCC PANEL	☐	
☐	AF0293:V+	AF0293P	WHT	16	☐	AF0294:V+	MCC PANEL	☐	
☐	AF0293:COM	AF0293N	WHT	16	☐	AF0294:COM	MCC PANEL	☐	
☐	AF0294:V+	AF0294P	WHT	16	☐	AF0295:V+	MCC PANEL	☐	
☐	AF0294:COM	AF0294N	WHT	16	☐	AF0295:COM	MCC PANEL	☐	

FROM					TO				
✓	DEVICE ID	NO.	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
☐	AF0295:V+	AF0295P	WHT	16	☐	AF0296:V+	MCC PANEL	☐	
☐	AF0295:COM	AF0295N	WHT	16	☐	AF0296:COM	MCC PANEL	☐	
☐	AF0296:V+	AF0296P	WHT	16	☐	AF0297:V+	MCC PANEL	☐	
☐	AF0296:COM	AF0296N	WHT	16	☐	AF0297:COM	MCC PANEL	☐	

Single Connections (71)

FROM					TO				
✓	DEVICE ID	NO.	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
SB0400									
☐	SB0400:B2-11	SB0400B211	WHT	20	☐	AF0297:36	MCC PNL SMT130	☐	
☐	SB0400:B2-12	SB0400B212	WHT	20	☐	AF0297:04	MCC PNL SMT130	☐	
FU - XT									
☐	FU0290:LI	FU0136	WHT	14	☐	XT0102:4	PANEL A	☐	
☐	FU0295:LD	FU0295	WHT	16	☐	XT0292:29	MCC PANEL	☐	
XT - XT									
☐	XT0295:1	-0V	WHT	14	☐	XT0104:4	PANEL A	☐	
☐	XT0292:30	-0V	WHT	16	☐	XT0295:2	MCC PANEL	☐	
XT0290									
☐	XT0290:4	ESTOPB	WHT	20	☐	XT2920:7	MCC PANEL	☐	
☐	XT0290:3	ESTOPC	WHT	20	☐	XT0563:2	PWR DIST DOOR	☐	
XT2920									
☐	XT2920:5	SB951211	WHT	20	☐	XT0337:25	GEN CMPNT	☐	
☐	XT2920:6	SB951212	WHT	20	☐	XT0337:26	GEN CMPNT	☐	
☐	XT2920:7	ESTOPB	WHT	20	☐	XT0337:27	GEN CMPNT	☐	
☐	XT2920:8	ESTOPA	WHT	20	☐	XT0337:28	GEN CMPNT	☐	
☐	XT2920:9	ESTOP	WHT	20	☐	XT0334:1	GEN CMPNT	☐	
☐	XT2920:10	KA0131A1	WHT	20	☐	XT0334:2	GEN CMPNT	☐	
☐	XT2920:4	ESTOPD	WHT	20	☐	XT0563:1	PWR DIST DOOR	☐	
KA2960									
☐	KA2960:11	CCATS29601	WHT	16	☐	XT0292:31	MCC PANEL	☐	
☐	KA2960:14	CCATS29602	WHT	16	☐	XT0292:32	MCC PANEL	☐	
AU0290									
☐	AU0290:V+	FU0290	WHT	16	☐	FU0290:LD	MCC PANEL	☐	
☐	AU0290:COM	-0V	WHT	16	☐	XT0295:1	MCC PANEL	☐	
AF0291									
☐	AF0291:V+	FU0291	WHT	16	☐	FU0291:LD	MCC PANEL	☐	
☐	AF0291:COM	-0V	WHT	16	☐	XT0295:1	MCC PANEL	☐	
☐	AF0291:27	HL0411BB	WHT	20	☐	XT0292:18	MCC PANEL	☐	
☐	AF0291:26	HL0409BB	WHT	20	☐	XT0292:16	MCC PANEL	☐	
☐	AF0291:25	SH04756	WHT	20	☐	XT0292:24	MCC PANEL	☐	
☐	AF0291:24	SH04706	WHT	20	☐	XT0292:12	MCC PANEL	☐	

FROM					TO				
✓	DEVICE ID	NO.	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
☐	AF0291:23	SH04716	WHT	20	☐	XT0292:6	MCC PANEL	☐	
☐	AF0291:19	KA2960A2	WHT	20	☐	KA2960:A2	MCC PANEL	☐	
☐	AF0291:11	HL0411BA	WHT	20	☐	XT0292:17	MCC PANEL	☐	
☐	AF0291:10	HL0409BA	WHT	20	☐	XT0292:15	MCC PANEL	☐	
☐	AF0291:09	SH04755	WHT	20	☐	XT0292:23	MCC PANEL	☐	
☐	AF0291:08	SH04705	WHT	20	☐	XT0292:11	MCC PANEL	☐	
☐	AF0291:07	SH04715	WHT	20	☐	XT0292:5	MCC PANEL	☐	
☐	AF0291:03	KA2960A1	WHT	20	☐	KA2960:A1	MCC PANEL	☐	
☐	AF0291:21	KA3103A2	WHT	20	☐	KA3103:A2	GEN CMPNT	☐	
☐	AF0291:20	-029120	WHT	20	☐	KA2320:A2	GEN CMPNT	☐	
☐	AF0291:17	KA2970A2	WHT	20	☐	KA2970:A2	GEN CMPNT	☐	
☐	AF0291:16	KA3420A2	WHT	20	☐	KA3420:A2	GEN CMPNT	☐	
☐	AF0291:05	KA3103A1	WHT	20	☐	KA3103:A1	GEN CMPNT	☐	
☐	AF0291:04	-029104	WHT	20	☐	KA2320:A1	GEN CMPNT	☐	
☐	AF0291:01	KA2970A1	WHT	20	☐	KA2970:A1	GEN CMPNT	☐	
☐	AF0291:00	KA3420A1	WHT	20	☐	KA3420:A1	GEN CMPNT	☐	
AF0292									
☐	AF0292:V+	FU0294	WHT	16	☐	FU0294:LD	MCC PANEL	☐	
☐	AF0292:COM	-0V	WHT	16	☐	XT0295:2	MCC PANEL	☐	
☐	AF0292:32	UJ01310K1	WHT	20	☐	UJ0131:0K1	PANEL A	☐	
☐	AF0292:00	UJ01310K2	WHT	20	☐	UJ0131:0K2	PANEL A	☐	
AF0293									
☐	AF0293:03	-0V	WHT	16	☐	XT0295:3	MCC PANEL	☐	
☐	AF0293:01	-0V	WHT	20	☐	XT0295:3	MCC PANEL	☐	
☐	AF0293:02	UJ0131IOUT	WHT	20	☐	UJ0131:IOUT	PANEL A	☐	
☐	AF0293:00	UJ0131VIN	WHT	20	☐	UJ0131:VIN	PANEL A	☐	
AF0296									
☐	AF0296:42	SA047511	WHT	20	☐	XT0290:7	MCC PANEL	☐	
☐	AF0296:41	SA047523	WHT	20	☐	XT0290:5	MCC PANEL	☐	
☐	AF0296:39	SB0403BC	WHT	20	☐	XT0292:27	MCC PANEL	☐	
☐	AF0296:38	SB0402BC	WHT	20	☐	XT0292:25	MCC PANEL	☐	
☐	AF0296:35	SH04753	WHT	20	☐	XT0292:19	MCC PANEL	☐	
☐	AF0296:34	SB047111	WHT	20	☐	XT0292:13	MCC PANEL	☐	
☐	AF0296:33	SH04701	WHT	20	☐	XT0292:7	MCC PANEL	☐	
☐	AF0296:32	SH04713	WHT	20	☐	XT0292:1	MCC PANEL	☐	
☐	AF0296:10	SA047512	WHT	20	☐	XT0290:8	MCC PANEL	☐	
☐	AF0296:09	SA047524	WHT	20	☐	XT0290:6	MCC PANEL	☐	
☐	AF0296:07	SB0403BNO	WHT	20	☐	XT0292:28	MCC PANEL	☐	
☐	AF0296:06	SB0402BNO	WHT	20	☐	XT0292:26	MCC PANEL	☐	
☐	AF0296:03	SH04754	WHT	20	☐	XT0292:20	MCC PANEL	☐	
☐	AF0296:02	SB047112	WHT	20	☐	XT0292:14	MCC PANEL	☐	

FROM					TO				
✓	DEVICE ID	NO.	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
☐	AF0296:01	SH04702	WHT	20	☐	XT0292:8	MCC PANEL	☐	
☐	AF0296:00	SH04714	WHT	20	☐	XT0292:2	MCC PANEL	☐	
AF0297									
☐	AF0297:35	SB047221	WHT	20	☐	XT0290:1	MCC PANEL	☐	
☐	AF0297:34	SB951211	WHT	20	☐	XT2920:5	MCC PANEL	☐	
☐	AF0297:33	SB851211	WHT	20	☐	XT2920:1	MCC PANEL	☐	
☐	AF0297:03	SB047222	WHT	20	☐	XT0290:2	MCC PANEL	☐	
☐	AF0297:02	SB951212	WHT	20	☐	XT2920:6	MCC PANEL	☐	
☐	AF0297:01	SB851212	WHT	20	☐	XT2920:2	MCC PANEL	☐	

Cables (17)

FROM					TO				
✓	DEVICE ID	TYPE	WIRE ID	SIZE	✓	DEVICE ID	LOCATION	IPV	NOTES
Cable: WC7622									
☐	AF0293:38	WC7622	RED	20	☐	XT0337:4	GEN CMPNT	☐	
☐	AF0293:06	WC7622	BLK	20	☐	XT0337:5	GEN CMPNT	☐	
☐	AF0293:54	WC7622	SH	20	☐	XT0337:6	GEN CMPNT	☐	
Cable: WC7890									
☐	AF0293:25	WC7890	RED-TR1	18	☐	XT7100:1	JB7100	☐	
☐	AF0293:09	WC7890	WHT-TR1	18	☐	XT7100:2	JB7100	☐	
☐	AF0293:08	WC7890	BLK-TR1	18	☐	XT7100:3	JB7100	☐	
☐	AF0293:56	WC7890	SH-TR1	18	☐	FW1:1	JB7100	☐	
☐	AF0293:27	WC7890	RED-TR2	18	☐	XT7100:4	JB7100	☐	
☐	AF0293:11	WC7890	WHT-TR2	18	☐	XT7100:5	JB7100	☐	
☐	AF0293:10	WC7890	BLK-TR2	18	☐	XT7100:6	JB7100	☐	
☐	AF0293:58	WC7890	SH-TR2	18	☐	FW2:1	JB7100	☐	
☐	AF0293:29	WC7890	RED-TR3	18	☐	XT7100:7	JB7100	☐	
☐	AF0293:13	WC7890	WHT-TR3	18	☐	XT7100:8	JB7100	☐	
☐	AF0293:12	WC7890	BLK-TR3	18	☐	XT7100:9	JB7100	☐	
☐	AF0293:60	WC7890	SH-TR3	18	☐	FW3:1	JB7100	☐	
Cable: WC0603									
☐	AU0290:L1	WC0603	ENET	CABLE	☐	AP0603:L2	PLC PANEL	☐	
Cable: WC0029									
☐	AU0290:L2	WC0029	ENET	CABLE	☐	AU0200:L1	TCP	☐	