


TEST SHEET 100 - Hardware Inspection	
Test #	Comments
1	The wire markers shall be provided properly for all wires.
2	Engraved label shall be provided for all nameplates.
3	Lifting lugs shall be provided.
4	Warning label for 220V AC shall be provided.
5	Final NMR-63 shall be submitted by the main vendor. (TRANSTEL SCOPE)
6	Relay Cabinet termination shall be identified & wired by the vendor.
7	Top Fan Ventilation shall be more for easy airflow.
Date:	
TESTED BY	PROJECT COORDINATOR
 ☒ Witnessed Code: 19/05/2018 KSA-001	DANISH KHAN  PRS ENGINEER ZEESHAN FARRUKH 

provide gland plate with cable gland for field cabinet.

Field cabinet

Fahad AK
Sadiq Ansari

Muhammad Zeeshan - Traffic Tech Gulf

From: Danish Khan
Sent: Saturday, May 21, 2011 11:12 AM
To: Leslie Low
Cc: mohammed Adil Abou; Shahid Hussain; Zeeshan Farrukh; Daniel Napitupulu; Marli Mallani; Amanda Sam; Muhammad Luniara
Subject: SUCCESSFULL PRS FAT
Attachments: FAT document.pdf
Importance: High

Dear Leslie,

Find attach is the FAT documents which is signed by the ERAM & PETROFAC on Thursday 19th May 2011. There were very few/minor comments that has raised by Inspector regarding to the hardware setup which all will comply to the final installation on site.

Attach test report is for your records. Please be informed that we have not received the design of the PASS/STOP light Pole from you. Also do let us know where you want us to deliver the material expect the Pole which has to fabricate. Send us the address for the disposal.

Thanks and Regards,

Regards,

Danish Khan
Project Manager

Email: danish.khan@fore-vision.com
Mobile: +966 55 147 3472
Web: www.fore-vision.com
Al Mubrah Group P.O. Box 20002
Jeddah 21455, Saudi Arabia
T +966 2 647 5746 loc. 122
F +966 2 648 3459

FORE VISION
blending business with technology

This email and any files transmitted with it are intended for, and should only be read by the intended addressee. Its contents are confidential, and if you are not the intended addressee, please notify the sender immediately, and delete all records of the message from your computer. Any reproduction, dissemination, copying, disclosure, modification, distribution and/or publication of this message without the written consent of the sender are strictly prohibited.